

From: [REDACTED]  
To: [REDACTED]  
Cc: [REDACTED]  
Subject: [REDACTED] Response from the applicant  
Date: 15 April 2019 19:58:18  
Attachments: [REDACTED]

I note in their response of April 10 to your request to revise the Statement of Common Ground between National Grid and Horizon, see attached, the applicant cannot be bothered, or as they put it "there is insufficient time to meaningfully engage"

I assume, and hope, that you will not tolerate such abuse of the process

The position at the hearings is factually incorrect. It needs to be revised

Many thanks  
Jonathan

This email has been scanned by the Symantec Email Security cloud service.  
For more information please visit <http://www.symanteccloud.com>

iPad

19:49  
infrastructure.planninginspectorate.gov.uk

82%

## Horizon's Response to ExA's Request for Further Information

Horizon's Response to Rule 17 Letter Question	
	<p><b>App 403 Addendum 2</b></p> <p><b>(ii) Add additional Clause 3.3.5 after Clause after 3.3.4.</b></p> <p><i>3.3.5 Horizon require the new NG 400kV connection to be completed to support back energisation and commissioning of Unit 1 during Q2 Year 6 (latest). This is an ONR Regulatory Level 1 Hold Point which shall require Horizon to demonstrate security of the grid connected supply prior to commencement of commissioning activities.</i></p> <p>d) Horizon should advise that there is insufficient time available to engage meaningfully with NG to review and agree any required amendments to the Statement of Common Ground. The position reported at the Hearings in March 2019 remains valid.</p>

Sent from my iPad