



SCOTTISHPOWER
RENEWABLES



East Anglia ONE North and East Anglia TWO Offshore Windfarms

Draft Statement of Common Ground Environment Agency

Applicants: East Anglia ONE North Limited and East Anglia TWO Limited
Document Reference: ExA.SoCG-3.D0.V1
SPR Reference: EA1N_EA2-DWF-ENV-REP-IBR-000876

Date: June 2020
Revision: Version 01
Author: Royal HaskoningDHV

Applicable to **East Anglia ONE North** and **East Anglia TWO**



Revision Summary				
Rev	Date	Prepared by	Checked by	Approved by
01	10/06/2020	Paolo Pizzolla	Julia Bolton / Ian Mackay	Rich Morris

Description of Revisions			
Rev	Page	Section	Description
01	n/a	n/a	First draft SoCG issued to Examining Authority



Table of Contents

1	Introduction	1
1.1	Background	1
1.2	The Development	2
1.3	Summary of Agreed, Not Agreed and Outstanding Matters	3
2	Statement of Common Ground	4
2.1	Site Selection and Assessment of Alternatives	4
2.2	Ground Conditions and Contamination	8
2.3	Water Resources and Flood Risk	13
2.4	Onshore Ecology	23
3	Signatures	28



Glossary of Acronyms

APP	Application Document
CoCP	Code of Construction Practice
DCO	Development Consent Order
EA	Environment Agency
EIA	Environmental Impact Assessment
ES	Environmental Statement
ETG	Expert Topic Group
FRA	Flood Risk Assessment
HDD	Horizontal Directional Drill
HRA	Hydrogeological Risk Assessment
NE	Natural England
OCoCP	Outline Code of Construction Practice
OLEMS	Outline Landscape and Ecological Management Strategy
PEIR	Preliminary Environmental Information Report
SoCG	Statement of Common Ground
SPA	Special Protected Area
WFD	Water Framework Directive



Glossary of Terminology

Applicants	East Anglia TWO Limited / East Anglia ONE North Limited
Cable sealing end compound	A compound which allows the safe transition of cables between the overhead lines and underground cables which connect to the National Grid substation.
Cable sealing end (with circuit breaker) compound	A compound (which includes a circuit breaker) which allows the safe transition of cables between the overhead lines and underground cables which connect to the National Grid substation.
East Anglia ONE North project	The proposed project consisting of up to 67 wind turbines, up to four offshore electrical platforms, up to one construction, operation and maintenance platform, inter-array cables, platform link cables, up to one operational meteorological mast, up to two offshore export cables, fibre optic cables, landfall infrastructure, onshore cables and ducts, onshore substation, and National Grid infrastructure.
East Anglia TWO project	The proposed project consisting of up to 75 wind turbines, up to four offshore electrical platforms, up to one construction, operation and maintenance platform, inter-array cables, platform link cables, up to one operational meteorological mast, up to two offshore export cables, fibre optic cables, landfall infrastructure, onshore cables and ducts, onshore substation, and National Grid infrastructure.
East Anglia TWO windfarm site / East Anglia ONE North windfarm site	The offshore area within which wind turbines and offshore platforms will be located.
Horizontal directional drilling (HDD)	A method of cable installation where the cable is drilled beneath a feature without the need for trenching.
Inter-array cables	Offshore cables which link the wind turbines to each other and the offshore electrical platforms, these cables will include fibre optic cables.
Jointing bay	Underground structures constructed at intervals along the onshore cable route to join sections of cable and facilitate installation of the cables into the buried ducts.
Landfall	The area (from Mean Low Water Springs) where the offshore export cables would make contact with land, and connect to the onshore cables.
Meteorological mast	An offshore structure which contains metrological instruments used for wind data acquisition.
Mitigation areas	Areas captured within the onshore development area specifically for mitigating expected or anticipated impacts.
National electricity grid	The high voltage electricity transmission network in England and Wales owned and maintained by National Grid Electricity Transmission
National Grid infrastructure	A National Grid substation, cable sealing end compounds, cable sealing end (with circuit breaker) compound, underground cabling and National Grid overhead line realignment works to facilitate connection to the national electricity grid, all of which will be consented as part of the proposed East Anglia TWO / East Anglia ONE North project Development Consent Order but will be National Grid owned assets.
National Grid overhead line realignment works	Works required to upgrade the existing electricity pylons and overhead lines (including cable sealing end compounds and cable sealing end (with



	circuit breaker) compound) to transport electricity from the National Grid substation to the national electricity grid.
National Grid substation	The substation (including all of the electrical equipment within it) necessary to connect the electricity generated by the proposed East Anglia TWO / East Anglia ONE North project to the national electricity grid which will be owned by National Grid but is being consented as part of the proposed East Anglia TWO / East Anglia ONE North project Development Consent Order.
National Grid substation location	The proposed location of the National Grid substation.
Offshore electrical platform	A fixed structure located within the windfarm area, containing electrical equipment to aggregate the power from the wind turbines and convert it into a more suitable form for export to shore.
Offshore export cables	The cables which would bring electricity from the offshore electrical platforms to the landfall. These cables will include fibre optic cables.
Offshore infrastructure	All of the offshore infrastructure including wind turbines, platforms, and cables.
Offshore platform	A collective term for the construction, operation and maintenance platform and the offshore electrical platforms.
Onshore cable corridor	The corridor within which the onshore cable route will be located.
Onshore cable route	This is the construction swathe within the onshore cable corridor which would contain onshore cables as well as temporary ground required for construction which includes cable trenches, haul road and spoil storage areas.
Onshore cables	The cables which would bring electricity from landfall to the onshore substation. The onshore cable is comprised of up to six power cables (which may be laid directly within a trench, or laid in cable ducts or protective covers), up to two fibre optic cables and up to two distributed temperature sensing cables.
Onshore development area	The area in which the landfall, onshore cable corridor, onshore substation, landscaping and ecological mitigation areas, temporary construction facilities (such as access roads and construction consolidation sites), and the National Grid Infrastructure will be located.
Onshore infrastructure	The combined name for all of the onshore infrastructure associated with the proposed East Anglia TWO / East Anglia ONE North project from landfall to the connection to the national electricity grid.
Onshore substation	The East Anglia TWO / East Anglia ONE North substation and all of the electrical equipment within the onshore substation and connecting to the National Grid infrastructure.
Platform link cable	Electrical cable which links one or more offshore platforms. These cables will include fibre optic cables.
Scour protection	Protective materials to avoid sediment being eroded away from the base of the foundations as a result of the flow of water.
Transition bay	Underground structures at the landfall that house the joints between the offshore export cables and the onshore cables.



1 Introduction

1.1 Background

1. This Statement of Common Ground (SoCG) has been prepared by East Anglia TWO Limited, East Anglia ONE North Limited (the Applicants) and the Environment Agency. It identifies areas of the East Anglia TWO and East Anglia ONE North Development Consent Order (DCO) applications (the Applications) where matters are agreed or not agreed between the parties.
2. The Applicants have had regard to the guidance for the examination of applications for development consent (Department for Communities and Local Government, 2015) when compiling this SoCG.
3. This SoCG has been structured to reflect topics of the Applications which are of interest to the Environment Agency. Topic specific matters agreed, not agreed and actions to resolve between the Applicants and the Environment Agency are included within this SoCG.
4. The tables presented below represent the SoCG with the Applicants and the Environment Agency in respect of the following topics:
 - Site Selection and Consideration of Alternatives;
 - Ground Conditions and Contamination;
 - Water Resources and Flood Risk;
 - Onshore Ecology; and
 - Development Consent Order (DCO).
5. Throughout the SoCG the phrase “Agreed” identifies any point of agreement between the Applicants and the Environment Agency. The phrase “Not Agreed” identifies any point that is not yet agreed between the Applicants and the Environment Agency.
6. The matters considered within this SoCG apply to the Environment Agency’s statutory remit which includes groundwater, contamination, onshore riparian habitats within the onshore development area, and flood risk in relation to Main Rivers (i.e. the Hundred River). Matters that are not yet agreed will be the subject of ongoing discussion between the Applicants and the Environment Agency to reach agreement on each matter wherever possible, or refine the extent of disagreement between parties. The notes column of the SoCG tables provides commentary on these matters.



7. This document is applicable to both the East Anglia TWO and East Anglia ONE North DCO applications, and therefore is endorsed with the yellow and blue icon used to identify materially identical documentation in accordance with the Examining Authority's procedural decisions on document management of 23rd December 2019 (PD-004). Whilst this document has been submitted to both Examinations, if it is read for one project submission there is no need to read it for the other project submission.

1.2 The Development

8. The key offshore components of each project will comprise:
- Offshore wind turbines and their associated foundations;
 - Offshore platforms - up to four offshore electrical platforms and their associated foundations supporting some of the windfarm's electrical equipment, and up to one construction, operation and maintenance platform and associated foundations that may cater for personnel and activities required during the construction phase and operation and maintenance of the windfarm;
 - Sub-sea cables between the wind turbines and offshore electrical platforms (inter-array), between separate offshore platforms (platform link cables) and between offshore electrical platforms and the landfall (export cables);
 - Scour protection around foundations and on inter-array, platform link and export sub-sea cables as required; and
 - Potential for one meteorological mast and its associated foundations for monitoring wind speeds during the operational phase of the windfarm.
9. The key onshore components of each project will comprise:
- The landfall site with up to two transition bays to connect the onshore and offshore cables;
 - Up to six onshore cables, up to two fibre optic cables and up to two distributed temperature sensing (DTS) cables installed underground (some or all of which may be installed in ducts) and associated jointing bays installed underground;
 - Onshore substation; and
 - Electrical cable connection between the onshore substation and National Grid substation.
10. National Grid infrastructure will also be required to connect each project to the national electricity grid. Key components of the National Grid infrastructure which is common to both projects will comprise:



- National Grid substation;
- Cable sealing end compounds and a cable sealing end (with circuit breaker) compound; and
- Realignment of the existing overhead lines; including the reconstruction or replacement of up to three existing overhead pylons in proximity to the National Grid substation and the addition of up to one new pylon in close proximity to existing overhead pylons.

1.3 Summary of Agreed, Not Agreed and Outstanding Matters

11. **Table 1** provides a summary of the matters agreed, not agreed and those which are outstanding between the Applicants and the Environment Agency for each of the relevant SoCG topics areas. For further information on agreements that are outstanding / under discussion and for which the Applicants and the Environment Agency are working to address during the examination period, please refer to the Notes column of **Table 3**, **Table 5**, **Table 7** and **Table 9**.

Table 1 Summary of Agreed, Not Agreed and Outstanding Matters

Topic	Summary
Site Selection and Assessment of Alternatives	Discussed at Meeting 1 and 2 – All matters Agreed after minor updates to the wording within the agreement table.
Ground Conditions and Contamination	Discussed at Meeting 1 and 2 – All matters Agreed following discussion and clarification of post consent requirements.
Water Resources and Flood Risk	Discussed at Meeting 1 and 2 – Matters in relation to Existing Environment and Mitigation are Agreed. Matters in relation to the Assessment Methodology regarding Works No. 37 are not agreed however an acceptable solution to resolve this matter has been agreed. Measures related to groundwater dependent ecological sites are under discussion.
Onshore Ecology	Discussed at Meeting 1 and 2 – All matters Agreed.
DCO	Discussed at Meeting 1 and 2 – All matters Agreed save for ongoing discussion on measures related to groundwater dependent ecological sites.



2 Statement of Common Ground

12. A summary of the consultation undertaken to date with the Environment Agency and the matters agreed or not agreed between the Applicants and the Environment Agency (based on discussions and information exchanged between the Applicants and the Environment Agency during the pre-application and examination phases of the Applications) are set out below for each of the SoCG topic areas.

2.1 Site Selection and Assessment of Alternatives

13. The Projects have the potential to impact upon the physical and human environment. **Chapter 4 Site Selection and Assessment of Alternatives** of the Environmental Statement (ES) (APP-052) details the methodology adopted for the site selection and assessment of alternatives process and presents the range of locations considered for the siting of each Project's offshore and onshore infrastructure.
14. **Table 2** provides an overview of consultation undertaken with the Environment Agency regarding the site selection and assessment of alternatives. Further details on the stakeholder engagement process for site selection and assessment of alternatives can be found in the Consultation Report (APP-029).

Table 2 Summary of consultation with the Environment Agency regarding site selection and assessment of alternatives

Date	Contact Type	Topic
Pre-Application		
20 th February 2018	Meeting	Site selection refinement, assessment of alternatives methodology and site visit
23 rd May 2018	Meeting	Discussion of landfall and coastal processes
7 th June 2018	Meeting	Site selection outcomes (post Phase 2 consultation) and definition of Onshore Development Area
Post-Application		
6 th February 2020	Meeting	SoCG meeting 1
28 th February 2020	Meeting	SoCG meeting 2

15. **Table 3** presents the matters agreed or not agreed in relation to site selection and assessment of alternatives.



Table 3 Site Selection and Assessment of Alternatives

ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
Site Selection and Assessment of Alternatives						
EA-001	Development of the Proposed Onshore Development Area	The methodology adopted for selecting and assessing the onshore development area (insofar as it relates to the Environment Agency's statutory remit) is considered robust and appropriate.	Agreed	Agreed	Agreed	None
EA-002	Landfall Site Selection and Alternatives	The methodology adopted for selecting and assessing the landfall location options, including the final option (insofar as it relates to the Environment Agency's statutory remit), is considered robust and appropriate.	Agreed	Agreed	Agreed	None
EA-003	Onshore Cable Corridor	The methodology adopted for selecting and assessing the onshore cable corridor (insofar as it relates to the Environment Agency's statutory remit), is considered robust and appropriate.	Agreed	Agreed	Agreed	It is noted that the Environment Agency has no preference in respect of the open trench or trenchless technique options for crossing the Sandlings SPA, providing the method selected and associated mitigation measures reflect the ecological sensitivity of the area.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
EA-004	Onshore Substation and National Grid substation Location	The methodology adopted for selecting and assessing the onshore substation and National Grid substation location options, including the final option (insofar as it relates to the Environment Agency's statutory remit), is considered robust and appropriate.	Agreed	Agreed	Agreed	None
EA-005	Mitigation	Following the selection of the landfall location, the proposed embedded mitigation adopted to ensure the integrity of the cliff is not compromised and to allow for natural coastal erosion, namely a minimum setback distance of 85m from the cliff top to the transition bays (Section 6.6.2 of Chapter 6 Project Description of the ES (APP-054)) and use of trenchless technique (Section 6.6.2 of Chapter 6 Project Description of the ES (APP-054)) is considered robust and appropriate.	Agreed	Agreed	Agreed	East Suffolk Council is the lead coastal protection authority for this section of the coastline. It is noted that Requirement 13 of the draft DCO requires a landfall construction method statement to be prepared by the Applicants and approved by relevant local authority prior to the landfall works commencing.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
Draft Development Consent Order (DCO)						
EA-006	Wording of Requirement(s)	Requirement 13 of the draft DCO (Landfall construction method statement) commits the applicant to producing a method statement for the construction of the landfall works. This will require approval from the relevant planning authority prior to the landfall works commencing. With this in place, measures to mitigate any impacts associated with the landfall construction are adequately secured.	Agreed	Agreed	Agreed	It was agreed that the Applicants would consult with the Environment Agency during preparation of the Landfall Construction Method Statement.
Other Matters as Required						
EA-007	None	Not applicable	Not applicable	Not applicable	Not applicable	None



2.2 Ground Conditions and Contamination

16. The Projects have the potential to impact upon ground conditions and contamination. **Chapter 18 Ground Conditions and Contamination** of the ES (APP-066) provides an assessment of the significance of these impacts.
17. **Table 4** provides an overview of consultation undertaken with the Environment Agency regarding ground conditions and contamination. Further details on the stakeholder engagement process for ground conditions and contamination can be found in the Consultation Report (APP-029).

Table 4 Summary of consultation with the Environment Agency regarding ground conditions and contamination

Date	Contact Type	Topic
Pre-Application		
26 th April 2018	Meeting	Method statement, project updates and approach to the assessment (methodology, impacts, data collection, etc.)
7 th November 2018	Meeting	Presentation of assessment, impacts and mitigation in advance of publication of the preliminary environmental information report (PEIR)
Post-Application		
6 th February 2020	Meeting	SoCG meeting 1
28 th February 2020	Meeting	SoCG meeting 2

18. **Table 5** presents the matters agreed or not agreed in relation to ground conditions and contamination.



Table 5 Ground Conditions and Contamination

ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
Environmental Impact Assessment						
EA-101	Existing Environment	Sufficient desk-based data has been collected to inform the assessment.	Agreed	Agreed	Agreed	None
EA-102	Assessment Methodology	The impact assessment methodologies used for the EIA provide an appropriate approach to assessing potential impacts of the project.	Agreed	Agreed	Agreed	The Applicant will adopt the terms 'Principal Aquifer' rather than 'Major Aquifer', 'Secondary Aquifer' rather than 'Minor Aquifer' and 'Unproductive Strata' rather than 'Non Aquifer' in future documentation.
EA-103	Assessment Methodology	The worst case scenario presented in the assessment is appropriate.	Agreed	Agreed	Agreed	None
EA-104	Assessment Conclusions	The ES adequately characterises the baseline environment in terms of ground conditions and contamination.	Agreed	Agreed	Agreed	In principle the Environment Agency agree with all items listed under EA-104, EA-105 and EA-106, subject to the approved Code of Construction Practice (CoCP) incorporating appropriate provisions to deliver the embedded mitigation set out in Section 18.3.3 in Chapter 18 Ground Conditions and Contamination of the ES (APP-066).



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						It was agreed that this would be noted in an updated OCoCP.
EA-105	Assessment Conclusions	The assessment of impacts for construction, operation and decommissioning presented are consistent with the agreed assessment methodologies.	Agreed	Agreed	Agreed	As above
EA-106	Assessment Conclusions	The assessment of cumulative impacts is consistent with the agreed methodologies.	Agreed	Agreed	Agreed	As above
EA-107	Mitigation	No mitigation other than that identified as the embedded mitigation within section 18.3.3 of Chapter 18 Ground Conditions and Contamination (APP-066) is required.	Agreed	Agreed	Agreed	None
Draft Development Consent Order (DCO)						
EA-108	Wording of Requirement(s)	The wording of Requirement 22 provided within the draft DCO (and supporting certified documents) with reference to development of a Code of	Agreed	Agreed	Agreed	It was agreed that the Applicants would consult with the Environment Agency during preparation of relevant sections of the CoCP and this would be noted in an updated OCoCP.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
		Construction Practice for the mitigation and monitoring of potential impacts on ground conditions and contamination, is appropriate and adequate.				The OCoCP will also be updated to state that the Applicants encourage environmental emergency response plans to be tested on-site in consultation with the Local Planning Authority and the Environment Agency.
EA-109	Wording of Requirement(s)	The wording of Requirement 18 provided within the draft DCO (and supporting certified documents) with reference to 'a written scheme to mitigate the potential for release of contaminants' which includes an investigation and assessment report and the implementation of mitigation measures, is appropriate and adequate.	Agreed	Agreed	Not Agreed – Under Discussion	It is agreed that the undertaking of hydrogeological risk assessments prior to construction activities commencing within 250m of a borehole or spring, will be incorporated within an updated OCoCP. The Applicant and the Environment Agency continue to discuss measures related to groundwater dependent ecological sites.
EA-110	Outline Code of Construction Practice	The Environment Agency request hydrogeological risk assessments to be undertaken for intrusive pre-commencement archaeology investigations and construction works within 250m of a borehole or spring, prior to construction commencing in that area, to assess pollution pathways and	Agreed	Agreed	Not Agreed – Under Discussion	It was agreed that this would be noted in an updated OCoCP and an updated outline pre-commencement archaeology execution plan. The Applicant and the Environment Agency continue to discuss measures related to groundwater dependent ecological sites.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
		ensure risks to groundwater and to the use of the abstraction point are considered within the hydrogeological risk assessment.				
EA-111	Outline Code of Construction Practice	The Environment Agency request that no chemicals be stored within 50m of a watercourse of water abstraction borehole.	Agreed	Agreed	Agreed	It was agreed that this would be noted in an updated OCoCP.
Other Matters as Required						
EA-112	None	Not applicable	Not applicable	Not applicable	Not applicable	None



2.3 Water Resources and Flood Risk

19. The Projects have the potential to impact upon ground conditions and contamination. **Chapter 20 Water Resources and Flood Risk** of the ES (APP-068) provides an assessment of the significance of these impacts.
20. **Table 6** provides an overview of consultation undertaken with the Environment Agency regarding water resources and flood risk. Further details on the stakeholder engagement process for water resources and flood risk can be found in the Consultation Report (APP-029).

Table 6 Summary of consultation with the Environment Agency regarding water resources and flood risk

Date	Contact Type	Topic
Pre-Application		
27 th April 2018	Meeting	Method statement, project updates and approach to the assessment (methodology, impacts, data collection, etc.)
7 th November 2018	Meeting	Presentation of assessment, impacts and mitigation in advance of publication of the PEIR
2 nd May 2019	Meeting	Post-PEIR consultation feedback
Post-Application		
6 th February 2020	Meeting	SoCG meeting 1
28 th February 2020	Meeting	SoCG meeting 2

21. **Table 7** presents the matters agreed or not agreed in relation to water resources and flood risk.



Table 7 Water Resources and Flood Risk

ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
Environmental Impact Assessment						
EA-201	Existing Environment	Sufficient desk-based data has been collected to inform the assessment.	Agreed	Agreed	Agreed	None
EA-202	Assessment Methodology	Save for works at Work No. 37 (at Marlesford Bridge) the impact assessment methodologies used for the EIA provide an appropriate approach to assessing potential impacts of the project.	Agreed	Agreed	Agreed	None
EA-203	Assessment Methodology	The impact assessment methodologies used for the EIA provide an appropriate approach to assessing potential impacts of the project within Work No. 37 (Marlesford Bridge).	Agreed	Agreed	Not Agreed	Work No. 37 is within Flood Zone 3a & 3b, a functional floodplain. Until detailed assessment works and detailed design is undertaken, it is not possible to establish the precise nature of works required at Work No. 37, or in particular whether ground raising, re-profiling or construction of structures that may divert or affect flood waters will be required. The Applicant will consult the Environment Agency on the need for a Flood Risk Activity Permit for works within Work No. 37 prior to



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						such works commencing. Such works are likely to be classified as 'essential infrastructure'. The Applicants and Environment Agency agree that to resolve this matter the Applicants will undertake a Flood Risk Assessment of works required within Work No. 37 as part of any future Environmental Permit application.
EA-204	Assessment Methodology	The worst case scenario presented in the assessment is appropriate.	Agreed	Agreed	Agreed	None
EA-205	Assessment Conclusions	Chapter 20 Water Resources and Flood Risk Assessment (APP-068) of the ES and Appendix 20.3 Flood Risk Assessment (APP-496) of that chapter adequately characterises the baseline environment in terms of water resources and flood risk.	Agreed	Agreed	Not Agreed – under discussion	It was agreed that the final CoCP will include references to all existing abstraction licences, all domestic abstractions and all protected rights; and ensure no derogation. It was agreed that should trenchless techniques be required along the onshore cable corridor the final CoCP will include a Method Statement for the works which will provide details of the design parameters and any measures to minimise impacts upon groundwater.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						As per EA-110, it was agreed that the final CoCP will include reference to hydrogeological risk assessments where required i.e. where works are undertaken within 250m of a borehole or spring. It was agreed that the final CoCP will include reference to the undertaking of pre-construction water features surveys (visual inspections) where required. The water features surveys will be used to ensure all water features have been identified so that they can be assessed, and hydrogeological risk assessments completed as necessary prior to works starting. It was agreed that the final CoCP will identify whether dewatering activities require an environmental permit. The CoCP will specify that any water removed from subsurface excavations is returned to ground, and that any water removed from a watercourse will be returned to the same watercourse, unless otherwise agreed with the Environment Agency. The above points will be noted in an updated OCoCP.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						The Applicant and the Environment Agency continue to discuss measures related to groundwater dependent ecological sites.
EA-206	Assessment Conclusions	The assessment of impacts for construction, operation and decommissioning presented are consistent with the agreed assessment methodologies.	Agreed	Agreed	Agreed	It was agreed that the final CoCP will detail the hierarchy of foul water drainage (i.e. connection to mains sewer network or septic tank) and justify the selected foul water drainage solution. This will be noted in an updated OCoCP.
EA-207	Assessment Conclusions	The assessment of cumulative impacts is consistent with the agreed methodologies.	Agreed	Agreed	Agreed	None
EA-208	Mitigation	The embedded mitigation identified within Section 20.3.3 of the Environmental Statement (document reference 6.1.20) and the means for implementation are appropriate and adequate. Any further mitigation requirements will be considered pre-construction within the final CoCP.	Agreed	Agreed	Agreed	It was agreed that the Applicant would consult with the Environment Agency during preparation of relevant sections of the CoCP and this would be noted in an updated OCoCP.
Draft Development Consent Order (DCO)						



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
EA-209	Wording of Requirement(s)	The wording of Requirement 18 provided within the draft DCO (and supporting certified documents) with reference to 'a written scheme to mitigate the potential for release of contaminants' which includes an investigation and assessment report and the implementation of mitigation measures, is appropriate and adequate.	Agreed	Agreed	Agreed	None
EA-210	Wording of Requirement(s)	The wording of Requirement 22 provided within the draft DCO (and supporting certified documents) with reference to development of a Code of Construction Practice for the mitigation and monitoring of potential impacts to water resources and flood risk is appropriate and adequate.	Agreed	Agreed	Not Agreed – under discussion	It is noted that Requirement 22 of the draft DCO includes the provision of a groundwater protection method statement (<i>Requirement 22(2)(h) a pollution prevention and response plan including a groundwater protection method statement and construction method statements for the protection of onshore water</i>). The OCoCP will be updated to include specific reference to the groundwater protection method statement which will consider impacts to groundwater quality and ensure methodologies to minimise




ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						construction-phase groundwater quality impacts are in place. The OCoCP will be updated to state that the Applicant encourages environmental emergency response plans to be tested on-site in consultation with the Local Planning Authority and the Environment Agency. The final CoCP will include provisions which commit the Applicants to not store materials within Flood Zone 2 or Flood Zone 3 along the length of the onshore cable route, and to store spoil outside of the Hundred River flood plain. It is agreed that the undertaking of hydrogeological risk assessments prior to construction activities commencing within 250m of a borehole or spring will be incorporated within the wording of an updated OCoCP. The purpose of a hydrogeological risk assessment will be to ensure groundwater flows are maintained. The hydrogeological risk assessments should primarily concern an assessment of whether or not the works will significantly disrupt groundwater flow to abstractions (active and non-active) and



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						environmental water features (along with any monitoring and mitigation requirements). The mobilisation of contamination should also be included where relevant. The Applicant and the Environment Agency continue to discuss measures related to groundwater dependent ecological sites.
Other Matters as Required						
EA-211	Licensed agricultural abstraction	The licensed agricultural abstraction on the Hundred River (Work No. 19) should not be disrupted as a result of any temporary works on the river.	Agreed	Agreed	Agreed	It was agreed that any over-pumping at the Hundred River crossing (Work No. 19) would be a non-consumptive operation (i.e. no transmission loss). This is to be stipulated in the final CoCP. It was agreed that relevant abstraction licence holder(s) are to be consulted by the Applicants about any works at the Hundred River which have the potential to disrupt flow. It was agreed that appropriate measures are to be identified within the final CoCP to ensure that sufficient flow is maintained along the Hundred River. The above will be noted in an updated OCoCP.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
EA-212	Water Framework Directive	The Environment Agency require the implications of the updated Water Framework Directive coming into force in 2021 to be considered.	Agreed	Agreed	Agreed	For each waterbody that could be affected by the Projects, the Applicant will review whether the Water Framework Directive status objectives have changed and determine whether such changes have any implications for the findings of the assessment. This review will be secured through the final Ecological Management Plan secured under Requirement 21 of the DCO. The above will be noted in an updated Outline Landscape and Ecological Management Strategy (OLEMS).
EA-213	Surface water drainage	A Flood Risk Activity Permit may be required to connect the surface water drainage into the Main River (Friston Watercourse).	Agreed	Agreed	Agreed	The surface water discharge rate entering the system is not within the remit of the Environment Agency and would be subject to approval from Suffolk County Council prior to discharge to Friston Watercourse. However, the physical connection into the existing Main River channel would require a Flood Risk Activity Permit from the Environment Agency. The above will be noted in an updated OLEMS.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
EA-214	Existing compensation discharge	The final CoCP will include information on surface water flow rates and discharge rates during temporary works to ensure the compensation discharge currently operated by Essex & Suffolk Water at the Hundred River (Work No. 19) can be maintained.	Agreed	Agreed	Agreed	It is agreed that Applicants will demonstrate that temporary arrangements to maintain flow at the Hundred River crossing will be sufficient to convey the compensation discharge. The above will be noted in an updated OCoCP.



2.4 Onshore Ecology

22. The Projects have the potential to impact upon ground conditions and contamination. **Chapter 22 Onshore Ecology** of the ES (APP-070) provides an assessment of the significance of these impacts.
23. **Table 8** provides an overview of consultation undertaken with the Environment Agency regarding onshore ecology. Further details on the stakeholder engagement process for onshore ecology can be found in the Consultation Report (APP-029).

Table 8 Summary of consultation with the Environment Agency regarding onshore ecology

Date	Contact Type	Topic
Pre-Application		
20 th February 2018	Meeting	Survey methodologies and mitigation requirements
27 th April 2018	Meeting	Method statement, project updates and approach to the assessment (methodology, impacts, data collection, etc.)
5 th November 2018	Meeting	Presentation of assessment, impacts and mitigation in advance of publication of the PEIR
9 th May 2019	Meeting	Post-PEIR consultation feedback
Post-Application		
6 th February 2020	Meeting	SoCG meeting 1
28 th February 2020	Meeting	SoCG meeting 2

24. **Table 9** presents the matters agreed or not agreed in relation to onshore ecology.



Table 9 Onshore Ecology

ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
Environmental Impact Assessment						
EA-301	Existing Environment	Sufficient desk-based data and survey data has been collected to inform the assessment to meet the standard and requirements of the Environment Agency.	Agreed	Agreed	Agreed	It is agreed that the following pre-construction surveys will be undertaken: • Reptiles • Eel • Fish • Otter • Water vole The scope of the above surveys will be specified in the Ecological Management Plan. An updated OLEMS will specify that the Environment Agency will be consulted on the scope of those pre-construction surveys that fall within the Environment Agency's remit.
EA-302	Assessment Methodology	The impact assessment methodologies used for the EIA provide an appropriate approach to assessing potential impacts of the project (insofar as it relates to	Agreed	Agreed	Agreed	Pre-construction surveys will inform the detailed design and construction works.



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
		the Environment Agency's statutory remit),				
EA-303	Assessment Methodology	The worst case scenario presented in the assessment is appropriate (insofar as it relates to the Environment Agency's statutory remit),	Agreed	Agreed	Agreed	None
EA-304	Assessment Conclusions	The ES adequately characterises the baseline environment in terms of onshore ecology (insofar as it relates to the Environment Agency's statutory remit),	Agreed	Agreed	Agreed	The Environment Agency requests the Applicants provide a description of the baseline for eel and coarse fish prior to construction commencing. The eel and fish baseline established by pre-construction surveys will be presented within the Ecological Management Plan. As per EA-301, an updated OLEMS will specify that the Environment Agency will be consulted on the scope of the eel and fish pre-construction surveys.
EA-305	Assessment Conclusions	The assessment of impacts for construction, operation and decommissioning presented are consistent with the agreed assessment methodologies.	Agreed	Agreed	Agreed	The Environment Agency agrees on points EA-305 and EA-306, subject to specific details being set out within the Watercourse Crossing Method Statement which will draw on pre-construction surveys and a full



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
						understanding of the construction works to be undertaken and subsequent effects. An Outline Watercourse Crossing Method Statement will be produced during Examination which will confirm the above process.
EA-306	Assessment Conclusions	The assessment of cumulative impacts is consistent with the agreed methodologies (insofar as it relates to the Environment Agency's statutory remit).	Agreed	Agreed	Agreed	As above
EA-307	Mitigation	No mitigation other than that identified as the embedded mitigation within section 22.3.3 of Chapter 22 Onshore Ecology (APP-070) is required (insofar as it relates to the Environment Agency's statutory remit).	Agreed	Agreed	Agreed	None
Draft Development Consent Order (DCO)						
EA-308	Wording of Requirement(s)	The wording of Requirement 21 provided within the draft DCO (and supporting certified documents) with reference to	Agreed	Agreed	Agreed	It was agreed that the Environment Agency would be consulted by the Applicants during preparation of the Ecological Management



ID	Topic	Statement	East Anglia TWO Limited Position	East Anglia ONE North Limited Position	Environment Agency Position	Notes
		development of an Ecological Management Plan for the mitigation and monitoring of potential impacts to onshore ecology is appropriate and adequate (insofar as it relates to the Environment Agency's statutory remit).				Plan and this would be noted in an updated OLEMS.
EA-309	Wording of Requirement(s)	The wording of Requirement 22 provided within the draft DCO (and supporting certified documents) with reference to development of a Code of Construction Practice for the mitigation and monitoring of potential impacts to onshore ecology is appropriate and adequate (insofar as it relates to the Environment Agency's statutory remit).	Agreed	Agreed	Agreed	It was agreed that the Environment Agency would be consulted by the Applicants during preparation of the Watercourse Crossing Method Statement and this would be noted in an updated OCoCP.
Other Matters as Required						
EA-310	None	Not applicable	Not applicable	Not applicable	Not applicable	None



3 Signatures

25. The above Statement of Common Ground is agreed between East Anglia TWO Limited, East Anglia ONE North Limited and the Environment Agency on the day specified below.

Signed: _____

Print Name: _____

Job Title: _____

Date: _____

Duly authorised for and on behalf of the **Environment Agency**

Signed: _____

Print Name: _____

Job Title: _____

Date: _____

Duly authorised for and on behalf of **East Anglia TWO Limited**

Signed: _____

Print Name: _____

Job Title: _____

Date: _____

Duly authorised for and on behalf of **East Anglia ONE North Limited**