



Marine
Management
Organisation

Marine Licensing
Tyneside House
Skinnerburn Road
Newcastle Business Park Newcastle upon Tyne
NE4 7A

T +44 (0)300 123 1032
www.gov.uk/mmo

██████████
Consents Manager
Sheringham Shoal and
Dudgeon Offshore Wind Farm
1 Kingdom Street
London
W2 6BD
By email only

Our reference:
DCO/2019/00004/Variation 1

26 June 2026

Dear ██████████,

THE SHERINGHAM SHOAL AND DUDGEON EXTENSIONS OFFSHORE WIND FARM ORDER 2024 (“the Order”) – VARIATION 1 (SCHEDULES 10, 11, 12, & 13)

On 17 April 2024 the Secretary of State granted consent for the Sheringham Shoal (SEP) and Dudgeon (DEP) Extensions Offshore Wind Farm Order 2024 (“the Order”) which included, in Schedules 10, 11, 12, and 13, four Deemed Marine Licences (DMLs) in accordance with Section 149 of the Planning Act 2008.

On 5 November 2024 the Marine Management Organisation (MMO) received a request from the Equinor New Energy Limited to vary the DMLs for the Sheringham Shoal and Dudgeon Extensions Offshore Wind Farm Order (Schedules 10, 11, 12, and 13) contained within the Order. The request was to make the following key changes:

- Increases to the total rotor-swept area for SEP and DEP (from 1.00 km² to up to 1.42km² for SEP and from 1.30 km² to up to 1.85 km² for DEP);
- Corresponding increases to the minimum air gap (air gap being the distance between the lowest point of the rotating blade of a wind turbine generator and highest astronomical tide);
- An increase to the maximum number of interlink cables from three to four in the event two Offshore Substation Platforms (OSPs) are constructed (Scenarios 1(c), 1(d), 2 or 3 as defined in the Order) or in the case that only DEP is constructed (scenario 1(b) as defined in the Order) and from seven to eight in the event one OSP is constructed for SEP and DEP (in the SEP wind farm site, Scenario 4 as defined in the Order) together with related increases to interlink cable protection area and volume and to the maximum number of interlink cable crossings for Scenarios 1(b), 1(c), 1(d), 2, 3, and 4;
- An increase to the maximum area and volume of infield cable protection and a reduction in infield cable crossings associated with Work No. 2B for all scenarios; and



- Amendments to correctable errors identified in the Correction Application (where relevant), together with additional corrections relevant to the DMLs only

The MMO has now completed its consideration of these requests and, in exercise of the powers conferred by section 72(3) (d) of the Marine and Coastal Access Act 2009, has varied the DMLs as detailed in the Notices of Variation enclosed.


Also enclosed is a copy of the varied DMLs.

This documentation is publicly available on the MMO's website at:

<https://www.gov.uk/government/collections/marine-licensing-nationally-significant-infrastructure-projects>

In accordance with regulation 3 of The Marine Licensing (Notices Appeals) Regulations 2011, you may appeal the notice of variation to the First-tier Tribunal. If you wish to appeal then in accordance with Rule 22(1)(b) of the Tribunal Procedure (First-tier Tribunal)(General Regulatory Chamber) Rules 2009 (SI 2009/1976) you have 28 days from the date of the sending of the notice of variation to send or deliver a notice of appeal to the First-tier Tribunal.

Yours Sincerely



Marine Licensing Case Manager



@marinemanagement.org.uk

Enc:

Variation 1 of Sheringham Shoal and Dudgeon Extensions Offshore Wind Farm Order 2024 Schedules 10-13
Notice of Variation 1 for Schedules 10, 11, 12, and 13 of the Sheringham Shoal and Dudgeon Extensions
Offshore Wind Farm Order 2024



