



N O R T H F A L L S

Offshore Wind Farm

Electro-Magnetic Fields Technical Statement

Document Reference: 9.39
Volume: 9
Date: April 2025
Revision: 0

Project Reference: EN010119



Project	North Falls Offshore Wind Farm
Document Title	Electro-Magnetic Fields Technical Statement
Document Reference	9.39
Supplier	Blake Clough
Supplier Document ID	BCC10694

This document and any information therein are confidential property of North Falls Offshore Wind Farm Limited and without infringement neither the whole nor any extract may be disclosed, loaned, copied or used for manufacturing, provision of services or other purposes whatsoever without prior written consent of North Falls Offshore Wind Farm Limited, and no liability is accepted for loss or damage from any cause whatsoever from the use of the document. North Falls Offshore Wind Farm Limited retains the right to alter the document at any time unless a written statement to the contrary has been appended.

Revision	Date	Status/Reason for Issue	Originator	Checked	Approved
0	April 2025	Deadline 4	BC	NFOW	NFOW

BCC10694

North Falls Offshore Wind

EMF Assessment

Client: RWE



Document Control

Revision	Status	Prepared by	Checked by	Approved by	Date
R0	First Issue	WA	OA	SM	30/03/2025
R1	Second Issue	WA	OA	SM	16/04/2025

Project Title: North Falls Offshore Wind EMF Assessment

Project Reference: BCC10694

Client: RWE

Website: www.blakeclough.com

Contact Email: [REDACTED]@blakeclough.com

Contact Number: [REDACTED]

This report has been prepared exclusively for the purposes of the Project and Client set out above. It is intended solely for the use of the Client in relation to this Project. No third party may rely upon or derive any rights from the content, analysis or conclusions of this report. The author accepts no responsibility or liability to any person or entity for the use or reliance on this report, either in whole or in part.

Any reproduction, distribution, or use of the report, in any form, without the prior written consent of the author [or the Client], is strictly prohibited. Copyright © [Blake Clough Consulting Ltd] [2025].

Contents

Document Control	2
1. Introduction	6
1.1. Scope	6
1.2. Project Description	6
1.3. Computation Tool.....	8
1.4. Standards and Technical Specifications.....	9
2. Design Data	10
2.1. Environmental Parameters Assumptions	10
2.2. Cable Installation Assumptions.....	10
2.3. General Assumptions	10
2.4. Load Rating.....	11
2.5. Scenarios	11
2.6. Cable Details.....	11
2.7. Cable Trench and HDD Details.....	12
3. EMF Assessment Study.....	14
3.1. Scenario 1	14
3.1.1. Simulation Parameters and Cables Details	14
3.1.2. Simulation Results	14
3.2. Scenario 1a	16
3.2.1. Simulation Parameters and Cables Details	16
3.2.2. Simulation Results	16
3.3. Scenario 2	18
3.3.1. Simulation Parameters and Cables Details	18
3.3.2. Simulation Results	18
3.4. Scenario 2a	20
3.4.1. Simulation Parameters and Cables Details	20
3.4.2. Simulation Results	20
3.5. Scenario 3	22
3.5.1. Simulation Parameters and Cables Details	22
3.5.2. Simulation Results	22
3.6. Scenario 3a	24
3.6.1. Simulation Parameters and Cables Details	24
3.6.2. Simulation Results	24
3.7. Scenario 4	26
3.7.1. Simulation Parameters and Cables Details	26
3.7.2. Simulation Results	26

3.8.	Scenario 4a	28
3.8.1.	Simulation Parameters and Cables Details	28
3.8.2.	Simulation Results	28
3.9.	Scenario 5	30
3.9.1.	Simulation Parameters and Cables Details	30
3.9.2.	Simulation Results	30
3.10.	Scenario 5a	32
3.10.1.	Simulation Parameters and Cables Details	32
3.10.2.	Simulation Results	32
3.11.	Scenario 6	34
3.11.1.	Simulation Parameters and Cables Details	34
3.11.2.	Simulation Results	34
3.12.	Scenario 6a	36
3.12.1.	Simulation Parameters and Cables Details	36
3.12.2.	Simulation Results	36
3.13.	Scenario 7	38
3.13.1.	Simulation Parameters and Cables Details	38
3.13.2.	Simulation Results	38
3.14.	Scenario 8	40
3.14.1.	Simulation Parameters and Cables Details	40
3.14.2.	Simulation Results	40
3.15.	Scenario 9	42
3.15.1.	Simulation Parameters and Cables Details	42
3.15.2.	Simulation Results	42
3.16.	Scenario 10	44
3.16.1.	Simulation Parameters and Cables Details	44
3.16.2.	Simulation Results	44
4.	Comparison of All Scenarios Result	46
5.	EMF Compliance.....	47
5.1.	Public Exposure Limits:	47
6.	Conclusion	48
7.	References.....	49
	Appendix-A Datasheets	51
	Appendix-B Simulation Report	57

List of Abbreviations

AC	Alternating Current
DC	Direct Current
TR	Thermal Resistivity
HDD	Horizontal Directional Drilling
XLPE	Cross Link Polyethylene
HV	High Voltage
LV	Low Voltage
P	Active Power
PF	Power Factor
POC	Point of Connection
POS	Point of Supply
p.u.	Per Unit
EMF	Electromagnetic Field Intensity
NF	North Fall
VE	Five Estuaries

Units

kV	Kilovolts
MV	Megavolt
MVA	Megavolt-Amperes
MVAr	Megavar
MW	Megawatt
μT	Micro Tesla

1. Introduction

1.1. Scope

Blake Clough has been contracted by RWE to conduct an Electromagnetic Field Assessment (EMF) of the proposed onshore cables for the North Falls Offshore Wind farm. This project involves conducting simulations to assess the electromagnetic field (EMF) impacts of underground cable systems installed at different depths below the surface. The objective is to evaluate the compliance of the cable scenarios with UK guidance notes and provide necessary recommendations for achieving compliance where required.

The objectives of the project are as follows:

- Perform simulations to analyse the EMF emissions from various underground cable configurations.
- Assess the compliance of the EMF levels with regulations and standards.
- Generate results and reports, including necessary graphs, to present findings.
- Provide recommendations on modifications, if necessary, to meet compliance.

The primary objective of this study is to assess the potential EMF levels to ensure they remain within acceptable limits while also meeting the project's operational needs and environmental guidelines.

1.2. Project Description

The North Falls Offshore Wind Farm project involves the installation of onshore export cables (underground cables) to connect the offshore wind farm to the national grid at 400 kV. The onshore cable length from the offshore wind cable to the national grid is around 21.6 km. The onshore export cable consists of two circuits of 220 kV with 800 MW capacity or 275 kV with 1000 MW capacity.

An Electromagnetic Field (EMF) study is required to assess the impact of the cables on the surrounding environment, especially considering the proximity of residential and commercial areas. This report will evaluate different burial methods, including open trench and Horizontal Directional Drilling (HDD), with varying depths to ensure minimal disruption and compliance with health and safety standards.

Figure 1-1 shows the onshore cable route of the export cable. The 400 kV onshore substation is located at point 31 on the map, with the PoC into the National Grid located at point 32.

The North fall onshore cable (NF) route is shared with another project – Five Estuaries (VE). So, this project will also be considered when assessing the EMF values.




Figure 1-1: Onshore boundary overview map of North falls offshore wind.

Figure 1-2 shows the single line diagram of the North fall offshore wind.




Figure 1-2: Project single line diagram.

1.3. Computation Tool

The current rating study was conducted using ELEK Cable HV V7.0 by Electrotechnik [1], which complies with IEC 60287 [3] and CIGRE TB 880 [4].

ELEK Software for cable calculation is a robust and versatile tool that supports electrical professionals in the design and analysis of cable systems. Its advanced features, compliance with standards, and user-friendly interface make it an essential resource for ensuring the safety, efficiency, and reliability of electrical installations. Some key features are given below:

Load Calculation: Determines the appropriate cable size based on current-carrying capacity and load requirements.

Temperature Effects: Assesses the impact of operating temperatures on cable performance and selects the right cable size to handle heat dissipation effectively.

Heat Dissipation: Simulates thermal conditions to evaluate heat dissipation and ensure cables operate within safe temperature ranges.

Ambient Conditions: Takes into account ambient temperature and installation conditions to adjust calculations accordingly.

Short-Circuit Rating: Analysis the cable's ability to withstand short-circuit conditions, providing information on the required protection measures.

Electromagnetic Field (EMF) Analysis: Evaluates the electromagnetic field exposure from cables to ensure compliance with health and safety standards. The software helps in determining cable burial depths and configurations to minimize EMF impact, ensuring the safety of personnel and the surrounding environment.

1.4. Standards and Technical Specifications

As a minimum, the following Table 1-1 shows the standards and technical specifications that have been considered as the basis of the underground cable EMF assessment.

Table 1-1: Applicable standards and technical specifications.

STANDARD / TECHNICAL DOCUMENT	DOCUMENT TITLE
IEC 60287	Calculation of the Continuous Current Rating of Cables
SPTS 2.5	General Requirements for 132, 275, 400kV Cables
ENA TS 12-24	Technical specification for plastic ducts for buried electric cables
ENA EREC C55	Insulated sheath power cable systems
ICNIRP	International Commission on Non-Ionizing Radiation Protection

2. Design Data

2.1. Environmental Parameters Assumptions

Table 2-1 presents the environmental parameters used for the cable EMF assessment. The environmental parameters are assumed in accordance with IEC 60287-3-1, and a soil thermal resistivity value is considered 1.2 K.m/W. For accurate cable sizing, it is essential to obtain the site-specific soil thermal resistivity values. In some cases, the actual value may exceed the assumed value of 1.2 K.m/W, potentially leading to significant under sizing of the cable. The Relative Soil Permeability value is assumed to be 1. No Solar radiation is assumed.

Table 2-1: Environmental parameters.

Parameter	Value
Ground temperature for cable ducted installation	15 °C
Maximum ambient temperature	30 °C
Thermal resistivity of soil	1.2 Km/W
Relative soil permeability	1
Solar Radiation	No solar radiation (trench layout)

2.2. Cable Installation Assumptions

The following cable installation parameters are assumed for the simulation of all scenarios.

- The thermal resistivity of the soil is considered to be 1.2 K.m/W.
- The relative permeability of the soil is considered to be 1.
- The ground temperature of soil is considered to be 15 °C.
- The maximum temperature of the conductor is considered to be 90 °C.
- All ducts are ID/OD 237/250 mm PVC ducts.
- Cable arrangement is considered flat with spacing.
- Cross bonded – regularly transposed.

2.3. General Assumptions

- For the worst case, the open trench depth of laying is considered as 1100 mm.
- EMF values will be measured at ground level and 1 m above ground level.
- A 0.95 pf is considered while calculating the load current as per the Grid code [7] for export conditions, as a connection agreement is not available.
- General cable datasheets are used as the cable brand is not finalized. Datasheets are attached in the appendix.
- Due to the unavailability of a similar datasheet for 275 kV as for 220 kV and 400 kV cables, a 330 kV datasheet is used for 275 kV (parameters are compared to another datasheet of 275 kV to make sure all values are within limits).

2.4. Load Rating

As per the provided information about export capacities, Table 2-2 summarises the current requirements in different scenarios, which is calculated using:

$$I_R = \frac{S}{\sqrt{3} * V_{L-L} * PF}$$

I_R : Rated Current (A)

S : Apparent Power (VA)

V_{LL} : Line to Line Voltage (V)

Table 2-2: Required current rating of the circuits.

Circuits	Voltage (kV)	Capacity (MW)	Total Current (A)
North Fall Export cable	220	850	2349
North Fall Export cable	275	1000	2210
Five Estuaries Cable	275	1080	2387
North Fall 400kV Cable	400	850	1292
North Fall 400kV Cable	400	1000	1520

2.5. Scenarios

As per the provided information, Table 2-3 presents all scenarios which will be considered for the EMF assessment. As the total export capacity of North Fall wind farm is still not finalised, both 850 MW with 220 kV and 1000 MW with 275 kV are being considered along with Five Estuaries 275 kV circuit.

Table 2-3: Project study scenarios.

Scenarios	Installation Condition	NF Voltage (kV)	NF Wind Farm capacity (MW)	VE Voltage (kV)	VE Wind Farm capacity (MW)
Scenario 1	Open Cut Trench	220	850	-	-
Scenario 1a		220	850	275	1080
Scenario 2		275	1000	-	-
Scenario 2a		275	1000	275	1080
Scenario 3	Shallow HDD	220	850	-	-
Scenario 3a		220	850	275	1080
Scenario 4		275	1000	-	-
Scenario 4a		275	1000	275	1080
Scenario 5	Deep HDD	220	850	-	-
Scenario 5a		220	850	275	1080
Scenario 6		275	1000	-	-
Scenario 6a		275	1000	275	1080
Scenario 7	Open Cut Trench	400	850	-	-
Scenario 8		400	1000	-	-
Scenario 9	Shallow HDD	400	850	-	-
Scenario 10		400	1000	-	-

2.6. Cable Details

As per the provided information, Table 2-4 presents the cable size and required current rating per cable run in all scenarios.

Table 2-4: Cable details and required current per cable run.

Circuits	Voltage (kV)	Capacity (MW)	Cable Size	No. of Cables / Cores	Required Current (A) per Cable Run
North Fall Export cable	220	850	2500 mm ² Al.	2 runs of 3 x 1c	1174
North Fall Export cable	275	1000	2500 mm ² Al.	2 runs of 3 x 1c	1105
Five Estuaries Cable	275	1080	2500 mm ² Al.	2 runs of 3 x 1c	1194
North Fall 400kV Cable	400	850	2000 mm ² Al.	2 runs of 3 x 1c	646
North Fall 400kV Cable	400	1000	2000 mm ² Al.	2 runs of 3 x 1c	760

Table 2-5 presents the design parameters of the power cable. The cable's metallic screens are cross-bonded, and a detailed cable model design for the 220 kV, 275 kV and 400 kV power cables are provided in the Appendices.

Table 2-5: Power cable design parameters.

Parameter	Cable Details		
System Voltage	220 kV	275 kV	400 kV
Conductor Material	Aluminium	Aluminium	Aluminium
Conductor Screen	Semi-conducting	Semi-conducting	Semi-conducting
Insulation	XLPE	XLPE	XLPE
Insulation Screen	Semi-conducting	Semi-conducting	Semi-conducting
Screen	Cu. wire screen	Cu. wire screen	Cu. wire screen
Tape	Aluminium Laminated Tape	Aluminium Laminated Tape	Aluminium Laminated Tape
Over Sheath	PVC	PVC	PVC
Maximum Conductor Temperature	90 °C	90 °C	90 °C

2.7. Cable Trench and HDD Details

(a) Open cut trench




Figure 2-1: Open cut trench cross section.

(b) Typical cable trench




Figure 2-2: Typical cable trench cross section.

(c) Shallow HDD (5 m below surface)




Figure 2-3: Typical Shallow HDD cross section.

(d) Deep HDD (20 m below surface)




Figure 2-4: Typical Deep HDD cross section.

3. EMF Assessment Study

According to the provided information, the following 16 scenarios are simulated to evaluate the electromagnetic field (EMF) values at depths of ground level and 1m above ground level.

3.1. Scenario 1

In Scenario 1, the EMF assessment will be conducted for 850 MW 220 kV NF cable in Open cut trench.

3.1.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- Depth of the cable is 1100 mm.
- Cable size is 2500 mm² 220 kV Al.
- Flat arrangement with 500 mm spacing among phases.

3.1.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-1: Cable installation arrangement (Scenario 1).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-1.

Table 3-1: Summary of the EMF study results (Scenario 1).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	104.22
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	34.57

Based on the results presented in Table 3-1, the maximum electromagnetic field intensity of the cables is 104.22 μT at 0 m above the ground.

Figure 3-2-1 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-1: Magnetic field (μT) with respect to lateral distance (m) (Scenario 1).

3.2. Scenario 1a

In Scenario 1a, the EMF assessment will be conducted for 850 MW 220 kV NF cable in Open cut trench along with Five Estuaries 1080 MW 275 kV cables.

3.2.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- The depth of the cables is 1100 mm.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 500 mm spacing among phases.
- 14m separation between NF and VE cables.

3.2.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-2: Cable installation arrangement (Scenario 1a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-2.

Table 3-2: Summary of the EMF study results (Scenario 1a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	106.14
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	34.67

Based on the results presented in Table 3-2, the maximum electromagnetic field intensity of the cables is 106.14 μT at 0 m above the ground.

Figure 3-2-2 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-2: Magnetic field (μT) with respect to lateral distance (m) (Scenario 1a).

3.3. Scenario 2

In Scenario 2, the EMF assessment will be conducted for 1000 MW 275 kV NF cable in Open cut trench.

3.3.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- The depth of the cables is 1100 mm.
- Cable size is 2500 mm² 275 kV Al.
- Flat arrangement with 500 mm spacing among phases.

3.3.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-3: Cable installation arrangement (Scenario 2).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-3.

Table 3-3: Summary of the EMF study results (Scenario 2).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	99.02
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	32.7

Based on the results presented in Table 3-3, the maximum electromagnetic field intensity of the cables is 99.02 μT at 0 m above the ground.

Figure 3-2-3 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-3: Magnetic field (μT) with respect to lateral distance (m) (Scenario 2).

3.4. Scenario 2a

In Scenario 2a, the EMF assessment will be conducted for 1000 MW 275 kV NF cable in Open cut trench along with Five Estuaries 1080 MW 275 kV cables.

3.4.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- The depth of the cables is 1100 mm.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 500 mm spacing among phases.
- 14m separation between NF and VE cables.

3.4.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-4: Cable installation arrangement (Scenario 2a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-4.

Table 3-4: Summary of the EMF study results (Scenario 2a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	106.2
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	34.71

Based on the results presented in Table 3-4, the maximum electromagnetic field intensity of the cables is 106.2 μT at 0 m above the ground.

Figure 3-2-4 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-4: Magnetic field (μT) with respect to lateral distance (m) (Scenario 2a).

3.5. Scenario 3

In Scenario 3, the EMF assessment will be conducted for 850 MW 220 kV NF cable in Shallow HDD at 5 m depth.

3.5.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable size is 2500 mm² 220 kV AI.
- Flat arrangement with 5m spacing among phases.

3.5.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-5: Cable installation arrangement (Scenario 3).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions, Table 3-5 presents the results of the EMF study. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-5.

Table 3-5: Summary of the EMF study results (Scenario 3).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	41.63
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	32.61

Based on the results presented in Table 3-5, the maximum electromagnetic field intensity of the cables is 41.63 μT at 0 m above the ground.

Figure 3-2-5 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-5: Magnetic field (μT) with respect to lateral distance (m) (Scenario 3).

3.6. Scenario 3a

In Scenario 3a, the EMF assessment will be conducted for 850 MW 220 kV NF cable along with Five Estuaries 1080 MW 275 kV cables in Shallow HDD at 5 m depth.

3.6.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 5m spacing among phases.
- 10m separation between NF and VE cables.

3.6.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-6: Cable installation arrangement (Scenario 3a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-6.

Table 3-6: Summary of the EMF study results (Scenario 3a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	41.19
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	32.09

Based on the results presented in Table 3-6, the maximum electromagnetic field intensity of the cables is 41.19 μT at 0 m above the ground.

Figure 3-2-6 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-6: Magnetic field (μT) with respect to lateral distance (m) (Scenario 3a).

3.7. Scenario 4

In Scenario 4, the EMF assessment will be conducted for 1000 MW 275 kV NF cable in Shallow HDD at 5 m depth.

3.7.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable size is 2500 mm² 275 kV Al.
- Flat arrangement with 5m spacing among phases.

3.7.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-7: Cable installation arrangement (Scenario 4).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-7.

Table 3-7: Summary of the EMF study results (Scenario 4).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	39.21
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	30.71

Based on the results presented in Table 3-7, the maximum electromagnetic field intensity of the cables is 39.21 μT at 0 m above the ground.

Figure 3-2-7 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-7: Magnetic field (μT) with respect to lateral distance (m) (Scenario 4).

3.8. Scenario 4a

In Scenario 4a, the EMF assessment will be conducted for 1000 MW 275 kV NF cable along with Five Estuaries 1080 MW 275 kV cables in Shallow HDD at 5 m depth.

3.8.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 5m spacing among phases.
- 10m separation between NF and VE cables.

3.8.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-8: Cable installation arrangement (Scenario 4a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-8.

Table 3-8: Summary of the EMF study results (Scenario 4a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	41.26
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	32.15

Based on the results presented in Table 3-8, the maximum electromagnetic field intensity of the cables is 41.26 μT at 0 m above the ground.

Figure 3-2-8 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-8: Magnetic field (μT) with respect to lateral distance (m) (Scenario 4a).

3.9. Scenario 5

In Scenario 5, the EMF assessment will be conducted for 850 MW 220 kV NF cable in Deep HDD at 20 m depth.

3.9.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- The depth of the cable is 20m.
- Cable size is 2500 mm² 220 kV Al.
- Flat arrangement with 10m spacing among phases.

3.9.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-9: Cable installation arrangement (Scenario 5).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-9.

Table 3-9: Summary of the EMF study results (Scenario 5).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	8.24
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	7.71

Based on the results presented in Table 3-9, the maximum electromagnetic field intensity of the cables is 8.24 μT at 0 m above the ground.

Figure 3-2-9 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-9: Magnetic field (μT) with respect to lateral distance (m) (Scenario 5).

3.10. Scenario 5a

In Scenario 5a, the EMF assessment will be conducted for 850 MW 220 kV NF cable along with Five Estuaries 1080 MW 275 kV cables in Deep HDD at 20 m depth.

3.10.1. Simulation Parameters and Cables Details

- Cable laying in Deep HDD.
- The depth of the cable is 20m.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 10m spacing among phases.
- 10m separation between NF and VE cables.

3.10.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-10: Cable installation arrangement (Scenario 5a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-10.

Table 3-10: Summary of the EMF study results (Scenario 5a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	8.2
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	7.69

Based on the results presented in Table 3-10, the maximum electromagnetic field intensity of the cables is 8.2 μT at 0 m above the ground.

Figure 3-2-10 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-10: Magnetic field (μT) with respect to lateral distance (m) (Scenario 5a).

3.11. Scenario 6

In Scenario 6, the EMF assessment will be conducted for 1000 MW 275 kV NF cable in Deep HDD at 20 m depth.

3.11.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- The depth of the cable is 20m.
- Cable size is 2500 mm² 275 kV Al.
- Flat arrangement with 10m spacing among phases.

3.11.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-11: Cable installation arrangement (Scenario 6).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-11.

Table 3-11: Summary of the EMF study results (Scenario 6).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	7.75
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	7.25

Based on the results presented in Table 3-11, the maximum electromagnetic field intensity of the cables is 7.75 μT at 0 m above the ground.

Figure 3-2-11 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-11: Magnetic field (μT) with respect to lateral distance (m) (Scenario 6).

3.12. Scenario 6a

In Scenario 6a, the EMF assessment will be conducted for 1000 MW 275 kV NF cable along with Five Estuaries 1080 MW 275 kV cables in Deep HDD at 20 m depth.

3.12.1. Simulation Parameters and Cables Details

- Cable laying in Deep HDD.
- The depth of the cable is 20m.
- Cable sizes are 2500 mm² 220 kV Al. and 2500 mm² 275 kV Al.
- Flat arrangement with 10m spacing among phases.
- 10m separation between NF and VE cables.

3.12.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-12: Cable installation arrangement (Scenario 6a).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-12.

Table 3-12: Summary of the EMF study results (Scenario 6a).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	8.2
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	7.69

Based on the results presented in Table 3-12, the maximum electromagnetic field intensity of the cables is 8.2 μT at 0 m above the ground.

Figure 3-2-12 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-12: Magnetic field (μT) with respect to lateral distance (m) (Scenario 6a).

3.13. Scenario 7

In Scenario 7, the EMF assessment will be conducted for 850MW 400 kV NF cable in Open cut trench.

3.13.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- Depth of the cable is 1100 mm.
- Cable size is 2000 mm² 400 kV Al.
- Flat arrangement with 500 mm spacing among phases.

3.13.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-13: Cable installation arrangement (Scenario 7).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-13.

Table 3-13: Summary of the EMF study results (Scenario 7).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	57.63
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	19.06

Based on the results presented in Table 3-13, the maximum electromagnetic field intensity of the cables is 57.63 μT at 0 m above the ground.

Figure 3-2-13 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-13: Magnetic field (μT) with respect to lateral distance (m) (Scenario 7).

3.14. Scenario 8

In Scenario 8, the EMF assessment will be conducted for 1000MW 400 kV NF cable in Open cut trench.

3.14.1. Simulation Parameters and Cables Details

- Cable laying in open cut trench.
- Depth of the cable is 1100 mm.
- Cable size is 2000 mm² 400 kV Al.
- Flat arrangement with 500 mm spacing among phases.

3.14.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-14: Cable installation arrangement (Scenario 8).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-14.

Table 3-14: Summary of the EMF study results (Scenario 8).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	67.8
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	22.43

Based on the results presented in Table 3-14, the maximum electromagnetic field intensity of the cables is 67.8 μT at 0 m above the ground.

Figure 3-2-14 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-14: Magnetic field (μT) with respect to lateral distance (m) (Scenario 8).

3.15. Scenario 9

In Scenario 9, the EMF assessment will be conducted for 850MW 400 kV NF cable in Shallow HDD at 5m depth.

3.15.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable size is 2000 mm² 400 kV Al.
- Flat arrangement with 5m spacing among phases.

3.15.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-15: Cable installation arrangement (Scenario 9).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-15.

Table 3-15: Summary of the EMF study results (Scenario 9).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	22.91
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	17.94

Based on the results presented in Table 3-15, the maximum electromagnetic field intensity of the cables is 22.91 μT at 0 m above the ground.

Figure 3-2-15 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-15: Magnetic field (μT) with respect to lateral distance (m) (Scenario 9).

3.16. Scenario 10

In Scenario 10, the EMF assessment will be conducted for 1000MW 400 kV NF cable in Shallow HDD at 5m depth.

3.16.1. Simulation Parameters and Cables Details

- Cable laying in Shallow HDD.
- The depth of the cable is 5m.
- Cable size is 2000 mm² 400 kV Al.
- Flat arrangement with 5m spacing among phases.

3.16.2. Simulation Results

Cable Arrangement and Current Carrying Capacity




Figure 3-1-16: Cable installation arrangement (Scenario 10).

EMF Modelling Result

Based on the modelled installation, cable, and environmental conditions. The electromagnetic field intensity of the cables can be determined by referencing the results presented in Table 3-16.

Table 3-16: Summary of the EMF study results (Scenario 10).

S#	Description	Unit	Values
1	Maximum Electromagnetic field intensity @ 0m above the ground	μT	26.95
2	Maximum Electromagnetic field intensity @ 1m above the ground	μT	21.1

Based on the results presented in Table 3-16, the maximum electromagnetic field intensity of the cables is $26.95 \mu\text{T}$ at 0 m above the ground.

Figure 3-2-16 shows the graphical representation of the magnetic field with respect to lateral distance.




Figure 3-2-16: Magnetic field (μT) with respect to lateral distance (m) (Scenario 10).

4. Comparison of All Scenarios Result

Table 4-1 presents the comparison results of the EMF study for all 16 scenarios at 0m above ground level. The maximum electromagnetic field intensity for all cases can be determined by referring to the results presented in Table 4-1.

Table 4-1: Summary of EMF simulation results.

Scenarios	Description	Values (μT)
Scenario 1	Electromagnetic field intensity @ 0m above the ground	104.22
Scenario 1a	Electromagnetic field intensity @ 0m above the ground	106.14
Scenario 2	Electromagnetic field intensity @ 0m above the ground	99.02
Scenario 2a	Electromagnetic field intensity @ 0m above the ground	106.20
Scenario 3	Electromagnetic field intensity @ 0m above the ground	41.63
Scenario 3a	Electromagnetic field intensity @ 0m above the ground	41.19
Scenario 4	Electromagnetic field intensity @ 0m above the ground	39.21
Scenario 4a	Electromagnetic field intensity @ 0m above the ground	41.26
Scenario 5	Electromagnetic field intensity @ 0m above the ground	8.24
Scenario 5a	Electromagnetic field intensity @ 0m above the ground	8.20
Scenario 6	Electromagnetic field intensity @ 0m above the ground	7.75
Scenario 6a	Electromagnetic field intensity @ 0m above the ground	8.20
Scenario 7	Electromagnetic field intensity @ 0m above the ground	57.63
Scenario 8	Electromagnetic field intensity @ 0m above the ground	67.80
Scenario 9	Electromagnetic field intensity @ 0m above the ground	22.91
Scenario 10	Electromagnetic field intensity @ 0m above the ground	26.95

Based on the above summary table, the analysis reveals that the maximum electromagnetic field intensity in all cases is 106.2 μT at 0 meters above the ground in Scenario 2a.

5. EMF Compliance

The UK's approach to managing public exposure to electromagnetic fields (EMFs) is based on the 1998 ICNIRP Guidelines, which have been formally endorsed by the UK Government [12]. This is reflected in national policies and enforced through voluntary Codes of Practice agreed upon with the Energy Networks Association (ENA) [11].

5.1. Public Exposure Limits:

For areas where members of the public may spend significant time (e.g., homes, schools), the following limits apply:

- **Electric Field Strength:** 9 kV/m
- **Magnetic Flux Density:** 360 μT [11].

These limits are designed to protect against known acute health effects from power-frequency fields (50 Hz) and are consistent with the ICNIRP's reference levels [12].

The ICNIRP 1998 Guidelines set the public exposure limit for magnetic fields at 100 μT (rms) to prevent known health effects [12]. However, the UK uses the 360 μT reference level, for practical compliance assessment. This higher value accounts for short-term peaks and ensures that infrastructure design remains within safe limits [11].

As per the simulation results of all 16 scenarios, the worst-case value is around 106.20 μT , which is within the limit of 360 μT required for compliance.

6. Conclusion

The electromagnetic field (EMF) analysis for all 16 scenarios shows that the maximum magnetic field intensity is 106.2 μT , observed in Scenario 2a. This value is well within the UK's public exposure reference limit of 360 μT , as outlined in the ICNIRP-endorsed national guidelines. The reference level accounts for realistic operating conditions and short-term variations in field strength. Based on these results, all scenarios evaluated are in full compliance with the applicable EMF exposure standards, confirming that the proposed configurations pose no exceedance of public safety limits.

Recommendation:

Although all simulated values remain compliant, the results can be further improved by increasing the cable burial depth in open-cut trench installations. This adjustment will reduce the maximum magnetic field intensity to below 100 μT , offering an enhanced safety margin and aligning with best engineering practices for minimising public exposure.

7. References

- [1] Electrotechnik, "Electrical Design Software - ELEK," <https://elek.com.au/>.
<https://elek.com.au/electrical-software/> (accessed 23-09-2022).
- [2] IEC 60287-2-1 Electric cables - Calculation of the current rating - Part 2-1: Thermal resistance - Calculation of the thermal resistance
- [3] IEC 60287-3-1 Electric cables - Calculation of the current rating - Operating conditions
- [4] CIGRE TB 880, Power Cable Rating Examples for Calculation Tool Verification, 2022
- [5] IEC 60284-3-1:2017 Electrical cables - Calculation of the current rating - Part 3-1: Operating conditions - Site reference conditions
- [6] DEMIRER KABLO, "DEMIRER KABLO High and Extra High Voltage Cable System 66-500kV XLPE cable." Accessed: Dec. 11, 2023. [Online]. Available: <http://www.demirerkablo.com/media/33103/catalogue.pdf>.
- [7] "The Grid Code, Issue 6, Revision 25, 5-July-2024"
- [8] SPTS 2.5 – General Requirements for 132, 275, 400kV Cables, BETTA-11-005, Issue 1, PowerSystems.
- [9] ENA TS 12-24 - Technical specification for plastic ducts for buried electric cables
- [10] E. Fernandez and J. Patrick, Magnetic Fields from High Voltage Power Cables. Electrotechnik Pty Ltd. Available: www.elek.com.au
- [11] "UK Policy." *EMFs.info*, n.d., <https://www.emfs.info/exposure-limits-and-policy/UK-policy>. Accessed 31 Mar. 2025.
- [12] ICNIRP (1998) *Guidelines for limiting exposure to time-varying electric, magnetic and electromagnetic fields (up to 300 GHz)*. Health Physics, 74(4), pp. 494–522. Available at: <https://www.icnirp.org/cms/upload/publications/ICNIRPemfgdl.pdf> (Accessed: 31 March 2025).
- [13] *Power Lines: Control of Microshocks and other indirect effects of public exposure to electric fields – A voluntary Code of Practice*. Available at: https://www.emfs.info/uploads/publications/Microshocks_Code_of_Practice.pdf (Accessed: 31 March 2025).

Appendices

Appendix-A Datasheets



127/220 (245) kV

XLPE Insulated with Cu Wire + Al Tape

Continuous Current Rating for Single Circuit (A)

COPPER CONDUCTOR

Cross-Sectional Area (mm ²)		400	500	630	800	1000	1200	1600	2000	2500
Direct-buried		696	795	909	1026	1143	1316	1469	1622	1776
	Pipe	680	778	890	1006	1126	1299	1455	1614	1776
In Air	Trefoil	771	886	1020	1159	1302	1540	1738	1938	2142
	Flat (S=3D)	923	1072	1254	1437	1633	1905	2169	2434	2723

HDPE pipe diameter = 2D

ALUMINIUM CONDUCTOR

Cross-Sectional Area (mm ²)		400	500	630	800	1000	1200	1600	2000	2500
Direct-buried		545	627	720	820	925	1040	1195	1335	1475
	Pipe	534	614	704	805	910	1026	1184	1328	1473
In Air	Trefoil	607	703	812	936	1064	1222	1426	1610	1801
	Flat (S=3D)	726	849	993	1152	1319	1504	1764	2004	2258

HDPE pipe diameter = 2D

Figure A-1: Electrical data for 220 kV XLPE AC Cable (Part 1) [6].



CONDUCTOR (Cu)	Cross-Sectional Area (mm ²)	400	500	630	800	1000	1200	1600	2000	2500
	Shape	Circular	Circular	Circular	Circular	Circular	Milliken	Milliken	Milliken	Milliken
	Diameter (mm)	23,45	26,4	30,25	34	39	43,5	49,5	56	63,5
Thickness of Conductor Screen (mm)		3,3	1,8	1,2	1,2	1,4	1,4	1,5	1,6	1,6
Thickness of Insulation (mm)		23	22	21	21	20	20	20	20	20
Thickness of Insulation Screen (mm)		1,2	1,2	1,2	1,2	1,2	1,2	1,2	1,2	1,2
Cu-Screen Cross-Sectional Area (mm ²)		150	150	150	150	150	150	150	150	150
Thickness of Outer Sheath (mm)		3,6	3,6	3,7	3,8	3,8	4	4,2	4,6	4,9
Outer Diameter of Cable (mm)		93	91	92	96	99	105	112	119	128
Weight of Cable (kg/m)		10,3	10,9	12,1	14	16,1	18,3	22,4	26,8	32,8
Max. DC Cu Conductor Resistance at 20°C (ohm/km)		0,047	0,0366	0,0283	0,0221	0,0176	0,0151	0,0113	0,009	0,0072
Capacitance (µF/km)		0,139	0,143	0,156	0,168	0,191	0,209	0,229	0,252	0,277
Inductance (mH/km)		0,462	0,434	0,408	0,394	0,375	0,365	0,352	0,339	0,33

CONDUCTOR (Al)	Cross-Sectional Area (mm ²)	400	500	630	800	1000	1200	1600	2000	2500
	Shape	Circular	Circular	Circular	Circular	Circular	Milliken	Milliken	Milliken	Milliken
	Diameter (mm)	24,25	27,4	30,6	34,8	39	43,5	50,2	56,5	63,5
Max. DC Al Conductor Resistance at 20°C (ohm/km)		0,0778	0,0605	0,0469	0,0367	0,0291	0,0247	0,0186	0,0149	0,0127
Weight of Cable (kg/m)		8,1	8	8,2	9,1	9,9	11,1	12,8	14,7	17

Figure A-2: Electrical data for 220 kV XLPE AC Cable (Part 2) [6].



190/330 (362) kV

XLPE Insulated with Cu Wire + Al Tape

Continuous Current Rating for Single Circuit (A)

COPPER CONDUCTOR

Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500
Direct-buried	1013	1128	1298	1447	1596	1746
Pipe	1000	1117	1287	1441	1593	1751
In Air						
Trefoil	1157	1298	1529	1724	1921	2122
Flat (S=3D)	1402	1596	1859	2113	2384	2659

HDPE pipe diameter = 2D

ALUMINIUM CONDUCTOR

Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500
Direct-buried	809	913	1025	1177	1313	1450
Pipe	800	903	1017	1172	1310	1453
In Air						
Trefoil	932	1058	1212	1412	1593	1782
Flat (S=3D)	1123	1289	1468	1719	1959	2205

HDPE pipe diameter = 2D

Figure A-3: Electrical data for 275 kV XLPE AC Cable (Part 1) [6].



CONDUCTOR (Cu)	Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500
	Shape	Circular	Circular	Miliken	Miliken	Miliken	Miliken
	Diameter (mm)	34	39	43,5	49,5	56	63,5
Thickness of Conductor Screen (mm)		1,2	1,4	1,4	1,5	1,6	1,6
Thickness of Insulation (mm)		28	27	27	27	26	26
Thickness of Insulation Screen (mm)		1,2	1,2	1,2	1,2	1,2	1,2
Cu-Screen Cross-Sectional Area (mm ²)		185	185	185	185	185	185
Thickness of Outer Sheath (mm)		4,3	4,3	4,5	4,7	5	5,3
Outer Diameter of Cable (mm)		111	114	120	127	132	141
Weight of Cable (kg/m)		16,6	18,8	21,3	25,2	29,4	35,6
Max. DC Cu Conductor Resistance at 20°C (ohm/km)		0,0221	0,0176	0,0151	0,0113	0,009	0,0072
Capacitance (µF/km)		0,138	0,155	0,168	0,183	0,206	0,227
Inductance (mH/km)		0,425	0,402	0,039	0,375	0,358	0,346

CONDUCTOR (Al)	Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500
	Shape	Circular	Circular	Miliken	Miliken	Miliken	Miliken
	Diameter (mm)	34,8	39	43,5	50,2	56,5	63,5
Max. DC Al Conductor Resistance at 20°C (ohm/km)		0,0367	0,0291	0,0247	0,0186	0,0149	0,0127
Weight of Cable (kg/m)		11,7	12,3	13,8	15,7	17,2	19,9

Figure A-4: Electrical data for 275 kV XLPE AC Cable (Part 2) [6].



220/380 (420) kV

XLPE Insulated with Cu Wire +Al Tape

Continuous Current Rating for Single Circuit (A)

COPPER CONDUCTOR

Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500	3000
Direct-buried	1006	1120	1287	1434	1583	1730	2004
Pipe	996	1110	1277	1428	1582	1737	2021
In Air							
Trefoil	1153	1293	1521	1715	1911	2111	2457
Flat (S=3D)	1387	1586	1853	2105	2367	2640	3116

HDPE pipe diameter = 2D

ALUMINIUM CONDUCTOR

Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500	3000
Direct-buried	806	906	1017	1166	1302	1436	1640
Pipe	795	897	1008	1161	1301	1440	1652
In Air							
Trefoil	928	1054	1214	1405	1585	1772	2038
Flat (S=3D)	1111	1281	1463	1712	1945	2189	2542

HDPE pipe diameter = 2D

Figure A-5: Electrical data for 400 kV XLPE AC Cable (Part 1) [6].



CONDUCTOR (Cu)	Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500	3000
	Shape	Circular	Circular	Miliken	Miliken	Miliken	Miliken	Miliken
	Diameter (mm)	34	39	43,5	49,5	56	63,5	71
Thickness of Conductor Screen (mm)		1,8	1,4	1,4	1,5	1,6	1,6	1,6
Thickness of Insulation (mm)		30	28	27	27	27	27	27
Thickness of Insulation Screen (mm)		1,2	1,2	1,2	1,2	1,2	1,2	1,2
Cu-Screen Cross-Sectional Area (mm ²)		185	185	185	185	185	185	185
Thickness of Outer Sheath (mm)		4,4	4,4	4,5	4,7	5,1	5,3	5,6
Outer Diameter of Cable (mm)		116	117	120	127	134	143	152
Weight of Cable (kg/m)		17,6	19,2	21,3	25,4	29,9	36	42,7
Max. DC Cu Conductor Resistance at 20°C (ohm/km)		0,0221	0,0176	0,0151	0,0113	0,009	0,0072	0,006
Capacitance (µF/km)		0,135	0,151	0,168	0,182	0,2	0,22	0,241
Inductance (mH/km)		0,433	0,405	0,39	0,375	0,362	0,349	0,336

CONDUCTOR (Al)	Cross-Sectional Area (mm ²)	800	1000	1200	1600	2000	2500	3000
	Shape	Circular	Circular	Miliken	Miliken	Miliken	Miliken	Miliken
	Diameter (mm)	34,8	39	43,5	50,2	56,5	63,5	71
Max. DC Al Conductor Resistance at 20°C (ohm/km)		0,0367	0,0291	0,0247	0,0186	0,0149	0,0127	0,0099
Weight of Cable (kg/m)		12,7	12,7	13,8	15,9	17,7	20,3	23,4

Figure A-6: Electrical data for 400 kV XLPE AC Cable (Part 2) [6].

Appendix-B Simulation Report

Scenario 1

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.280	1175.000	-120	FORWARD	ON
1	B	0.000	1.280	1175.000	0	FORWARD	ON
1	C	0.500	1.280	1175.000	120	FORWARD	ON
2	A	4.500	1.280	1175.000	-120	FORWARD	ON
2	B	5.000	1.280	1175.000	0	FORWARD	ON
2	C	5.500	1.280	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 15.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.09	104.22
0	5.09	104.22
1	-0.37	34.57
1	5.37	34.57



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 1a

ELEK Cable High Voltage V7.0

29-03-2025, 02:04 am

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.273	1194.000	-120	FORWARD	ON
1	B	0.000	1.273	1194.000	0	FORWARD	ON
1	C	0.500	1.273	1194.000	120	FORWARD	ON
2	A	4.500	1.273	1194.000	-120	FORWARD	ON
2	B	5.000	1.273	1194.000	0	FORWARD	ON
2	C	5.500	1.273	1194.000	120	FORWARD	ON
3	A	18.500	1.280	1175.000	-120	FORWARD	ON
3	B	19.000	1.280	1175.000	0	FORWARD	ON
3	C	19.500	1.280	1175.000	120	FORWARD	ON
4	A	23.500	1.280	1175.000	-120	FORWARD	ON
4	B	24.000	1.280	1175.000	0	FORWARD	ON
4	C	24.500	1.280	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 34.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.09	106.14
1	-0.41	34.67



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 2

ELEK Cable High Voltage V7.0

29-03-2025, 01:48 am

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.273	1105.000	-120	FORWARD	ON
1	B	0.000	1.273	1105.000	0	FORWARD	ON
1	C	0.500	1.273	1105.000	120	FORWARD	ON
2	A	4.500	1.273	1105.000	-120	FORWARD	ON
2	B	5.000	1.273	1105.000	0	FORWARD	ON
2	C	5.500	1.273	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 15.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.08	99.02
0	5.08	99.02
1	-0.37	32.7
1	5.37	32.7



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 2a

ELEK Cable High Voltage V7.0

29-03-2025, 01:53 am

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.273	1194.000	-120	FORWARD	ON
1	B	0.000	1.273	1194.000	0	FORWARD	ON
1	C	0.500	1.273	1194.000	120	FORWARD	ON
2	A	4.500	1.273	1194.000	-120	FORWARD	ON
2	B	5.000	1.273	1194.000	0	FORWARD	ON
2	C	5.500	1.273	1194.000	120	FORWARD	ON
3	A	18.500	1.273	1105.000	-120	FORWARD	ON
3	B	19.000	1.273	1105.000	0	FORWARD	ON
3	C	19.500	1.273	1105.000	120	FORWARD	ON
4	A	23.500	1.273	1105.000	-120	FORWARD	ON
4	B	24.000	1.273	1105.000	0	FORWARD	ON
4	C	24.500	1.273	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 34.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.09	106.2
1	-0.41	34.71



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 3

ELEK Cable High Voltage V7.0

29-03-2025, 01:44 am

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.179	1175.000	-120	FORWARD	ON
1	B	0.000	5.179	1175.000	0	FORWARD	ON
1	C	5.000	5.179	1175.000	120	FORWARD	ON
2	A	15.000	5.179	1175.000	-120	FORWARD	ON
2	B	20.000	5.179	1175.000	0	FORWARD	ON
2	C	25.000	5.179	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 40.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-1.59	41.63
0	-1.58	41.63
0	-1.57	41.63
0	21.57	41.63
0	21.58	41.63
0	21.59	41.63
1	-1.78	32.61
1	-1.77	32.61
1	-1.76	32.61
1	21.76	32.61
1	21.77	32.61
1	21.78	32.61



Software by
- www.elek.com

Page 1 of 3




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 3a

ELEK Cable High Voltage V7.0

29-03-2025, 02:01 am

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.173	1194.000	-120	FORWARD	ON
1	B	0.000	5.173	1194.000	0	FORWARD	ON
1	C	5.000	5.173	1194.000	120	FORWARD	ON
2	A	15.000	5.173	1194.000	-120	FORWARD	ON
2	B	20.000	5.173	1194.000	0	FORWARD	ON
2	C	25.000	5.173	1194.000	120	FORWARD	ON
3	A	35.000	5.179	1175.000	-120	FORWARD	ON
3	B	40.000	5.179	1175.000	0	FORWARD	ON
3	C	45.000	5.179	1175.000	120	FORWARD	ON
4	A	55.000	5.179	1175.000	-120	FORWARD	ON
4	B	60.000	5.179	1175.000	0	FORWARD	ON
4	C	65.000	5.179	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 80.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-2.03	41.19
0	-2.02	41.19
1	-2.3	32.09
1	-2.29	32.09
1	-2.28	32.09



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 4

ELEK Cable High Voltage V7.0

29-03-2025, 12:59 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.173	1105.000	-120	FORWARD	ON
1	B	0.000	5.173	1105.000	0	FORWARD	ON
1	C	5.000	5.173	1105.000	120	FORWARD	ON
2	A	15.000	5.173	1105.000	-120	FORWARD	ON
2	B	20.000	5.173	1105.000	0	FORWARD	ON
2	C	25.000	5.173	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 40.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-1.59	39.21
0	-1.58	39.21
0	-1.57	39.21
0	21.57	39.21
0	21.58	39.21
0	21.59	39.21
1	-1.78	30.71
1	-1.77	30.71
1	-1.76	30.71
1	21.76	30.71
1	21.77	30.71
1	21.78	30.71



Software by
- www.elek.com

Page 1 of 3




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 4a

ELEK Cable High Voltage V7.0

29-03-2025, 01:06 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.173	1194.000	-120	FORWARD	ON
1	B	0.000	5.173	1194.000	0	FORWARD	ON
1	C	5.000	5.173	1194.000	120	FORWARD	ON
2	A	15.000	5.173	1194.000	-120	FORWARD	ON
2	B	20.000	5.173	1194.000	0	FORWARD	ON
2	C	25.000	5.173	1194.000	120	FORWARD	ON
3	A	35.000	5.173	1105.000	-120	FORWARD	ON
3	B	40.000	5.173	1105.000	0	FORWARD	ON
3	C	45.000	5.173	1105.000	120	FORWARD	ON
4	A	55.000	5.173	1105.000	-120	FORWARD	ON
4	B	60.000	5.173	1105.000	0	FORWARD	ON
4	C	65.000	5.173	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 80.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-2	41.26
1	-2.26	32.15
1	-2.25	32.15



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 5

ELEK Cable High Voltage V7.0

29-03-2025, 01:10 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-10.000	20.180	1175.000	-120	FORWARD	ON
1	B	0.000	20.180	1175.000	0	FORWARD	ON
1	C	10.000	20.180	1175.000	120	FORWARD	ON
2	A	20.000	20.180	1175.000	-120	FORWARD	ON
2	B	30.000	20.180	1175.000	0	FORWARD	ON
2	C	40.000	20.180	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -30.00
Maximum horizontal distance (m) = 60.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-5.26	8.24
0	-5.25	8.24
0	-5.24	8.24
0	-5.23	8.24
0	-5.22	8.24
0	35.22	8.24
0	35.23	8.24
0	35.24	8.24
0	35.25	8.24
0	35.26	8.24
1	-5.22	7.71
1	-5.21	7.71
1	-5.2	7.71



Software by
- www.elek.com

Page 1 of 3

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
1	-5.19	7.71
1	-5.18	7.71
1	-5.17	7.71
1	-5.16	7.71
1	-5.15	7.71
1	-5.14	7.71
1	-5.13	7.71
1	-5.12	7.71
1	-5.11	7.71
1	-5.1	7.71
1	-5.09	7.71
1	-5.08	7.71
1	-5.07	7.71
1	-5.06	7.71
1	35.06	7.71
1	35.07	7.71
1	35.08	7.71
1	35.09	7.71
1	35.1	7.71
1	35.11	7.71
1	35.12	7.71
1	35.13	7.71
1	35.14	7.71
1	35.15	7.71
1	35.16	7.71
1	35.17	7.71
1	35.18	7.71
1	35.19	7.71
1	35.2	7.71
1	35.21	7.71
1	35.22	7.71




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 5a

ELEK Cable High Voltage V7.0

29-03-2025, 01:17 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-10.000	20.173	1194.000	-120	FORWARD	ON
1	B	0.000	20.173	1194.000	0	FORWARD	ON
1	C	10.000	20.173	1194.000	120	FORWARD	ON
2	A	20.000	20.173	1194.000	-120	FORWARD	ON
2	B	30.000	20.173	1194.000	0	FORWARD	ON
2	C	40.000	20.173	1194.000	120	FORWARD	ON
3	A	50.000	20.180	1175.000	-120	FORWARD	ON
3	B	60.000	20.180	1175.000	0	FORWARD	ON
3	C	70.000	20.180	1175.000	120	FORWARD	ON
4	A	80.000	20.180	1175.000	-120	FORWARD	ON
4	B	90.000	20.180	1175.000	0	FORWARD	ON
4	C	100.000	20.180	1175.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -30.00
Maximum horizontal distance (m) = 120.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-8.04	8.2
0	-8.03	8.2
0	-8.02	8.2
0	-8.01	8.2
0	-8	8.2
0	-7.99	8.2
0	-7.98	8.2



Software by
- www.elek.com

Page 1 of 3

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-7.97	8.2
0	-7.96	8.2
0	-7.95	8.2
0	-7.94	8.2
0	-7.93	8.2
0	-7.92	8.2
0	-7.91	8.2
0	-7.9	8.2
0	-7.89	8.2
1	-8.14	7.69
1	-8.13	7.69
1	-8.12	7.69
1	-8.11	7.69
1	-8.1	7.69
1	-8.09	7.69
1	-8.08	7.69
1	-8.07	7.69
1	-8.06	7.69
1	-8.05	7.69
1	-8.04	7.69
1	-8.03	7.69
1	-8.02	7.69
1	-8.01	7.69
1	-8	7.69
1	-7.99	7.69
1	-7.98	7.69




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 6

ELEK Cable High Voltage V7.0

29-03-2025, 01:19 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-10.000	20.173	1105.000	-120	FORWARD	ON
1	B	0.000	20.173	1105.000	0	FORWARD	ON
1	C	10.000	20.173	1105.000	120	FORWARD	ON
2	A	20.000	20.173	1105.000	-120	FORWARD	ON
2	B	30.000	20.173	1105.000	0	FORWARD	ON
2	C	40.000	20.173	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -30.00
Maximum horizontal distance (m) = 60.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-5.27	7.75
0	-5.26	7.75
0	-5.25	7.75
0	-5.24	7.75
0	-5.23	7.75
0	-5.22	7.75
0	-5.21	7.75
0	35.21	7.75
0	35.22	7.75
0	35.23	7.75
0	35.24	7.75
0	35.25	7.75
0	35.26	7.75



Software by
- www.elek.com

Page 1 of 3

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	35.27	7.75
1	-5.23	7.25
1	-5.22	7.25
1	-5.21	7.25
1	-5.2	7.25
1	-5.19	7.25
1	-5.18	7.25
1	-5.17	7.25
1	-5.16	7.25
1	-5.15	7.25
1	-5.14	7.25
1	-5.13	7.25
1	-5.12	7.25
1	-5.11	7.25
1	-5.1	7.25
1	-5.09	7.25
1	-5.08	7.25
1	-5.07	7.25
1	-5.06	7.25
1	-5.05	7.25
1	35.05	7.25
1	35.06	7.25
1	35.07	7.25
1	35.08	7.25
1	35.09	7.25
1	35.1	7.25
1	35.11	7.25
1	35.12	7.25
1	35.13	7.25
1	35.14	7.25
1	35.15	7.25
1	35.16	7.25
1	35.17	7.25
1	35.18	7.25
1	35.19	7.25
1	35.2	7.25
1	35.21	7.25
1	35.22	7.25
1	35.23	7.25




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 6a

ELEK Cable High Voltage V7.0

29-03-2025, 01:26 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-10.000	20.173	1194.000	-120	FORWARD	ON
1	B	0.000	20.173	1194.000	0	FORWARD	ON
1	C	10.000	20.173	1194.000	120	FORWARD	ON
2	A	20.000	20.173	1194.000	-120	FORWARD	ON
2	B	30.000	20.173	1194.000	0	FORWARD	ON
2	C	40.000	20.173	1194.000	120	FORWARD	ON
3	A	50.000	20.173	1105.000	-120	FORWARD	ON
3	B	60.000	20.173	1105.000	0	FORWARD	ON
3	C	70.000	20.173	1105.000	120	FORWARD	ON
4	A	80.000	20.173	1105.000	-120	FORWARD	ON
4	B	90.000	20.173	1105.000	0	FORWARD	ON
4	C	100.000	20.173	1105.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -30.00
Maximum horizontal distance (m) = 120.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-7.87	8.2
0	-7.86	8.2
0	-7.85	8.2
0	-7.84	8.2
0	-7.83	8.2
0	-7.82	8.2
0	-7.81	8.2



Software by
- www.elek.com

Page 1 of 3

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-7.8	8.2
0	-7.79	8.2
0	-7.78	8.2
0	-7.77	8.2
1	-7.92	7.69
1	-7.91	7.69
1	-7.9	7.69




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 7

ELEK Cable High Voltage V7.0

28-03-2025, 08:19 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.276	646.000	-120	FORWARD	ON
1	B	0.000	1.276	646.000	0	FORWARD	ON
1	C	0.500	1.276	646.000	120	FORWARD	ON
2	A	4.500	1.276	646.000	-120	FORWARD	ON
2	B	5.000	1.276	646.000	0	FORWARD	ON
2	C	5.500	1.276	646.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 15.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.09	57.63
0	-0.08	57.63
0	5.08	57.63
0	5.09	57.63
1	-0.37	19.07
1	5.37	19.07



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 8

ELEK Cable High Voltage V7.0

28-03-2025, 09:55 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-0.500	1.276	760.000	-120	FORWARD	ON
1	B	0.000	1.276	760.000	0	FORWARD	ON
1	C	0.500	1.276	760.000	120	FORWARD	ON
2	A	4.500	1.276	760.000	-120	FORWARD	ON
2	B	5.000	1.276	760.000	0	FORWARD	ON
2	C	5.500	1.276	760.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -10.00
Maximum horizontal distance (m) = 15.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-0.09	67.8
0	-0.08	67.8
0	5.08	67.8
0	5.09	67.8
1	-0.37	22.43
1	5.37	22.43



Software by
- www.elek.com

Page 1 of 2




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 9

ELEK Cable High Voltage V7.0

29-03-2025, 01:29 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.176	646.000	-120	FORWARD	ON
1	B	0.000	5.176	646.000	0	FORWARD	ON
1	C	5.000	5.176	646.000	120	FORWARD	ON
2	A	15.000	5.176	646.000	-120	FORWARD	ON
2	B	20.000	5.176	646.000	0	FORWARD	ON
2	C	25.000	5.176	646.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 40.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-1.58	22.91
0	21.58	22.91
1	-1.79	17.94
1	-1.78	17.94
1	-1.77	17.94
1	-1.76	17.94
1	-1.75	17.94
1	21.75	17.94
1	21.76	17.94
1	21.77	17.94
1	21.78	17.94
1	21.79	17.94



Software by
- www.elek.com

Page 1 of 3




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

Scenario 10

ELEK Cable High Voltage V7.0

29-03-2025, 01:32 pm

Magnetic Field Intensity Calculations

Installation Data

Installation method = Buried
Relative soil permeability = 1.00

Cable Data

Circuit Number	Phase	X Position (m)	Y Position (m)	Current (A)	Angle (deg.)	Direction	On / Off
1	A	-5.000	5.176	760.000	-120	FORWARD	ON
1	B	0.000	5.176	760.000	0	FORWARD	ON
1	C	5.000	5.176	760.000	120	FORWARD	ON
2	A	15.000	5.176	760.000	-120	FORWARD	ON
2	B	20.000	5.176	760.000	0	FORWARD	ON
2	C	25.000	5.176	760.000	120	FORWARD	ON

Measurement Data

Minimum horizontal distance (m) = -20.00
Maximum horizontal distance (m) = 40.00
Horizontal step size (m) = 0.01
Minimum vertical distance (m) = 0.00
Maximum vertical distance (m) = 1.00
Vertical step size (m) = 1.00

Results

Height above the ground, Y (m)	Lateral distance, X (m)	Maximum field intensity, B (uT)
0	-1.6	26.95
0	-1.59	26.95
0	-1.58	26.95
0	-1.57	26.95
0	-1.56	26.95
0	21.56	26.95
0	21.57	26.95
0	21.58	26.95
0	21.59	26.95
0	21.6	26.95
1	-1.78	21.1
1	-1.77	21.1
1	21.77	21.1



Software by
- www.elek.com

Page 1 of 3




Figure 1: Magnetic field (uT) with respect to Lateral distance (m)

End of Report



NORTH FALLS

Offshore Wind Farm



RWE

HARNESSING THE POWER OF NORTH SEA WIND

North Falls Offshore Wind Farm Limited

A joint venture company owned equally by SSE Renewables and RWE.

To contact please email contact@northfallsoffshore.com

© 2024 All Rights Reserved