

Environment Agency – Registration number: 20050710
Version: 04

- Highly likely – where agreement should be possible, or a relatively simple change is required.
- Likely – where an issue is still being discussed, but we believe it can be resolved.
- Unlikely – where agreement on an issue is unlikely or it is difficult to identify a solution.

[illegible]

			necessary for the lifetime of the development.	
	Pollution prevention	CEMP currently does not apply to site preparation works	Amend wording of Requirement 4	Resolved
	Pollution prevention	No details have been provided regarding operational pollution prevention measures in the routine management of potentially contaminated drainage from BESS compound. Such contamination could reach the underlying aquifer via drainage into attenuation ponds and into ditches/ watercourses.	Provide outline operational controls to monitor for, prevent, and manage spills and leaks within the BESS compound in outline OEMP, and provide detailed controls in Site Maintenance Plan.	Resolved
	Pollution prevention	Requirement 4(2) of the Draft DCO states that CEMP must include a protocol in the event that unexpected contaminated land is identified. This protocol is not included in the Outline CEMP.	Provision in the revised Outline CEMP for a contamination watching brief and discovery protocol, requiring consultation with the Environment Agency if unexpected land contamination is encountered during ground investigation or construction.	Resolved