



BEACON FEN ENERGY PARK

Planning Inspectorate Reference: EN010151

Schedule of Changes to the Draft DCO

Document Reference: 3.1

July 2025



Quality information

Prepared by	Checked by	Verified by	Approved by
HSF Kramer			

Revision History

Revision	Revision date	Details	Authorised	Name	Position
1	July 2025	Version submitted in response to s51 advice	HSF Kramer		

1. Introduction

1.1 Purpose of this Schedule

1.1.1 The table below sets out the changes made to the **Draft Development Consent Order (Document Ref: 3.1)** in response to the post-acceptance section 51 advice received. This Schedule is provided by the Applicant to aid the ExA in understanding the changes made.

Table 1: Changes made to the Draft DCO in response to section 51 advice

ROW	PROVISION	CHANGE	REASONING
1.	Article 2(1) (interpretation)	"the 2015 Regulations <u>Order</u> " means the Town and Country Planning (General Permitted Development) (England) Order 2015;	Amendment to reflect that the statutory instrument is an Order, rather than regulations. References to "the 2015 Regulations" in Article 9 (planning permission) have also been amended.
2.	Article 2(1) (interpretation)	Addition of: <u>"National Grid 2005 permission" means planning permission B/05/0046 granted by Boston Borough Council on 20 April 2005 (and any variation thereof);</u>	Additional definition added as a result of addition of new Article 48 (see row 3 below).
3.	Article 48 (National Grid extension works)	<u>National Grid extension works</u> <u>48.—(1) If National Grid elects to undertake any elements of the works described in Work No.5 pursuant to planning permission granted under Part 3 of the 1990 Act or Article 3 of the 2015 Order then the requirements contained in Part 1 of Schedule 2 (requirements) will not have effect in so far as they relate to those works and National Grid will serve written notice of the same on the relevant planning authority.</u> <u>(2) As from the date on which Work No.5 is commenced any conditions of the National Grid 2005 permission that relate to the land at plot 18-19 cease to have effect to the extent they are inconsistent with the authorised development or with anything done or approved under the requirements in Part 1 of Schedule 2 (requirements).</u>	New article added following further engagement during the pre-examination period between the Applicant and National Grid Electricity Transmission plc. Please refer to paragraphs 8.1.26 – 8.1.30 of the Explanatory Memorandum (Document Ref: 3.2) for the full explanation of why this article has been added and where it is preceded.
4.	Schedule 1 (authorised development)	Amendment to Work No.5A: Work No. 5— works to the existing substation including— (a) Work No. 5A— creation of a new generation bay and associated works at the existing substation including— (i) an electrical bay to connect into the existing network at Work No. 5B , including associated outdoor air insulated switchgear (AIS) or indoor gas insulated switchgear (GIS) and electrical apparatus, circuit breakers, disconnectors and earth switches;	The Applicant identified that the deleted wording was a minor error in the description of Work No.5A, because it is not factually correct that the electrical bay is to connect into the existing network at Work No. 5B.