


NOT FOR CONSTRUCTION
FOR INFORMATION ONLY



PROJECT

Fosse Green Energy


CLIENT


Fosse Green Energy Ltd


CONSULTANT


AECOM Limited


LEGEND


 STORAGE


 CONTROL BUILDING


 PARKING

 WATER TANK

 BATTERY CONTAINERS AND POWER CONVERSION STATION (PCS)

 POND

 MV SWITCHROOM



02550m

1:1000

NOTES

1. DRAWING IS FOR INDICATIVE PURPOSES ONLY.

2. FINAL SYSTEM CONFIGURATION SUBJECT TO DETAILED DESIGN.

3. BESS UNITS WILL BE SPACED A MINIMUM OF 3m APART. FOR ADDITIONAL EQUIPMENT DIMENSIONS SEE FIGURE 3-4.

4. AREA WITHIN THE BESS ENCLOSURE IS APPROXIMATELY 7 HECTARES.

LEGISLATION

Regulation 5(2)(a) Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009.

ISSUE PURPOSE

DCO Submission

PROJECT NUMBER

60700987

FIGURE TITLE

Indicative Centralised BESS Layout

FIGURE NUMBER

Figure 3-5

REV.

01

DOCUMENT REFERENCE

EN010154/APP/6.2

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, even as agreed by AECOM or as required by law. AECOM accepts no responsibility and denies any liability whatsoever to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.