




NOT FOR CONSTRUCTION
FOR INFORMATION ONLY



This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability, whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.



PROJECT

Fosse Green Energy

CLIENT

Fosse Green Energy Ltd

CONSULTANT

AECOM Limited

LEGEND

NOTES

1. ALL DIMENSIONS ARE IN METERS UNLESS STATED OTHERWISE.
2. DRAWING IS FOR INDICATIVE PURPOSES ONLY. TRENCHLESS DRILLING DETAILS ARE TO BE CONFIRMED IN LATER DESIGN STAGES AND WITH TRENCHLESS DRILLING CONTRACTOR.
3. TRENCHLESS DRILLING LENGTH IS SUBJECT TO SITE CONDITIONS AND IDENTIFIED CONSTRAINTS.
4. GROUND INVESTIGATION INFORMATION NOT AVAILABLE AT THE TIME OF DRAWING PRODUCTION. TRENCHLESS DRILLING DESIGN IS SUBJECT TO GROUND INVESTIGATION FINDINGS AND FURTHER TOPOGRAPHICAL SURVEY.
5. CABLE SIZING, TYPE, CONFIGURATION AND MAXIMUM DEPTHS ARE SUBJECT TO SPECIFICATIONS OUTLINED IN CABLE CALCULATIONS.
6. ACTUAL TRENCHLESS BOREHOLE DEPTH BELOW WATERCOURSE TO BE NO LESS THAN 8M. THIS IS SUBJECT TO FINAL DESIGN TO SUIT GROUND CONDITIONS AND CABLE RATING REQUIREMENTS.
7. THE MINIMUM DEPTH BENEATH THE HIGHWAYS IS DEPENDENT ON THE ROAD MAKEUP, AND WILL ALIGN WITH MINIMUM DEPTH REQUIRED BY THE ASSET OWNER.

LEGISLATION

Regulation 5(2)(a) Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009.

ISSUE PURPOSE

DCO Submission

PROJECT NUMBER

60700987

FIGURE TITLE

Typical Trenchless Crossings Cross-Section

FIGURE NUMBER

Figure 3-13

REV.

01

DOCUMENT REFERENCE

EN010154/APP/6.2