



ONE EARTH SOLAR FARM
EN010159

WEST LINDSEY DISTRICT COUNCIL
Secretary of State Deadline 1 Letter

WLDC Comments

Document Reference	WLDC comments
Paragraph 8	<p>WLDC welcome the additional focus in the proposed amendments to Requirement 7 on ensuring achievable and safe access to the BESS and substation during the design flood event.</p> <p>WLDC notes that this is tied in the proposed paragraph 7(2) to the outline battery safety management plan [REP7-022]. However, whilst the outline battery safety management plan has reference to access (section 4.3) its does not explicitly have reference to mitigation of the design flood events generally, or in relation to access. WLDC recommends the applicant is required to include information on flood mitigation measures on an updated revision of the outline battery safety management plan.</p>
Paragraph 9	<p>WLDC agree with the proposed amendments to Requirement 22 Flood Risk Mitigation.</p>