



## Great North Road Solar and Biodiversity Park

Environmental Statement

Volume 4 – Technical Appendices

Technical Appendix A5.4 – Outline Fire Safety Management Plan

Document reference – EN010162/APP/6.4.5.44B

Revision number 23

December 2025

February 2026

Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009, APFP Regulation 5(2)(a)

## Contents

<b>A5.4.1 Introduction</b>	<b>3</b>
A5.4.1.1 Description	3
A5.4.1.2 Background	4
A5.4.1.3 Objectives	4
A5.4.1.4 Approach	5
A5.4.1.5 Reference Documents	5
<b>A5.4.2 Organisations</b>	<b>6</b>
A5.4.2.1 Roles and responsibilities	6
A5.4.2.2 Competence	9
A5.4.2.3 Authority	9
A5.4.2.4 Communication	9
A5.4.2.5 Project development cycle guidance	10
<b>A5.4.3 Fire safety arrangements</b>	<b>11</b>
A5.4.3.1 Fire safety design	11
A5.4.3.2 Risk assessment	11
A5.4.3.3 Fire protection measures	20
A5.4.3.4 Recommendations list and compliance	20
A5.4.3.5 Fire safety training	41
A5.4.3.6 Facilities for fire fighting	41
A5.4.3.7 Evacuation / emergency procedures	41
A5.4.3.8 Fire Suppressant	42
<b>A5.4.4 Monitoring</b>	<b>43</b>
A5.4.4.1 Evacuation drills	43
A5.4.4.2 Checks, maintenance and testing	43
A5.4.4.3 Record keeping	43
<b>A5.4.5 Audit and review</b>	<b>43</b>
A5.4.5.1 Fire risk assessment	43
A5.4.5.2 Response to changes	<a href="#">4443</a>
A5.4.5.3 Records audit	44
A5.4.5.4 FSMP formal review	44
<b>A5.4 Appendix A – Training Schedule</b>	<b>45</b>
<b>A5.4 Appendix B – Standard Personal Emergency Evacuation Plans (PEEPs)</b>	<b>46</b>
Plan 1 – Person with Sight Impairment	46
Requirement	46
Escape Procedure	46

Specialist Equipment.....	46
Fire Warden Assistance .....	46
Communication .....	46
<b>Plan 2 – Person with Hearing Impairment.....</b>	<b>46</b>
Requirement.....	46
Procedure.....	46
Specialist Equipment.....	47
Fire Warden Assistance .....	47
Communication .....	47
<b>A5.4 Appendix C – Emergency Procedures .....</b>	<b>48</b>
Fire Emergency Response Plan .....	48
What People / Staff Should Do If They Discover a Fire .....	48
What People / Staff Should Do If They Hear the Fire Alarm.....	48
What Designated Staff Should Do if a False Activation has Occurred: .....	48
Contacting the Fire & Rescue Service .....	49
Fire & Rescue Service Liaison Procedure .....	49
Battery Energy Storage Specific Information .....	49
Specific Information for the Fire & Rescue Service .....	49
<b>A5.4 Appendix D – Maintenance / Testing Schedule .....</b>	<b>50</b>

## A5.4.1 INTRODUCTION

### A5.4.1.1 DESCRIPTION

- 1 The proposed Great North Road (GNR) Solar and Biodiversity Park (the “Development”) includes a Battery Energy Storage System (BESS) with an indicative maximum power output of 440 MW. The BESS will be within Work Area no. 5a: BESS. The Applicant has taken extensive measures to ensure a comprehensive fire safety strategy forms part of the Environmental Statement (ES).
- 2 This Outline Fire Safety Management Plan (FSMP) has been developed in collaboration with Blanboz Smart Renewables. This FSMP has been prepared by using the same approach adopted successfully at the consented Staythorpe BESS project (Planning Reference 22/01840/FULM). That approach was agreed after extensive consultation with Nottinghamshire Fire & Rescue Service (NFRS), and after accounting for concerns raised by the public in relation to fire safety. It was developed in coordination with industry leading experts including a Senior Advisor to the National Fire Chiefs Council (NFCC), the expert advisor to NFRS and a former Head of Safety for another large Fire and Rescue Service.
- 3 This Outline FSMP has been prepared based on the Draft Outline FSMP that was submitted for consultation as part of the Preliminary Environmental Information Report in January 2025. No responses were received that made specific comments on the content of the Draft Outline FSMP, and consequently no changes were made between the Draft Outline FSMP and this Outline FSMP.
- 4 The intention is that, following grant of the DCO, once a preferred make and model of battery has been identified, this Outline FSMP will be refined further, in consultation with relevant bodies, into a final FSMP which will be submitted for the approval of Newark and Sherwood District Council (NSDC).
- 5 The aim of this report is for the Applicant to adopt the recommended measures set out in this document. Where this occurs, the risk of a fire occurring should be significantly reduced throughout the design, procurement, construction and operational phases of the project. Proactive measures will also be set out in this document aiming to deter the spread of fire should it occur on-site.
- 6 During the construction phase, the Applicant will liaise with NFRS to ensure that the site complies with legislation, and that NFRS are familiar with the facility. The Applicant will have continual liaison with NFRS throughout the operational life of the facility, to ensure the preparation of a clear and detailed response strategy as part of a comprehensive emergency response plan (ERP) in the case of a thermal event.
- 7 There are no applicable comprehensive IEC / BS EN standards that provide the same level of guidance, and as such, NFPA 855 is considered the standard for BESS facilities for mitigating hazards associated with energy storage systems. The recommendations list and insurers guidance heavily reference UL 9540, UL 9540A, UL 1973, NFPA 68 and, or NFPA 69 and IEC

62933-5-2 for the procurement and testing of BESS components, and NFPA 855 to cover the development of the BESS facility.

#### **A5.4.1.2 BACKGROUND**

- 8 The BESS is part of the Development, for which an application for a DCO will be submitted.
- 9 It is expected that the BESS, as part of the Development, will be delivered via a BESS Supply Agreement with a BESS Original Equipment Manufacturer (OEM) and Balance of Plant (BoP) contractor. This Supply Agreement will significantly influence the technical specifications that underpin the BESS at the Development. The technical specifications will comply with all mitigations listed within this FSMP.
- 10 The BESS facility will consist of energy storage cells, modules, racks, cable and connectors, Battery Management System (BMS), DC isolators and Housings, Power Conversion Systems (PCS / inverters and step-up transformer(s)), containerised housings, cables, connectors, smoke and fire detection systems, and fire suppression systems.
- 11 The BESS is planned to consist of multiple enclosures, housing battery modules placed in series to form a rack, racks placed beside each other in parallel, heating/cooling system, fire detection and prevention system (linked together to a central fire control panel), and a Battery Management System (BMS) to ensure the safe management of each single rack/string (and to isolate each rack/enclosure by opening DC contactors). The Energy Management System (EMS) forms the second layer of protection, ensuring all rack/enclosure level BMSs are operating within the safe limits, and allows the Operations and Maintenance (O&M) team to remotely operate and monitor the system through the site wide Supervisory Control And Data Acquisition (SCADA) system.
- 12 The battery cells have a design life of 25 years, and the DCO specifies an operational phase of 40 years. Equipment will be replaced as required to meet the 25 year design life requirement. Where components are replaced due to failure, or end of life, these will be replaced with equivalent components and certification. Any Lithium-Ion batteries replaced due to failure, augmentation or end of life, shall maintain or exceed the same level of certification that the batteries were previously procured with. The Applicant will appoint an O&M Contractor to conduct periodic maintenance activities on all aspects of the BESS facility.

#### **A5.4.1.3 OBJECTIVES**

- 13 The objectives of the recommendations in this FSMP are to:
  - Assist the Applicant to fulfil their responsibilities to provide appropriate and effective fire safety management in their premises;
  - Support the design fire strategy;
  - Assist managers responsible for fire safety in the premises in discharging their duties effectively; and
  - Provide a documentary record of the fire safety arrangements in the premises to assist in demonstrating compliance with the requirements of The Fire Safety Order (see section A5.4.1.5).

#### **A5.4.1.4 APPROACH**

14 The FSMP recommendations cover the following key areas:

- Organisation – overview of the planned organisation including roles and responsibilities;
- Fire Safety Arrangements – fire safety arrangements for the site, including:
  - Risk Assessment - comprehensive risk assessment covering the most critical failure modes experienced by the BESS from its initial transportation to site and storage, to issues seen on other similar sized BESS facilities. The risk assessment includes prevention measures and mitigations that must be implemented throughout the design, construction and operation of the project;
  - Recommendations List - the recommendations list contains technical guidance from independent insurers, GNR BESS will demonstrate compliance with these insurance requirements, considering NFPA 855 to enhance the design of the facility, mitigating fire risk as far as reasonably possible. The goal is to prevent any event from occurring, and secondarily introduce mitigations to prevent the spread of any such event;
- Monitoring – evacuation drills, checks, maintenance and testing, record keeping; and
- Audit and Review – review schedule, audit trail requirements and response to changes.

#### **A5.4.1.5 REFERENCE DOCUMENTS**

- BS 9999: 2017 Code of practice for fire safety in the design, management and use of buildings;
- UL 1973 – Standard for Batteries for Use in Stationary, Vehicle Auxiliary Power and Light Electric Rail (LER) Applications.
- UL 9540 – Energy Storage System (ESS) Requirements;
- UL 9540A – Battery Energy Storage System (ESS) Test Method;
- NFPA 68 – Standard on Explosion Protection by Deflagration Venting;
- NFPA 69 – Standard on Explosion Prevention Systems;
- NFPA 855 – Standard for the Installation of Stationary Energy Storage Systems;
- IEC 62619 –Secondary cells and batteries containing alkaline or other non-acid electrolytes - Safety requirements for secondary lithium cells and batteries, for use in industrial applications;
- Allianz Global Corporate and Speciality, Allianz Risk Consulting, Tech Talk 26 – Battery Energy Storage Systems (BESS) Using Li-Ion Reference 26/19/02;
- FM Global, Property Loss Prevention Datasheets, 5-33 Lithium-Ion Battery Energy Storage Systems, Interim Revision January 2024;
- BS5839-1:2017 - Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises;
- BS EN IEC 62933-5-1 Electrical energy storage (EES) systems - Part 5-1: Safety considerations for grid-integrated EES systems - General specification.

- BS EN IEC 62933-5-2 Electrical energy storage (EES) systems - Part 5-2: Safety requirements for grid-integrated EES systems - Electrochemical based systems.
- The Building Regulations 2010, Approved Document B (Fire Safety) - Volume 2;
- European Association for Storage of Energy (EASE), Battery Energy Storage System (BESS) Safety Best Practices Guideline, March 2025; and
- The Fire Safety Order.

## A5.4.2 ORGANISATIONS

### A5.4.2.1 ROLES AND RESPONSIBILITIES

<sup>15</sup> Table A5.4.1 sets out the recommended fire safety roles and responsibilities relevant to the management structure.

**Table A5.4.1 – Roles & Responsibilities**

Role	Summary of Responsibilities
Board / Directors	<ul style="list-style-type: none"> <li>• Must ensure all relevant statutory fire safety provisions and requirements are always implemented and complied with in full;</li> <li>• Ensure that the fire safety policies/codes of practice that complement this management plan are in place, properly implemented and reviewed;</li> <li>• Ensure that qualified people are appointed to oversee and implement fire safety arrangements, and ensure that they are competent and appropriately trained to undertake their duties;</li> <li>• Ensure that arrangements are in place for the completion of Fire Risk Assessments and fire risk assessment reviews, including, where appropriate, technical surveys in respect of fire protection;</li> <li>• Ensure that fire, security, and health and safety arrangements at the premises are adequate and complementary;</li> <li>• Ensure that the plant has adequate insurance coverage.</li> </ul>
Fire Safety Manager	<ul style="list-style-type: none"> <li>• Ensure that Fire Risk Assessments and reviews are carried out when required;</li> <li>• Ensure that fire safety systems and equipment are appropriately located and properly maintained;</li> <li>• Ensure that a robust and effective Emergency Response Plan is in place to safely evacuate all persons, whether employees, visitors etc. This emergency plan must take into account people with mobility, sensory and learning impairments, including those with temporary impairments;</li> </ul>

Role	Summary of Responsibilities
	<ul style="list-style-type: none"> <li>• Arrange for the Emergency Response Plan to be issued to employees, visitors etc. to inform them what to do in the event of a fire, particularly safe evacuation;</li> <li>• Ensure that staff are appropriately trained in fire safety procedures to reflect the requirements of the Fire Risk Assessment;</li> <li>• Ensure that a copy of the current Fire Risk Assessment for the premises is readily accessible, and its provisions complied with;</li> <li>• Ensure that Fire Risk Assessments are reviewed at appropriate intervals;</li> <li>• Ensure that effective arrangements are in place for contacting the emergency services;</li> <li>• Ensure that the Fire and Rescue Service are aware of any significant hazards associated with the premises e.g., ethanol and any other dangerous substances; and</li> <li>• Liaise with NFRS to include post-incident meetings to discuss response, lessons learned and improvements to procedures.</li> </ul>
BESS Specialist Consultant	<ul style="list-style-type: none"> <li>• Ensure that all relevant applicable standards and regulations are implemented in the selected BESS technology;</li> <li>• Provide technology reviews from a BESS fire safety engineering angle;</li> <li>• Support Board/Directors, Fire Safety Manager among others with BESS engineering knowledge and intelligence to optimise solutions to reduce fire and explosion risks.</li> </ul>
Competent / Designated Persons	<ul style="list-style-type: none"> <li>• Assist and support with the preparation and review (at least annually) of Fire Risk Assessments;</li> <li>• Ensure compliance with the outcomes of the Fire Risk Assessment and that the necessary control measures are implemented;</li> <li>• Prepare and review the Fire Emergency Plan and ensure it is issued to all staff;</li> <li>• Ensure information on fire safety arrangements is available to staff;</li> <li>• Ensure all staff, visitors etc. are inducted on the contents of the Fire Emergency Plan;</li> <li>• Arrange and review fire drills at a suitable frequency;</li> <li>• Specify the arrangements for assisting visitors, disabled people or those with temporary physical impairments to safely evacuate the premises. Where appropriate, a PEEP must be developed;</li> </ul>

Role	Summary of Responsibilities
	<ul style="list-style-type: none"> <li>• Ensure Fire Alarms are tested in accordance with the testing and maintenance schedule;</li> <li>• Monitor that all fire safety equipment and systems are appropriately and regularly maintained;</li> <li>• Ensure the Fire Safety Logbook is kept up to date;</li> <li>• Ensure that Fire Action Notices and fire signage are appropriate and kept up to date;</li> <li>• Ensure all escape routes are kept clear of obstruction and that access to fire extinguishers and fire alarms is not impeded;</li> <li>• Ensure that all relevant fire prevention procedures are put into effect;</li> <li>• Ensure that fire safety inspections of the premises are carried out;</li> <li>• Ensure local fire related safety policies including no-smoking; and</li> <li>• Liaise with NFRS to include post-incident meetings to discuss response, lessons learned and improvements to procedures.</li> </ul>
Employees	<ul style="list-style-type: none"> <li>• Ensure familiarity with the Fire Emergency Plan for the premises and co-operate by participating in fire evacuation/drill procedures and by observing practical fire safety arrangements;</li> <li>• Fully conversant with site strategy and steps to be taken during any events related to fire;</li> <li>• Know, and co-operate with, the fire safety manager(s) for the premises;</li> <li>• Report to a relevant manager any concerns about fire safety;</li> <li>• Are familiar with all escape routes;</li> <li>• Take care to not wedge fire doors open, nor block or obstruct them;</li> <li>• Are aware of the action to be taken on discovering a fire, hearing a fire alarm, for raising the alarm (including the location of fire alarm call points) and for calling the Fire and Rescue Service;</li> <li>• Promptly evacuate the premises, in accordance with the Emergency response plan, to a place of safety without putting themselves and others at risk, and do NOT attempt to extinguish a fire unless they have been specifically trained; and</li> <li>• Comply with the No Smoking policy in place.</li> </ul>

- 16 Arrangements should be put in place to ensure deputies are nominated to perform essential functions in the absence of the primary designated person.

**A5.4.2.2 COMPETENCE**

- 17 All those who have designated roles and responsibilities in respect of the fire safety management plan shall be competent. Competence will be achieved through knowledge, training and experience.

**A5.4.2.3 AUTHORITY**

- 18 Any person with a designated role and/or responsibility would be given the necessary authority to make decisions and take actions commensurate with their role / responsibilities.

**A5.4.2.4 COMMUNICATION**

- 19 Methods of communication are to be put in place to ensure effective sharing and exchange of fire safety information.
- 20 The essential areas for communication are set out in Table A5.4.2.

**Table A5.4.2 – Communication**

Subject	Method / Procedure
Dissemination of information about fire hazards	<ul style="list-style-type: none"> <li>• Safety briefings and meetings.</li> <li>• Exchange of documents.</li> </ul>
Fire prevention arrangements	<ul style="list-style-type: none"> <li>• Included within staff training and refresher meetings.</li> <li>• Communicated with NFRS via email.</li> </ul>
Emergency fire response procedure	<ul style="list-style-type: none"> <li>• Included with staff training and refresher meetings.</li> <li>• Communicated with NFRS via email.</li> <li>• Local copy available within Information Box at main and emergency entrances to site.</li> <li>• Local copy available within welfare facility on-site (construction and operation).</li> <li>• Readily accessible to Operations and Maintenance (O&amp;M) control room.</li> </ul>
Reporting system for concerns or deficiencies in fire safety matters	E.g., verbal, submit hard-copy form, e-form via app.
Liaison with local Fire & Rescue Service	<ul style="list-style-type: none"> <li>• Familiarity visits.</li> <li>• Communication via email and phone.</li> <li>• Emergency Response Plan (ERP) within Information Box.</li> <li>• Post-incident meeting to discuss response, lessons learned and improvements to procedures.</li> </ul>

Subject	Method / Procedure
Informing relevant parties on the stakeholder management plan	Communication via phone, email and meetings.

#### A5.4.2.5 PROJECT DEVELOPMENT CYCLE GUIDANCE

- 21 Communication between the relevant parties during the construction phase is critical to ensure fire safety on site.
- 22 Table A5.4.3 sets out the key aspects of the expected co-ordination between the Applicant, the BESS OEM, BoP contractor and any other personnel on-site.

**Table A5.4.3 – Project Development Cycle Communication Requirements**

Subject	Key Summary	Notes
Significant Fire Hazards	The Applicant will be responsible for ensuring the correct information flow between the relevant parties regarding significant fire hazards, their locations, quantities and any key precautions to be taken.	Precautions covered within Section 3.
Communications	Agree process for communicating: <ul style="list-style-type: none"> <li>• Warning of fire;</li> <li>• Other fire-related alerts;</li> <li>• Changes in fire hazards;</li> <li>• Reports of fire concerns affecting the other party's area; and</li> <li>• Interface between operator's control room and NFRS.</li> </ul>	Other alerts may include investigating potential concerns (e.g., smell of smoke). Meetings (routine or ad-hoc) may be arranged.
Emergency Response	Agreements on: <ul style="list-style-type: none"> <li>• Designated escape routes;</li> <li>• Shared escape routes;</li> <li>• Assembly points;</li> <li>• Meeting fire crews attending;</li> <li>• Step by step guide for evaluating any potential BESS facility fires; and</li> <li>• Post-incident de-brief / remediation.</li> </ul>	ERP to be agreed with NFRS prior to construction commencing.
First Aid	Provide information on first aid provisions on site, nearest	

	hospitals and emergency contact details.	
--	--	--

### **A5.4.3 FIRE SAFETY ARRANGEMENTS**

#### **A5.4.3.1 FIRE SAFETY DESIGN**

- 23 The chosen BoP contractor retains control of the fire safety design until handover to GNR BESS. The BoP contractor will be responsible for integrating the site-wide fire protection and suppression strategy.

#### **A5.4.3.2 RISK ASSESSMENT**

- 24 The risk matrix in Table A5.4.4 has been developed to consider the probability and impact of any identified failure modes, and the prevention / mitigation measures that could be included throughout the different phases of the project.

**Table A5.4.4 – Risk Assessment Matrix**

			Probability				
		Severity Description	1 (Remote)	2 (Unlikely)	3 (Possible)	4 (Probable)	5 (Almost Certain)
Severity (S)	5 – Catastrophic	Risk of death, explosion, complete loss of facility, catastrophic environmental damage	HIGH	CRITICAL	CRITICAL	CRITICAL	CRITICAL
	4 – Major	Life changing injury, extensive damage to facility, significant environmental damage	HIGH	HIGH	CRITICAL	CRITICAL	CRITICAL
	3 – Moderate	Significant non-life changing injury, significant damage to facility, minor environmental damage	MEDIUM	MEDIUM	HIGH	HIGH	CRITICAL
	2 – Minor	Minor injury, minor damage to facility,	LOW	LOW	MEDIUM	HIGH	HIGH
	1 – Inconvenience	No risk of injury, no damage to facility and no environmental damage	LOW	LOW	LOW	MEDIUM	MEDIUM

**Table A5.4.5 – Site Risk Assessment Matrix**

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
1	Battery	Battery fire	Transportation	<ul style="list-style-type: none"> <li>Personnel Injury.</li> <li>Physical damage to Battery.</li> <li>Toxic chemicals leak.</li> <li>Explosion.</li> </ul>	3	3	High	Lithium batteries are required to pass Section 38.3 of the UN Manual of Tests and Criteria (UN Transportation Testing). The provision of a UN 38.3 or UN transportation testing report is required for transportation. UN 38.3 requires several tests to prove the battery design is safe for transportation including thermal, vibration, shock, short circuit, and impact testing. The chosen technology will require testing evidence to UN 38.3 to prove the design is safe for transportation.	3	1	Medium	UN 38.3 testing will be conducted on the design to reduce the probability of this occurring.
2	Natural Hazard	Water damage	Flooding	<ul style="list-style-type: none"> <li>Water damage to BESS equipment / submerged site</li> </ul>	4	1	Critical	A Flood Risk Assessment (FRA) has been completed for the Development, which identified no flood risk for Work Area no. 5a, including the BESS.	4	1	Medium	No effect is expected from flooding on the BESS.
3	Battery	Thermal hazard	Battery Cell / Module Over / Under Temperature	<ul style="list-style-type: none"> <li>Injuries to personnel (burns, smoke, and chemical inhalation).</li> </ul>	3	3	High	BESS containers are generally cooled by a Heating Ventilation and Air Conditioning (HVAC) unit or are liquid cooled using a heat exchanger, expansion vessel, pump and associated small bore pipe work to infer heat transfer from the battery cells.	3	1	Medium	The Applicant shall procure field proven equipment.

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
				<ul style="list-style-type: none"> <li>Damage to battery cell and BESS container.</li> </ul>				<p>The battery cells will have a target temperature which is pre-programmed by the BESS Original Equipment Manufacturer (OEM) in the Battery Management System (BMS) which communicates with the Industrial Personal Computer or package controller within the control panel. This then drives the cooling system to act to maintain an optimum ambient temperature to maintain the pre-programmed operating environment.</p> <p>Where the cooling system develops a fault, alarms will immediately be sent via the BESS SCADA system to the operations control room. The BESS container will automatically be prevented from charging / discharging, to allow the operators time to rectify the fault. Continuous preventative maintenance as advised by the BESS OEM.</p> <p>Regular maintenance of the BESS will be conducted in accordance with the BESS OEM's recommendations.</p>				
4	Battery	Thermal hazard	Fire Detection System Failure	<ul style="list-style-type: none"> <li>Injuries to personnel (burns, smoke, and chemical inhalation).</li> <li>Damage to battery cell and surrounding BESS infrastructure.</li> </ul>	4	3	Critical	<p>The BESS OEMs under consideration predominantly supply their solution with a minimum of 1 x smoke detector and 1 x heat / CO detector, these designs will have several sensors of each for back-up and these will not be connected on the same line to provide redundancy. Alternative suppliers will utilise the BMS and associated proven algorithms rather than physical detection devices, to detect if an event is occurring.</p> <p>In the rare event of a complete fire detection system failure, the initial communications loss or any continuous rise in temperature or electrical fault would be detected by the BMS and error messages communicated to the SCADA for operator rectification.</p> <p>Maintenance of the fire detection system is critical to ensure operation, at regular intervals as dictated by the BESS OEM, the operator will conduct checks on the full detection system.</p>	2	3	Medium	The severity is reduced due to the unit having several protections, starting from initial procurement of proven, certified components to BESS equipment that has been tested for propagation.

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
5	Battery	Thermal hazard	Fire Suppression System Failure	<ul style="list-style-type: none"> <li>Injuries to personnel (burns, smoke, and chemical inhalation).</li> <li>Damage to battery cell and surrounding BESS infrastructure.</li> </ul>	4	3	Critical	<p>Where the fire suppression system fails to activate when required, the emergency response plan for the site should be followed. Upon the initial activation of the fire detection system, the SCADA system will notify the operators to enable the emergency response plan and contact NFRS for assistance.</p> <p>The battery modules and enclosure selected during the tender process should be all proven to the UL9540A – Battery Energy Storage System (ESS) Test Method. UL9540A standard subjects the battery modules and enclosure to large scale fire testing, batteries are forced into failure, held for a period of time, and then proven to not propagate extensively outside the limits of the test, nor have an excessive concentration of flammable gas.</p>	3	2	Medium	<p>Please note that BESS OEMs determine the fire suppression system for the BESS container.</p> <p>The operator has selected LFP batteries as their battery selection. The operator has also optimised the layout of the site using NFPA 855 – Standard for Installation of Stationary Energy Storage Systems, this further reduces the chance of the event propagating from container to container by enforcing clearance distances from potential exposure, with exceptions for equipment that have completed UL9540A testing and are approved by NFRS / NSDC.</p>
6	Battery	Thermal hazard	Battery Cell / Module Failure – Thermal Runaway	<ul style="list-style-type: none"> <li>Injuries to personnel (burns, smoke, and chemical inhalation).</li> <li>Damage to battery cell and surrounding BESS infrastructure.</li> </ul>	5	3	Critical	<p>The Applicant will procure equipment in accordance with UL 9549 (or IEC 62619 ) certification and UL9540A testing, to prove that the fire will not spread to adjacent modules / units / systems as the testing shows. The philosophy is then to use the water within the fire tanks to cool adjacent enclosures / cabinets to add a secondary layer of prevention and allow the effected item to consume itself.</p> <p>Section 2.5.3.3 (Early Intervention Thermal Runaway Prevention) of FM Global 5-33 (2024) sets out that the battery protection system together with the BMS will be capable of automatic early detection and electrical isolation of a thermal runaway event via constant monitoring of the cells' temperature or by off-gas detectors capable of identifying the volatile organic compounds that commonly precede thermal runaway.</p>	3	1	Medium	<p>The BoP contractor and BESS OEM shall provide a detailed methodology of the purpose of the fire detection and suppression system, with particular emphasis on the disconnection of the BESS, interlocking of the container and HVAC systems.</p>
7	Battery	Explosion Hazard	Battery Cell/ Module Failure – Thermal Runaway.	<ul style="list-style-type: none"> <li>Damage to battery components and surrounding</li> </ul>	5	2	Critical	<p>NFPA 855 (2023) Section 9.6.5.6.6 states that when batteries are installed in a container outside, they must comply with one of the following:</p>	5	1	High	<p>The selected BESS unit will be equipped with either an explosion prevention system, compliant with NFPA 69, or a deflagration venting system, compliant with NFPA 68. This will form part of a comprehensive</p>

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
			Thermal effects chain reaction from cells within the battery module.	BESS infrastructure. <ul style="list-style-type: none"> <li>• Release of toxic gases – pollution.</li> <li>• Injury to site personnel (burns, smoke and chemical inhalation).</li> <li>• Release of flammable gasses.</li> </ul>				<ul style="list-style-type: none"> <li>• Explosion prevention systems designed, installed, operated, maintained and tested in accordance with NFPA 68.</li> <li>• Deflagration venting installed and maintained in accordance with NFPA 68.</li> </ul> Alternatively, these explosion prevention and deflagration venting features may be omitted if the BESS unit is deemed sufficiently safe from fire propagation, as demonstrated by adequate testing and by proving that the BESS design does not allow flammable gas concentrations inside the container to exceed 25% of the LFL.				safety strategy that takes into account all potential scenarios in the event of an emergency.
8	Battery	Explosion hazard	Ventilation System Failure  Battery Cell/ Module Failure – Thermal Runaway.	<ul style="list-style-type: none"> <li>• Injuries to personnel (blast pressure effects and burns).</li> <li>• Damage to batteries and surrounding BESS infrastructure.</li> </ul>	5	3	Critical	Section 2.5.5 (Air Circulation/Mechanical Ventilation) of FM Global 5-33 (2024) and the NFCC guidance (2025 draft) set out the following measures:  To prevent explosions caused by off-gassing, particularly hydrogen accumulation, due to inadequate air circulation in the battery containers, hydrogen detectors will be installed to alarm at 10% Lower Explosive Limit (LEL) in the battery containers. A forced circulation/ventilation system will be provided to vent off-gases to safe levels and activate emergency exhaust ventilation at a maximum of 25% LEL to rapidly exhaust air directly outdoors. The system's design will incorporate non-combustible ductwork, carefully routed to prevent water ingress and explosive gas leakage to other areas of the container and will include alarm notifications to a constantly attended location. This system will be integrated into the site's emergency response plan (ERP) and will have a clear marking of the ventilation system's disconnect switch to ensure emergency responders do not inadvertently disconnect the power supply during an incident.	2	3	Medium	
9	Battery	Thermal hazard	Battery Cell / Module Over / Under Voltage	<ul style="list-style-type: none"> <li>• Irreversible Battery damage.</li> </ul>	3	2	Medium	Batteries will be continuously monitored by the Battery Management Module (BMS). Where the BMS detects a cell in under voltage, Under Voltage Protection (UVP), an alarm would be	2	1	Low	

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
				<ul style="list-style-type: none"> <li>Efficiency reduction.</li> <li>Thermal Runaway.</li> </ul>				sent to the SCADA to inform the operator and the BMS should take corrective action to increase the cell voltage.  Where the battery cell is detected to have an overvoltage, Over Voltage Protection (OVP) will be activated. The BMS will force shut the battery rack contactors, bringing the rack offline and isolated from the remainder of the unit. Further investigation will be required, but it is likely that the battery module will be replaced by the battery supplier.				
10	All BESS equipment	Electrical hazard	Communications Failure		2	2	Low	Where a rare communications failure occurs within the BESS containers, the system will lock in, and all DC contactors will close to isolate the effected BESS enclosure. The auxiliary power will be maintained to provide power to the monitoring systems of the BESS. For a site-wide power outage, there is a UPS which is used to power only the critical auxiliary circuits until the auxiliary power can be returned.  The UPS will undergo continuous maintenance as part of the O&M regime.	1	2	Low	The communications logic from each BESS OEM will vary, the communications logic is usually CANbus between each rack and the system BMS, then MODbus RS484 or TCP/IP to the EMS and onwards to the SCADA. The SCADA then provides access to the operators through a local or remote HMI within the operations control room, then finally on to the integration with the grid where applicable.
11	Battery	Thermal hazard	HVAC / Liquid Cooling System Failure	<ul style="list-style-type: none"> <li>Injuries to personnel (burns, smoke, and chemical inhalation).</li> <li>Electrical and fire damage to battery cell.</li> </ul>	3	2	Medium	Entering standby mode allows the effected BESS enclosure to prevent any unintended temperature increases due to charging / discharging. The temperature will gradually increase / decrease to the local ambient temperature over time. The operators will be alerted through the SCADA and can immediately proceed with corrective action using the on-site spares contingent.  Maintenance of the HVAC system is critical to ensure reliable operation. At regular intervals as dictated by the BESS OEM, the operator will conduct preventative maintenance including filter clean-ups, filter replacements, refrigerant checks / re-charge or coolant checks / top-ups and related activities to ensure reliable operation of the cooling system.	2	1	Low	The HVAC system is normally powered from the auxiliary circuit for the site, which is fed from the main grid voltage via a step-down transformer. Where the system fails through mechanical, electrical or software means, the operators will be notified via the EMS / SCADA system that an error has occurred. The effected BESS enclosure will automatically enter standby mode by not importing / exporting from the batteries.
12	All BESS equipment	Electrical Failure	Energy Management	<ul style="list-style-type: none"> <li>Electrical and fire damage</li> </ul>	2	1	Low	Where a very unlikely error occurs with the EMS and too much power is imported from the	1	1	Low	The EMS is used to control all of the devices and interfaces on site, it

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
		and Thermal Hazard	System Failure	to battery cell and other site equipment.				grid or too much power is exported from the BESS, there are multiple lines of protection. The transformers on each BESS block are likely to be protected via Voltage Transformer monitoring and potentially Current Transformer monitoring, that will trip the site or BESS block off as required. The PCS also has voltage protection and will trip when outside of the expected voltage range.				provides a bridge from the BESS to the customer, market and utility interfaces. The EMS dispatches each of the energy storage systems and controls the communications to influence the charging / discharging of the batteries.
13	Transformer / Power Conversion System	Thermal and Environmental hazard	Transformer / Power Conversion System Failure	<ul style="list-style-type: none"> <li>Fire spreading to surrounding BESS containers and/or surrounding environment.</li> </ul>	4	2	High	The transformers and PCS will be positioned according to the manufacturer's guidance. The transformer will be banded to prevent the potential leakage of cooling fluid to the environment.	3	1	Medium	
14	Transformer / Power Conversion System BESS	Electrical hazard	Arcing or short circuit	<ul style="list-style-type: none"> <li>Electrocution resulting in injury or fatality</li> <li>Ignition to start fire</li> </ul>	5	2	Critical	<p>The BESS OEM and BoP Contractor shall provide arc flash protection, proven through relevant studies.</p> <p>The relevant contractors will conduct arc flash / fault level studies for the HV switchgear according to IEEE 1584 or equivalent and provide arc-flash PPE requirements for relevant equipment on site.</p> <p>All equipment on site will be subject to an intensive maintenance regime in accordance with the relevant BESS OEM, and BoP Contractor.</p>	5	1	High	
15	All BESS equipment	Electrical hazard	Failure to follow maintenance regime	<ul style="list-style-type: none"> <li>Reduced BESS lifetime.</li> <li>Battery efficiency and capacity decrease.</li> </ul>	1	2	Low	The BESS OEM provides a minimum recommended operation and maintenance regime that must be followed throughout the lifetime of the facility. The BESS O&M contractor and BESS OEM are both incentivised to fully implement the maintenance regime, as the financial performance from both parties may be significantly impacted from premature degradation, unexpected downtime or loss of systems. The operator should carry out periodic inspections and site meetings to ensure that the O&M provider is adhering to the recommended guidance.	1	1	Low	

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
16	All BESS equipment	Environmental hazard	Failure to follow vegetation management / debris management	<ul style="list-style-type: none"> <li>Injuries to personnel</li> <li>Damage to BESS infrastructure.</li> </ul>	1	2	Low	The operator will sign an agreement with an O&M provider to ensure that the BESS site is well maintained. The operator will delegate the site maintenance including vegetation management to the O&M provider. The O&M provider shall ensure that there is no over-hanging vegetation across the site boundaries, all BESS containers including transformer / PCS must be completely free of over-hanging tree branches and be sited a minimum of 3m from the closest vegetation in accordance with NFPA 855, unless UL9540A test reports are submitted to relax this restriction with approval from NFRS / the LPA.	1	1	Low	
17	All BESS Equipment	Thermal hazard	Emergency services unable to respond effectively due to lack of knowledge of battery chemistry, system size and procedure.	<ul style="list-style-type: none"> <li>Unwarranted damage to BESS equipment and surrounding infrastructure.</li> <li>Financial cost to replace and repair damage.</li> <li>Injury to first responders/ SFRS.</li> </ul>	4	3	Critical	A pre-incident and emergency response plan (ERP) will be developed in collaboration with the local fire rescue service to ensure effective response and safety in the event of a fire or explosion. The ERP will address key considerations, including hazard identification, safe access, water supply, firefighting infrastructure, vegetation management, and prevention of fire ignition and spread. Site personnel and the local fire rescue service will receive training on emergency plan priorities and actions to follow in the event of an incident, with regular updates and reviews to ensure the plan remains effective.	2	2	Low	Owners and developers directly benefit from developing an effective emergency plan as it can mitigate the overall scope of property damage and increases the likelihood of the facility maintaining continuity of operations.
18	Batteries / Oil-filled Transformers	Chemical spill hazard	Inadequate containment and detection measures, equipment failure, or human error	<ul style="list-style-type: none"> <li>Environmental pollution,</li> <li>Short circuit / Electrical fire</li> <li>Damage to BESS infrastructure</li> </ul>	4	3	Critical	Containment measures such as bunds for transformers and spill trays for liquid-cooling systems shall be installed, including leak detection sensors for the battery containers. A spill response plan will be developed and added to the ERP.	2	2	Low	
19	All BESS Equipment	Thermal hazard	Inadequate fire stop (F-stop) mechanism	<ul style="list-style-type: none"> <li>Uncontrolled fire/explosion</li> <li>Damage to BESS infrastructure</li> </ul>	4	3	Critical	The F-Stop mechanism shall be designed to maintain the operational functionality of the BMS and firefighting or explosion prevention systems of the BESS while disconnecting non-critical components during fire or explosion scenarios. These capabilities shall be tested and validated across multiple fault conditions.	3	2	Medium	

No.	Component	Hazard	Cause of Hazard	Consequence	Initial Risk Assessment			Prevention / Mitigation Strategy	Residual Risk Assessment			Further comments
					S	P	Risk		S	P	Risk	
								Functional safety assessments (FMEA/HARA) will be conducted to ensure F-Stop reliability. Compliance with relevant standards (UL 9540/IEC 61508) will determine the need for redundancy, which will be implemented to eliminate single points of failure and enhance emergency reliability.				

### **A5.4.3.3 FIRE PROTECTION MEASURES**

- 25 Passive and active fire protection measures should be maintained in good order to ensure their effectiveness. Active fire protection measures have been introduced throughout the site design, covering fire detection and suppression especially on the BESS containers as these are flagged as the highest risk assets. Passive fire protection has been included by following NFPA 855 guidance for the site layout design and firefighting equipment on site.
- 26 They will be subjected to checks, tests and maintenance as detailed in Appendix D.
- 27 Passive fire precautions as regards the physical conditions in the premises are designed to facilitate containment of fire by design, construction and layout, effective communication and safe evacuation. Active fire precautions within the fire safety management system detect and engage in the event of a fire, including fire alarm systems, emergency lighting systems, firefighting equipment and fire shutters / curtains.
- 28 Passive and active fire protection measures will be maintained in good working order in accordance with manufacturer's instructions and British Standard guidance where applicable. They will be subjected to checks, tests and maintenance as detailed in Appendix D.

### **A5.4.3.4 RECOMMENDATIONS LIST AND COMPLIANCE**

- 29 Tables A5.4.6, A5.4.7 and A5.4.8 cover key loss prevention recommendations for the design, operation, protection, inspection, maintenance, and testing of BESS systems that utilise Lithium-Ion batteries. The Applicant has demonstrated compliance with the key measures outlined below, that aim to significantly reduce the potential and mitigate the impact of BESS related incidents. The guidance provided by these technical publications is used to ensure developers produce the most resilient site possible. Additional study will be required as the project proceeds throughout the development lifecycle. The following technical publications have been referenced to draft the recommendations list below:
  - Allianz Global Corporate and Speciality, Allianz Risk Consulting, Tech Talk 26 – Battery Energy Storage Systems (BESS) Using Li-Ion Reference 26/19/20;
  - FM Global, Property Loss Prevention Datasheets, 5-33 Lithium-Ion Battery Energy Storage Systems, Interim Revision January 2024.
  - European Association for Storage of Energy (EASE), Battery Energy Storage System (BESS) Safety Best Practices Guideline, March 2025.

**Table A5.4.6 – Allianz Risk Consulting Recommendations**

Allianz Risk Consulting Recommendation	Compliance Statement	Compliance
<p><u>Fire Department</u>                      Invite the fire department to your property to discuss BESS hazards. An adequate emergency response is the key to avoiding an uncontrolled fire. Keep in mind that some fire fighters will not fully understand the hazards and may assume that lithium-ion batteries are the same as lithium batteries.</p> <ul style="list-style-type: none"> <li>• Key questions to discuss with the fire department include:                             <ul style="list-style-type: none"> <li>○ What is the main difference between extinguishing and cooling?</li> <li>○ How to handle a damaged battery?</li> <li>○ How to manage the flammable and toxic gases?</li> </ul> </li> <li>• Plan training exercises with the fire department when the system is commissioned.</li> <li>• Standard Operating Procedures (SOP) &amp; Standard Operating Guidelines (SOG) are of major importance and should be updated and tested on a regular basis.</li> </ul>	<p>The Applicant will engage with the Nottinghamshire Fire and Rescue Service and independent technical advisors for the production of the FSMP. The Applicant will seek to involve NFRS during the production of the emergency response plan that will be created for the site prior to the construction phase commencing.</p> <p>The Emergency Response Plan (ERP) will outline the steps to be taken by any personnel on site, personnel in the operations control room and provide key information for first responders who attend the site. The ERP will contain key information from the BESS OEM, The Applicant, and related parties to allow the first responders to evaluate the steps to be taken on site.</p> <p>The BESS OEM, BoP Contractor and O&amp;M Contractor will be required to maintain SOPs as part of their quality plan.</p>	<p>Full compliance upon completion of ERP</p>
<p><u>Construction and Location</u>                      Install BESS outdoors a minimum of 20 m (65 ft.) from important buildings or equipment. Maintain a minimum of 3 m (10 ft.) separation from lot lines, public ways and other exposures.</p> <ul style="list-style-type: none"> <li>• Within the module, maintain a minimum of 1 m (3 ft.) separation distance between enclosures for all units up to 50 kWh when not listed, or up to 250 kWh when listed.</li> <li>• Install a thermal barrier where the minimum space separation cannot be provided.</li> <li>• If the BESS must be located indoors, install in a 2-hour fire rated cut-off room, which is accessible directly outdoors for manual firefighting.</li> <li>• Restrict the access to competent employees or sub-contractors.</li> <li>• Ensure enclosures are non-combustible.</li> </ul>	<p>The BESS facility design will follow regulations and NFPA 855. NFPA 855 allows the separation distance between containers to be reduced to 0.9 m, where large scale fire testing has been completed in accordance with UL 9540A or equivalent standards, and the UL 9540A test report is approved by the NFRS / LPA. The Applicant will include UL 9540A compliance as part of the tendering exercise, and this will drive final grouping and separation distances between enclosure to enclosure, and from each enclosure to exposures.</p> <p>The Applicant will submit the UL 9540A test report from the BESS OEMs for sign-off by the NFRS prior to construction commencing. It is recommended that this is also agreed with the insurer of the BESS prior to proceeding with the application.</p> <p>The BESS enclosures shall comply with UL 9540.</p> <p>Pending acceptance of the UL 9540A test report by the LPA / NFRS, The Applicant has allowed for a spacing of 3.0 m between BESS enclosures on all sides.</p>	<p>Partially Compliant                      (Full compliance upon selection of BESS OEM)</p>
<p><u>Material, Equipment and Design</u></p> <ul style="list-style-type: none"> <li>• BESS should be tested in accordance with UL 9540A, Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems.                      This standard evaluates thermal runaway, gas composition, flaming, fire spread, re-ignition and the effectiveness of fire protection systems. Data generated can be used to determine the fire and explosion protection requirements for a BESS.</li> <li>• Place capacitor, transformer, and switch gear in separate rooms according to best engineering practices.</li> </ul>	<p>The chosen BESS equipment will be tested as per UL 9540A, the BESS OEM will conduct testing initially at cell level, and then progress to module, unit and system level as required to demonstrate compliance with UL 9540A. UL 9540A testing evaluates the design of the BESS equipment and is used to establish minimum clearance distances.</p> <p>The Applicant has allowed for a spacing of 8 m between the Transformer Station and BESS enclosures, final spacing shall be determined by the BESS OEM following provision of the UL 9540A test report(s). Any modification to the clearance distances and associated infrastructure post-consent will be completed through the discharge of DCO requirements process.</p> <p>Any transformers and switchgear shall be housed within a fenced off compound using CAT2 Mesh Fencing. Each transformer will have its own</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>

Allianz Risk Consulting Recommendation	Compliance Statement	Compliance
	bund and comply will the relevant clearance distances as described by the selected manufacturer and verified through calculations. Any switchgear will be housed within an independent Switchgear room within the compound.	
<p><u>Ventilation and Temperature Control</u></p> <ul style="list-style-type: none"> <li>Install adequate ventilation or an air conditioning system to control the temperature. Maintaining temperature control is vital to these batteries' longevity and proper operation as they degrade exponentially at elevated temperatures. On the other hand, energy capacity of batteries drop at low temperatures.</li> <li>Ensure ventilation is provided in accordance with the manufacturer's recommendations.</li> <li>Install and maintain the ventilation during all stages of a fire. Ventilation is important since batteries will continue to generate flammable gas as long as they are hot. Also, carbon monoxide will be generated until the batteries are completely cooled through to their core</li> </ul>	<p>The manufacturer of the BESS designs the temperature control and ventilation of the BESS. Following commissioning, the operations and maintenance of the system will be the responsibility of the O&amp;M contractor. A decision has not been reached on the cooling methodology, this will either be liquid or air cooled. The cooling functionality is extensively tested during the initial design of the BESS enclosures.</p> <p>The Applicant will ensure that their chosen BESS OEM's equipment complies with NFPA 68 (Deflagration Venting) or NFPA 69 (Explosion Protection Systems). This is required as a mitigation against the build up of flammable gases if a thermal event was to occur and is required as part of compliance with NFPA 855.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>
<p><u>Gas Detection and Smoke Detection</u></p> <ul style="list-style-type: none"> <li>Install a very early warning fire detection system, such as aspirating smoke detection.</li> <li>Install carbon monoxide (CO) detection within the container or BESS room.</li> </ul>	<p>The Applicant will ensure that their chosen BESS OEM's equipment contains smoke detection, and a heat detector / CO detector, or at a minimum monitoring of BMS data to detect early warning signs of an impending issue. Any detection will include audible and visual alarms, plus alarms on the HMI interface / link to The Applicant's operations control room.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>
<p><u>Fire Protection and Water Supply</u></p> <ul style="list-style-type: none"> <li>Install sprinkler protection within BESS rooms and ideally within BESS containers. The sprinkler system should be designed to provide 12.2 l/min/m<sup>2</sup> over 232 m<sup>2</sup>. Water has been proven to be the best agent to fight a fire involving lithium-Ion batteries. It is important to note that other extinguishing agents, such as aerosols or gaseous extinguishing systems, will extinguish the fire, but they do not provide cooling like water. Insufficient cooling allows a hot and deep-seated core to remain. The heat will rapidly spread back through the battery and reignite remaining active sections. This is the primary reason ARC recommends the use of water for fighting the fire and cooling the batteries.</li> <li>Implement a procedure for battery submersion in the pre-emergency plan performed by the fire department. Submerging batteries in water (preferably outdoors) after they burn has proven to be effective at cooling the batteries and neutralizing the thermal threat. They will continue to release gases, mostly carbon monoxide, but also flammable gas such as hydrogen. Therefore, never submerge several batteries in a confined space without adequate ventilation.</li> <li>Ensure that sufficient water is available for manual firefighting. The ability of the fire department to control a fire involving a BESS depends on the presence of an adequate water supply and their knowledge of the hazards. The following should be considered:                             <ul style="list-style-type: none"> <li>An external fire hydrant should be located within 100 m (330 ft.) of the BESS room or containers.</li> </ul> </li> </ul>	<p>The Applicant will procure equipment with UL9540 certification (or IEC 62619) and a UL 9540A test report, this test report is evidence that will be submitted to the NFRS and/or LPA to demonstrate that the chosen BESS equipment will not propagate from module to module, unit to unit, or system to system depending upon the final level of testing performed.</p> <p>The Applicant will appoint an independent assessor to review the UL 9540A test report in accordance with NFPA 855 prior to submission to NFRS (this will be an independent consultant, with no prior knowledge of the project). The interpretation of the test report from the independent engineer will drive the final site design, with guidance from NFRS expected.</p> <p>The chosen BESS OEM's equipment will have evidence that for UL 9540A testing no fire propagation occurred at any level of the BESS unit. The chosen fire suppression system will prevent cell-to-cell propagation and may include water-based systems with the use of sprinklers, complete with available connections for the fire rescue service. If no suppression system is present in the units, alternative measures will be implemented to prevent fire or thermal events from spreading to adjacent equipment.</p> <p>The Applicant's firefighting strategy will include cooling nearby BESS enclosures using the available water supply on site.</p> <p>The Applicant has included water tanks that meet the minimum requirements of NFRS, NFPA 855 and ARC. The water supply will provide 1,900 litres per minutes (LPM) for at least 2 hours, The Applicant has made provision for two tanks, each containing 231 m<sup>3</sup> of firefighting water.</p>	<p>Partially Compliant                      (Full compliance upon completion of ERP, and selection of equipment supplier.)</p>

Allianz Risk Consulting Recommendation	Compliance Statement	Compliance
<ul style="list-style-type: none"> <li>○ The water supply should be able to provide a minimum of 1,900 l/min (500 gpm) for at least 2 hours.</li> </ul>	Due to the UL9540A testing, the BESS should remain in place until the thermal event has fully ended (decided by the BESS OEM emergency response room and NFRS).	
<p><u>Maintenance</u>                      Follow original equipment manufacturer recommendations for the inspection, testing and maintenance of BESS. In addition, ensure that the following are completed:</p> <ul style="list-style-type: none"> <li>● Measure the internal resistance of the cells. Replace the cells when a dramatic drop is detected. Keep in mind that the internal resistance is mainly independent of the state of charge but increases as the battery ages. Therefore, it is a good gauge of predictable life.</li> <li>● Perform infrared scanning at least once per year.</li> <li>● Check for fluid leakage.</li> <li>● Implement electric terminal torquing procedures to maintain connection and contact integrity.</li> </ul>	<p>The Applicant will appoint an O&amp;M contractor with specific BESS maintenance experience. The chosen contractor will retain responsibility for maintaining the BESS, and The Applicant will provide oversight along with the BESS OEM to ensure that all maintenance activities are completed as planned.</p> <p>Battery cells are continually monitored using the BMS, and anomalies, such as voltage drop or unbalanced charge are flagged using the SCADA to the operations control room operators.</p> <p>We do not expect cell replacement to occur unless this activity occurs under the BESS OEM's operations and maintenance teams.</p>	Partially Compliant (Full compliance upon selection of equipment supplier.)

**Table A5.4.7 – FM Global – Guideline 5-33 Electrical Energy Storage Systems**

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
2.2.1 – 2.2.3	<p><u>Energy Storage System (ESS) Selection</u></p> <p>2.2.1 Verify with the manufacturer or integrator that the LIB-ESS design, including cell type, battery management system (BMS), etc., is appropriate for the application.</p> <p>2.2.2 Establish a management of change procedure to ensure that batteries or BMS components are compatible with modified system requirements or that replacements are appropriate to the existing system requirements.</p> <p>2.2.3 Do not use refurbished or previously used ESS components, including cells or modules.</p>	<p>The BESS OEM will propose solutions based upon the requirements provided by The Applicant. The relevant contractors will conduct Grid studies to ensure suitability for the intended application.</p> <p>The O&amp;M contractor retains responsibility for spares management and record logs, all spare BESS components will be sourced directly from the BESS OEM as part of The Applicant's spares strategy.</p> <p>The BESS OEM will not re-use components, this will be explicitly stated within the technical specification.</p>	Partially Compliant (Full compliance upon selection of equipment supplier.)
2.3.1	<p><u>Location</u></p> <p>2.3.1.1 Locate energy storage systems in accordance with one of the following, listed in order of preference:</p> <p>A. In an enclosure outside and away from critical buildings or equipment in accordance with 2.3.2 (Figure 2.3.1, location 1)</p> <p>B. In a dedicated building containing only LIB-ESS and associated support equipment in accordance with 2.3.3 (Figure 2.3.1, location 2)</p> <p>C. In a dedicated exterior cut-off room that is accessible for manual firefighting operations and is constructed in accordance with 2.3.4 (Figure 2.3.1, location 3)</p> <p>D. In a dedicated interior corner cut-off room that is accessible for manual firefighting and is constructed in accordance with 2.3.4 (Figure 2.3.1, location 4)</p> <p>E. In a dedicated interior cut-off room that is accessible for manual firefighting and is constructed in accordance with 2.3.4 (Figure 2.3.1, location 5)</p>	<p>The BESS will be located outside and away from critical infrastructure in accordance with the first order of preference from clause 2.3.1.1.</p>	Compliant
2.3.2	<p><u>Outdoor LIB-ESS Enclosures and Containers</u></p> <p>2.3.2.1 Select or construct LIB-ESS enclosures/containers using only non-combustible materials. Separation distance is based on doors being located on only one side of the enclosure and no vents or unprotected openings on any other sides. It is also based on active systems (HVAC or liquid cooling) maintaining cell or module temperatures in the target enclosure or container.</p> <p>2.3.2.2 For containerized LIB-ESS comprised of lithium iron phosphate (LFP) cells, provide aisle separation of at least 5 ft (1.5 m) on sides that contain access panels, doors or deflagration vents.</p> <p>2.3.2.4 Provide separation between solid walls having no openings based on installation-level testing that demonstrates thermal runaway cannot propagate between containers. Where a fire test report is not available or the test did not result in a fire in the unit of origin, provide separation as indicated in Sections 2.3.2.2 or 2.3.2.3 as appropriate.</p>	<p>The BESS will be located outside and away from critical infrastructure in accordance with the first order of preference from clause 2.3.2.1 opposite.</p> <p>The BESS enclosures will be manufactured using non-combustible materials as per the project requirements. The minimum distance of 1.5 m required for containerized LIB-ESS comprised of LFP cells is surpassed in all conceptual site layout schematics. The project requires a minimum separation distance of at least 3 m in compliance with 2.3.2.2, 2.3.2.4 and 2.3.2.5.</p>	Compliant

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	<p>2.3.2.4.1 If any penetrations are present, the separation should be extended, or the penetrations should be protected or equipped with FM Approved fire-safe wall penetrations.</p> <p>2.3.2.4.2 Where explosion vents or other penetrations are provided, ensure they are arranged and directed away from surrounding equipment and buildings.</p> <p>In a fire, these enclosures may have vents or penetrations that could allow hot gas and products of combustion to escape the enclosure, causing an exposure to adjacent equipment or buildings. Penetrations could include electrical conduit, doors, HVAC units, etc.</p> <p>2.3.2.5 Provide a minimum space separation between LIB-ESS enclosures and adjacent buildings or critical site utilities or equipment in accordance with Data Sheet 1-20, Protection Against Exterior Fire Exposure, using hazard category 3 for the exposing building occupancy.</p>		
2.3.3	<p>Dedicated ESS Building or Enclosure Larger Than 46.5 m<sup>2</sup></p> <p>Treat any prefabricated container or enclosure that is larger than 46.5 m<sup>2</sup> as a building.</p>	<p>Not applicable. The BESS Enclosures shall not exceed 16.2 m x 2.6 m (42.12 m<sup>2</sup>) to comply with NFPA 855 requirements for Outdoor BESS enclosures or cabinets.</p>	Compliant
2.3.4	<p><u>ESS Cut-off Rooms</u></p> <p>2.3.4.1 For multiple racks installed in a single row or back-to-back, install solid, non-combustible fire barriers between adjacent racks.</p> <p>2.3.4.2 Provide a minimum 1-hour fire-rated room, floors, walls, and ceiling in accordance with Data Sheet 1-21.</p> <p>A. Provide FM Approved fire doors with the same room rating.</p> <p>B. Provide FM Approved fire barriers for all floor, ceiling, and wall penetrations.</p> <p>2.3.4.3 Install ESS with minimum separation in accordance with 2.3.5.</p> <p>2.3.4.4 Provide mechanical ventilation in an ESS cut-off room at a rate of at least 1 cfm/ft<sup>2</sup> (0.3 m<sup>3</sup>/min/m<sup>2</sup>) of floor area. (See 2.5.5)</p> <p>2.3.4.5 Provide damage-limiting construction.</p> <p>2.3.4.5.1 Design DLC in accordance with Data Sheet 1-44, Damage-Limiting Construction, using propane as the representative gas.</p>	<p>There are no ESS cut-off rooms as the BESS containers are located outside.</p>	Compliant
2.3.5	<p><u>Separation Distances for Indoor LIB-ESS Racks</u></p> <p>2.3.5.1 Provide 6 ft (1.8 m) minimum separation from the accessible face of an LIB-ESS rack to non-combustible materials, non-combustible construction elements, and the accessible faces of adjacent LIB-ESS racks.</p> <p>The accessible face is the side that has a door, vent or can be opened, allowing fire to escape the rack of origin.</p> <p>2.3.5.2 Provide 9 ft (2.7 m) minimum separation from the accessible faces of LIB-ESS racks to combustibles and combustible construction elements.</p>	<p>The BESS facility design will follow regulations and NFPA 855 as highlighted by the NFRS.</p> <p>The project requires a minimum separation distance of at least 3 m between the accessible face of the enclosures and testing as per UL 9540A up to the installation level.</p> <p>The Applicant will include UL 9540A compliance as part of the tendering exercise, and this will drive final grouping and separation distances from enclosure to enclosure, and from each enclosure to exposures.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier.)</p>

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	<p>2.3.5.3 Separation between non-accessible sides of adjacent racks should be determined by an installation-level fire test demonstrating that thermal runaway cannot propagate between racks. Where a test report is not available or the test did not result in a fire in the rack of origin, assume thermal runaway will propagate between racks. See Section 2.4 for expected fire duration.</p>	<p>The Applicant will submit the UL 9540A test report from the BESS OEMs for sign-off by the NFRS prior to construction commencing. This will also be agreed with the insurer of the BESS prior to proceeding with the application.</p> <p>The BESS enclosures shall be tested to UL 9540.</p> <p>Pending acceptance of the UL 9540A test report by the LPA / NFRS, The Applicant has allowed for a spacing of 3.0 m between BESS enclosures on all sides.</p>	
2.4	<p><u>Protection</u></p> <p>2.4.1 Provide automatic sprinkler protection designed to a 0.3 gpm/ft<sup>2</sup> (12 mm/min) over the room area, with an additional allowance of 250 gal/min (946 L/min) for hose streams. 2.4.2 Ensure the water supply is capable of providing sprinkler water and hose stream requirements for the duration of the fire event (see Section 3.2). The expected duration will depend on the number of racks in a single fire area. The fire area is comprised of a row or rows of racks where minimum separation is not provided in accordance with 2.3.5. The duration should be estimated as 45 minutes times the number of adjacent LIB-ESS racks.</p> <p>The room design should address drainage or other mitigation of the water release. See Data Sheet 1-24, Protection Against Liquid Damage, for more information.</p> <p>2.4.2.1 Where the sprinkler demand requires a water supply duration greater than what is available, provide the following:</p> <p>A. Install noncombustible floor-to-ceiling partitions with penetrations protected by FM Approved fire stops between adjacent racks perpendicular to the rack door or opening to prevent fire spread. Ensure the partitions extend at least 12 in. (0.3 m) from the face of the rack. See Figure 2.4.2.1. Determine the horizontal distance between thermal barriers based on how many racks can be protected by the available water supply.</p> <p>B. Install a solid metal partition on the back (non-aisle) of each rack to prevent heat transfer to adjacent racks in the next row. Where the rack design incorporates a solid metal back (no ventilation openings), additional partitions are not needed. (See Figure 2.4.2.1.)</p> <p>2.4.3 Provide a smoke detection system within the enclosure, cut-off room, or ESS area designed and installed in accordance with Data Sheet 5-48, Automatic Fire Detection.</p>	<p>The Applicant will procure equipment with a UL 9540A test report, this test report is evidence that will be submitted to the NFRS and/or LPA to demonstrate that the chosen BESS equipment will not propagate from module to module, unit to unit, or system to system depending upon the level of testing performed.</p> <p>The Applicant will appoint an independent assessor to review the UL 9540A test report in accordance with NFPA 855 prior to submission to NFRS (this will be an independent consultant, with no prior knowledge of the project). The interpretation of the test report from the independent engineer will drive the final site design, with guidance from NFRS.</p> <p>The chosen BESS OEM's equipment will have evidence that for UL 9540A testing no fire propagation occurred at any level of the BESS unit. The chosen fire suppression system will prevent cell-to-cell propagation and may include water-based systems with the use of sprinklers, complete with available connections for the fire and rescue service. If no suppression system is present in the units, alternative measures will be implemented to prevent fire or thermal events from spreading to adjacent equipment.</p> <p>The Applicant's firefighting strategy will include cooling nearby BESS enclosures using the available water supply on site.</p> <p>The Applicant has included water tanks that meet the minimum requirements of NFRS, NFPA 855 and ARC. The water supply will provide 1,900 litres per minutes (LPM) for at least 2 hours, The Applicant have made provision for two tanks, each containing 231m<sup>3</sup> of firefighting water.</p>	Partially Compliant (Full compliance upon selection of equipment supplier.)
2.5.1	<p><u>Equipment and Processes</u></p> <p>2.5.1 Electrical System Protection</p> <p>2.5.1.1 Perform a system short circuit and protection coordination study to ensure the adequacy of rating and relay settings for existing circuit breakers when the electrical energy storage system adds power to the existing electrical system at a facility. For additional information on short circuit and protection coordination, see Data Sheet 5-20, Electrical Testing.</p>	<p>The BESS OEM will be requested to provide short circuit studies in accordance with the technical specification.</p> <p>The BoP Contractor will retain responsibility for all electrical plant studies in accordance with the technical specification.</p>	Partially Compliant (Full compliance upon selection of equipment supplier and provision of studies.)

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
2.5.2	<p><u>Equipment Protection</u></p> <p>2.5.2.1 Provide a disconnect device for maintenance needs or abnormal events for each rack.</p> <p>2.5.2.2 Provide a method of manual, remote, and local disconnect for the LIB-ESS. A remote disconnect should be in an accessible area that is monitored 24/7. A local disconnect should be provided adjacent to the ESS space.</p> <p>2.5.2.3 Provide temperature monitoring with high alarm for LIB-ESS room, building, or enclosure. Have alarms routed to a continuously attended location or specific operations personnel.</p>	<p>Each BESS rack / cabinet shall be procured with an independent method of isolation as described within the technical specification. Local disconnects for each BESS container are likely to be included within the BESS container and Inverter/Transformer skids, this will be fully defined when supplier selection has been concluded.</p> <p>Ambient temperature within each BESS is recorded and alarms are programmed to the SCADA.</p>	Partially Compliant (Full compliance upon selection of equipment supplier)
2.5.2.4	<p><u>LIB-ESS Rack</u></p> <p>2.5.2.4.1 Provide DC ground fault protection for grounded battery systems. For ungrounded battery systems, provide DC ground fault monitoring with alarming function. Have the alarm routed to a constantly attended location or specific operations personnel.</p> <p>2.5.2.4.2 Provide overcurrent protection against overload and short-circuit faults.</p> <p>2.5.2.4.3 Provide overvoltage and under-voltage protection against overcharging and over-discharging.</p>	<p>DC Ground Fault Protection will be provided by the BESS OEM, this will be confirmed in the technical specification for the BESS equipment. An insulation monitoring device (IMD / active device) will be provided to maintain insulation monitoring against ground. The IMD is often integrated into the PCS, however insulation faults and warnings need to be integrated into the inter-tripping of the BESS.</p> <p>Overcurrent protection will be included within the BESS design and is monitored by the BMS, this will be stated within the technical specification for the BESS equipment.</p> <p>OVP and UVP will be included within the BESS design and is monitored by the BMS, this will be confirmed in the technical specification for the BESS equipment.</p>	Partially Compliant (Full compliance upon selection of equipment supplier)
2.5.3	<p><u>Battery Management System Safety Functions</u></p> <p>2.5.3.1 Provide battery management systems with the following safety functions:</p> <p>A. High cell temperature trip (cell level): This function isolates the module or battery rack when detecting cell temperatures that exceed limits. A common design is to have modules hard-wired in series within a rack. Therefore, the smallest unit that can be isolated is generally the rack. Where a design accommodates it, isolating a module is acceptable.</p> <p>B. Thermal runaway trip (cell level): This function trips the entire system when a cell is detected to have entered a thermal runaway condition. In scenarios involving a thermal runaway, this function is the first to activate when thermal runaway conditions are detected.</p> <p>C. Rack switch fail-to-trip (rack level): This function identifies any failure from the pack switch to trip once a trip command is initiated. The rack switch is also known as the “pack switch.” It is a switch that disconnects a single rack in response to an abnormal condition. The rack switch is shown separately from the “master” level in Figure 2.5.3.1 for clarity. It is generally incorporated into the BMS.</p> <p>D. Inverter/charger fail-to-trip (supervisor level): This function initiates a trip command to an upstream breaker to isolate the ESS if the</p>	<p>The technical specification for the BMS shall state that the BMS monitors the condition of cells and racks and the interactions between racks. This functionality shall include but not be limited to monitoring the voltage, currents and temperature and balance of the State of Charge (SoC) of the aggregated cells, device feedback and sensor validity and ensuring the battery system and individual cells are operating within their operating range.</p> <p>The BMS shall generate alarms via the central SCADA (Supervisory Control and Data Acquisition) platform EMS (Energy Management System) if any of the monitored parameters exceed the limits set by the system manufacturer and shall take the necessary action to prevent damage to the Goods by operating the relevant hardware protection systems. Any failure of the BMS or the monitoring devices shall provide an alarm and, depending on the severity of the failure, initiate a controlled shutdown sequence for part or all of the battery system.</p>	Partially Compliant (Full compliance upon selection of equipment supplier)

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	inverter/charger fails to respond to a trip command. The “supervisor” control system controls the entire system, including the combination of racks, the environmental support systems, and the charging/discharging status. The supervisor level should isolate the LIB-ESS if the inverter/charger fails to trip on an appropriate signal, or if communication is disrupted between the inverter/charger and the supervisor control.		
2.5.3.2	<p><u>Online Condition Monitoring</u></p> <p>2.5.3.2.1 Provide online condition monitoring systems that will monitor battery room temperature and the following parameters, at a minimum, at the battery module and/or cell level:</p> <ul style="list-style-type: none"> <li>• Charging and discharging voltage and current</li> <li>• Temperature</li> <li>• Internal ohmic (resistance)</li> <li>• Capacity</li> <li>• State of charge (SoC)</li> <li>• State of health (SoH)</li> <li>• Alarm or fault log</li> </ul> <p>2.5.3.2.2 Provide online condition monitoring systems with the following features:</p> <p>A. The ability to transmit data to a constantly attended location or specific operations personnel</p> <p>B. The ability to generate alarms when unusual conditions are detected</p> <p>C. The ability to analyse monitored parameters and generate a summary of the condition of the battery</p> <p>D. Security to prevent unauthorized changes of critical parameter limits, such as voltage, temperature, and current, which are essential to maintain reliable lithium-ion battery operation.</p> <p>E. Self-diagnostic capability</p>	<p>The technical specification for the BMS shall state that the BMS will transmit all of the required data to the SCADA and finally to the operations control room and to a remote server. These will be available via a historian which will record the plant data for a minimum period of time (usually 12 months or more).</p> <p>Alarms shall be integrated into the central SCADA EMS. The alarms shall be interfaced to allow transmission and management of each alarm state to the operations control room. Alarms and events shall be accurately time-stamped. The alarms shall be capable of acceptance and resetting from the operations control room and local site. Alarm levels shall be appropriate for the manning levels of the Company’s control centre. All alarm initiating contacts shall be ‘not fail to danger’ in accordance with normal control and instrumentation practice. In general, the alarm initiating contact shall open to alarm, i.e., normally closed contacts.</p>	Partially Compliant (Full compliance upon selection of equipment supplier)
2.5.3.3	<p><u>Early Intervention Thermal Runaway Prevention</u></p> <p>2.5.3.3.1 Incorporate an early intervention system to automatically and electrically isolate the LIB-ESS, using one of the following approaches:</p> <p>1. High cell temperature: The cell manufacturer should provide the threshold temperature indicating an abuse condition based on 100% SOC. The majority of cells within a module should be constantly monitored.</p> <p>2. Off-gas detection: Provide gas detectors capable of detecting the volatile organic compounds associated with the off-gas event that precedes thermal runaway.</p>	<p>The project requires a BMS that can monitor and control cell temperature measurement and signalling, alarm generation in response to temperature anomalies and automatic shutdown protection systems.</p> <p>The battery protection system together with the BMS will be capable of automatic early detection and electrical isolation of a thermal runaway event via constant monitoring of the cells’ temperature or by off-gas detectors capable of identifying the volatile organic compounds that commonly precede thermal runaway.</p>	Partially Compliant (Full compliance upon selection of equipment supplier)

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
2.5.4	<p><u>Power Conversion Equipment</u></p> <p>2.5.4.1 Provide overcurrent protection against overload and short-circuit faults on the AC side.</p> <p>2.5.4.2 Provide surge arrestors on the AC side for voltage transient “voltage spike” protection. For additional information on voltage transient protection, see Data Sheet 5-11.</p> <p>2.5.4.3 Provide transformer electrical protection in accordance with Data Sheet 5-4, Transformers or 5- 20, Electrical Testing, as applicable.</p>	<p>The technical specification for the BESS shall include:</p> <ol style="list-style-type: none"> <li>1. Overprotection against overload and short-circuit faults on the AC Side.</li> <li>2. Surge arrestors or protection on the AC side.</li> <li>3. Transformer electrical protection.</li> </ol>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>
2.5.5	<p><u>Air Circulation/Mechanical Ventilation</u></p> <p>2.5.5.1 Locate the circulation/ventilation system to take suction at or near the ceiling.</p> <p>2.5.5.2 Install an FM Approved hydrogen detector that will alarm if the level of hydrogen exceeds 10% LEL, electrically isolate the LIB-ESS, and initiate emergency exhaust ventilation in accordance with Section 2.5.5.3.</p> <p>2.5.5.3 Install an emergency exhaust ventilation system that will increase the ventilation rate to 2.5 cfm/ft2 (0.75 m3/min/ m2) of floor area if hydrogen is detected at 10% of the LEL, and exhaust all air directly to outdoors.</p> <p>2.5.5.3.1 Route the emergency exhaust ventilation system through a system of blowers, fans, and ductwork terminating outdoors away from air inlets, doorways, and other openings.</p> <p>2.5.5.3.2 Construct ductwork of non-combustible materials.</p> <p>2.5.5.3.3 Provide make-up air inlets in exterior walls, in a remote location from exhaust outlets to prevent entrainment of exhaust gases.</p> <p>2.5.5.4 Arrange the circulation/ventilation system controls to alarm to a constantly-attended location or to specific operations personnel.</p>	<p>The technical specification for the BESS units shall state that to prevent explosions caused by off-gassing, particularly hydrogen accumulation, due to inadequate air circulation in the battery containers, hydrogen detectors shall be installed to alarm at 10% Lower Explosive Limit (LEL) in the battery containers. A forced circulation/ventilation system will be provided to vent off-gases to safe levels and activate emergency exhaust ventilation at a maximum of 25% LEL to rapidly exhaust air directly outdoors. The system's design will incorporate non-combustible ductwork, carefully routed to prevent water ingress and explosive gas leakage to other areas of the container and will include alarm notifications to a constantly attended location. This system will be integrated into the site's emergency response plan (ERP) and will have a clear marking of the ventilation system's disconnect switch to ensure emergency responders do not inadvertently disconnect the power supply during an incident.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>
2.6.1	<p><u>Operation</u></p> <p>2.6.1.1 Install, operate, and maintain batteries and battery management systems in accordance with manufacturer's recommendations.</p> <p>2.6.1.2 As part of commissioning, verify proper operation of all monitoring and protective devices.</p> <p>A. Inspect the battery system thoroughly for indication of overheating, abnormal vibration, abnormal noise, or malfunction. This should occur daily for a minimum of one week of normal operation.</p> <p>B. Perform infrared scanning and check battery operating and monitoring parameters to determine if any damage was sustained in shipping and installation.</p>	<p>All manufacturers' recommendations shall be followed, commissioning of the BESS modules will be completed by the BESS OEM's expert engineers. On-site resources will be used throughout the commissioning phase for monitoring.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier, and review of recommendations)</p>
2.6.2	<p><u>Equipment Maintenance</u></p> <p>2.6.2.1.1 Perform electrical system inspection, testing and maintenance of LIB-ESS systems in accordance with Data Sheet 5-20, Electrical Testing. Establish and implement a LIB-ESS system</p>	<p>Maintenance will be performed in accordance with the BESS OEM's recommendations. The BESS OEM's recommendations will be checked against Data Sheet 5-20, and an agreed scope will be developed with the BESS OEM.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier, and review of maintenance recommendations)</p>

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	inspection, testing, and maintenance program. See Data Sheet 9-0, Asset Integrity, for guidance on developing an asset integrity program		
2.6.2.2	<p><b>Battery Management System</b></p> <p>2.6.2.2.1 The inspection, testing, and maintenance program for the BMS should include at least the following:</p> <p>A. Periodic system self-test to ensure all critical systems are available and operational.</p> <p>B. Periodic pack switch maintenance. This may involve cycling the switch to ensure mechanical integrity and tightness of cable connections by torquing to specifications.</p> <p>C. HVAC maintenance. This may include change of air filters at periodic intervals. These intervals may vary depending on the location of the site. Dusty locations may require more frequent air filter replacement. Other HVAC maintenance items may include coolant check, compressor/heater core check and duct/cable check.</p> <p>D. Periodic check of spare battery modules to ensure they are maintained in charged state.</p> <p>E. Periodic tracking of state-of-health (SOH) values, which is the percent of remaining capacity (based on design capacity) in the battery packs.</p> <p>2.6.2.3 Establish a battery replacement program for aged batteries. Review the battery replacement program regularly and include, at a minimum, the following components:</p> <p>A. The OEM design life expectancy of the LIB-ESS batteries. This will be a number in years that the system is expected to perform adequately. After this point, the batteries should be replaced. This establishes the replacement timeline.</p> <p>B. Regular monitoring of the LIB-ESS SOH, which is the percent of remaining capacity based on design capacity. This information should be available through the BMS, which continuously tracks SOH. Unexpected component malfunctions or failures and operating outside design parameters can age batteries faster than when operating within design limits. The BMS will be able to monitor these unexpected issues and adjust the SOH of the system.</p> <p>C. Regular review of the replacement program, ensuring there is a method of adjusting the replacement timeline. The plan should allow for adjusting the replacement timeline if feedback from the BMS shows the SOH indicates accelerated ageing. The following factors justify earlier replacement:</p> <ol style="list-style-type: none"> <li>1. Significant changes or trends in the condition monitoring data that indicate development problems with the battery system</li> <li>2. Advice from the OEM on design problems that require replacement</li> </ol>	<p>All maintenance procedures and schedules will be created by the BESS OEM and will be regularly updated as requested by the BESS OEM.</p> <p>The Applicant intends to appoint a specialist O&amp;M contractor to monitor and maintain the BESS, transformer, UPS and other related systems performance. The Applicant will endeavour to ensure that the BMS maintenance schedule indicated opposite has been included with any planned maintenance regime including augmentation of battery modules / enclosures if required.</p> <p>Spare battery modules will be periodically checked in accordance with the BESS OEM's guidance, this is not performed by the BMS, but by the O&amp;M contractor manually.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier, and review of recommendations)</p>

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	3. Operating experience and failure history that indicates the battery should be replaced 4. Exposure to severe operating conditions D. A method of managing changes. This should consider major changes that affect the life expectancy and replacement timeline of the LIB-ESS. Changes could include replacement of the BMS, modifying the thermal management system, and changes in application or operational modes (e.g., modifying the BMS to operate based on an arbitrage mode vs. electric supply capacity).		
2.7	<u>Training</u> 2.7.1 Have operations personnel trained by the supplier/manufacturer of the ESS equipment. 2.7.2 Provide other training in accordance with Data Sheet 10-8, Operators.	The Applicant will include specialised training on the specific equipment deployed at the site as part of the technical specification for the O&M contractor from the BoP contractor. The successful BESS OEM will be expected to produce specific training for personnel who will frequently attend the facility from the O&M contractor.	Partially Compliant (Full compliance upon provision of training)
2.8	<u>Human Factors</u> 2.8.1 Housekeeping 2.8.1.1 Do not store combustible material in LIB-ESS enclosures, buildings, or cut-off rooms.	The Applicant will have allocated dedicated storage for spare equipment and materials on-site, this will be defined within the technical specification.	Partially Compliant (Full compliance upon selection of equipment supplier, and review of recommendations)
2.8.2	<u>Emergency Response and Pre-Incident Planning</u> 2.8.2.1 Develop an emergency response plan to address the potential fire hazards associated with energy storage systems. Refer to Data Sheet 10-1, Pre-Incident Planning, for general guidelines on establishing and maintaining an emergency response plan. 2.8.2.2 Develop a pre-incident plan with the fire service in accordance with Data Sheet 10-1, Pre- Incident Planning. Arrange and prepare the plan with documented procedures to expedite safe entry and emergency response to fires in the LIB-ESS area, including the following: <ul style="list-style-type: none"> <li>• Manual disconnection</li> <li>• Access routes</li> <li>• Manual fire protection methods</li> <li>• Manual smoke ventilation (if provided)</li> <li>• SDS for battery cells</li> </ul> 2.8.2.3 Develop a post-incident recovery plan that addresses the potential for reignition of LIB-ESS, as well as removal and disposal of damaged equipment. 2.8.2.3.1 A fire watch should be present until all potentially damaged ESS equipment containing Li-ion batteries is removed from the area following a fire event. The water supply should be replenished as quickly as feasible.	The Applicant will develop the ERP prior to energisation of the site, the ERP will be created in consultation with the NFRS. The Applicant will incorporate instructions from the BESS manufacturer for safety procedures on site.	Partially Compliant (Full compliance upon completion of ERP)

Ref.	FM Global Guideline Statement	Compliance Statement	Compliance
	<p>Fires involving Li-ion batteries are known to reignite. Li-ion batteries involved in or exposed to fires should be adequately cooled to prevent reignition.</p> <p>2.8.2.3.2 Identify the equipment needed to safely remove and replace damaged equipment and the supporting infrastructure to facilitate prompt removal. The plan should include service or equipment providers needed for recovery infrastructure. The OEM or integrator should provide guidance on decommissioning, removal of damaged equipment, and proper disposal in accordance with local regulations.</p>		
2.9	<p><u>Utilities</u></p> <p>2.9.1 In extreme environments, provide an emergency power supply to the HVAC systems. An extreme environment mentioned here is one that could allow cell-level temperatures to rise or fall outside the maximum operating temperature range of -4.0° F (-20° C) to 120° F (50° C) despite BMS control. 2.9.2 Ensure LIB-ESS enclosures with common HVAC components, such as a common condensing unit (cooling tower), are designed to shut down the LIB-ESS in the event of a component failure.</p>	<p>The site is located within an area of the UK that has a reliable temperature profile typically below the ambient temperature required within the BESS containers.</p> <p>Where auxiliary power is lost, the BESS will immediately stop exporting or importing power and allow the batteries to cool to the local ambient temperature as this is typically below the operating temperature range of the BESS.</p> <p>The Applicant will make provision for a UPS within the auxiliary circuit to provide short-term temporary power for monitoring purposes.</p> <p>Where the cooling system experiences a fault and can no-longer cool the battery containers, this will result in an automatic isolation of the affected container.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier)</p>

**Table A5.4.8 – EASE – BESS Safety Best Practices Guideline**

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
2.1	<p><u>Product safety - Preventive Measures: Battery Design (cell/module/pack/rack)</u></p> <p>To ensure a consistent minimum level of safety for Battery Energy Storage Systems (BESS) worldwide and to reduce the compliance burden on stakeholders, it is recommended that international harmonisation of standards be pursued. Establishing unified global standards will facilitate the adoption of best safety practices across all regions, enhancing safety and streamlining regulatory compliance.</p> <p>Although not mandatory, consideration should be given to revising the sample size for thermal propagation type tests. Although current standards typically require testing a single sample, increasing the sample size to 3 could provide more reliable data, accounting for the inherent variability in thermal runaway outcomes even under identical test conditions. This larger sample size would lead to more robust safety assessments.</p>	<p>The Applicant will procure equipment certified to UL 9540, UL 1973, IEC 62619, and IEC 63056, and tested as per UL 9540A, aligning with the latest safety standards to align with the latest international best practices and promote global harmonisation. The technical specification will mandate advanced safety features, including thermal barriers, active cooling systems, and fire-resistant materials, to prevent thermal runaway and ensure operational reliability. Thermal propagation tests will be performed as required by the latest edition of NFPA 855 and as per the UL 9540A test method.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier.)</p>
2.2	<p><u>Product safety - Preventive Measures: Battery Management System (BMS)</u></p> <p>To enhance BMS safety, the following should be considered when sufficient level of technology development is reached:</p> <ul style="list-style-type: none"> <li>• Incorporating advanced diagnostic and predictive maintenance tools within the BMS.</li> <li>• Ensuring seamless compatibility between the BMS and other system components.</li> <li>• Enhance the scope of BMS testing to include large-scale operational scenarios, ensuring real-world applicability and reliability.</li> <li>• Enhance the safety design of BMS to avoid fire caused by short circuit of the BMS itself.</li> <li>• BMS should be functional, backed up by an UPS so that data can be monitored and used to assess the severity and development of the fault. This can give input on how to safely react to the incident.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The chosen BESS equipment will be compliant with IEC 62619, UL 1973, and IEC 62933-5-2. Additionally, the technical specification for the BMS shall state that the BMS shall proactively monitor and manage system health, seamlessly integrate with all components, and ensure operational reliability. It will include safeguards to prevent fire hazards from internal faults and be supported by a UPS to maintain data monitoring during incidents, enabling effective response and mitigation.</p> <p>Further, the BMS shall continuously monitor cell and rack conditions, including voltage, current, temperature, and SoC balance, triggering alarms via the SCADA EMS for unwanted behaviours and activating protection systems or controlled shutdowns as needed. The BMS shall also detect, isolate and report thermal runaway events early through temperature monitoring or off-gas detection.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier.)</p>
2.3	<p><u>Product safety - Preventive Measures: Thermal Management System</u></p> <p>To improve thermal management safety, it is recommended to:</p> <ul style="list-style-type: none"> <li>• Ensure cooling systems are designed for optimal performance under critical conditions without relying on uninterruptible power supplies (UPS), as their high-power demand (30kW–60kW) makes continuous operation impractical. Additionally, running liquid cooling systems during failure scenarios may increase risks if leaks occur.</li> <li>• Ensure leakage alarms or warnings from the Thermal Management System are communicated to the BMS without fully integrating</li> </ul>	<p>The Applicant will ensure that their chosen BESS OEM equipment complies with the latest editions of UL 1973 and UL 9540. Furthermore, the technical specification for the BESS shall specify a thermal management system that ensures optimal performance under critical conditions, with safeguards to prevent thermal runaway and ensure operational reliability.</p> <p>The specification shall also require leakage warning capabilities and containment measures for refrigerant-based cooling systems.</p>	<p>Partially Compliant                      (Full compliance upon selection of equipment supplier.)</p>

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	control functions into it, as the BMS already manages multiple critical battery operations. <ul style="list-style-type: none"> <li>Conduct comprehensive risk assessments for cooling systems and validate them through recognised certification processes.</li> </ul>		
2.4	<u>Product safety - Preventive Measures: BESS Enclosure Design</u> To ensure a reliable BESS enclosure design, the following should be considered: <ul style="list-style-type: none"> <li>Conduct site-specific risk analyses for environmental and operational factors.</li> <li>Use enclosures rated IP54 or higher for outdoor installations.</li> <li>Tailor fire resistance rating to the installation and design, to achieve the desired mitigation                             <ul style="list-style-type: none"> <li>Perform real-world fire testing under thermal and mechanical stresses.</li> </ul> </li> <li>Perform environmental durability tests, such as accelerated ageing. Enclosures should retain their protective features throughout the BESS's operational lifespan of 15–25 years. Factors such as corrosion resistance for metallic enclosures and UV stability for non-metallic materials must be addressed.</li> <li>Establish maintenance protocols, including regular inspections and coating reapplications.</li> <li>Verify manufacturing quality and installation to ensure proper sealing and alignment of openings.</li> </ul>	The Applicant will ensure that their chosen BESS OEM's utilise equipment enclosures that ensure reliable and safe operation. The BESS shall comply with the latest editions of IEC 62619, IEC 62933-5-2, UL 1973, UL 9540, NFPA 70, and NFPA 855. Additionally, compliance with IEC 60529, with a minimum rating of IP54 for enclosures, shall be required.  The Applicant will ensure that their chosen BESS OEM's equipment has fire resistance ratings tailored to the installation and design, resulting from UL 9540A testing and other relevant tests. Furthermore, the technical specification will require that the enclosure design shall address factors such as corrosion resistance and UV stability and shall include prescribed maintenance protocols to ensure the enclosure retains its protective features throughout the BESS's operational lifespan.  The Applicant will engage with the Nottinghamshire Fire and Rescue Service, independent technical advisors, OEMs and EPC Contractor to create site-specific risk analyses and hazard identification.	Partially Compliant (Full compliance upon selection of equipment supplier.)
2.5	<u>Product safety - Preventive Measures: Hazard mitigation analysis</u> A specific and iterative Hazard Mitigation Analysis (HMA) should be conducted for each project and product in accordance with IEC 62933-5. This analysis must consider the safety of the Battery Energy Storage System (BESS) throughout its entire lifecycle. Alternatively, the HMA methodology outlined in NFPA 855 can be used, as it eliminates the need for Original Equipment Manufacturers (OEMs) to comply with two different standards. Regardless of the chosen approach, the HMA conducted for a BESS project must comprehensively address all hazards identified by the applicable regulations and cover the environmental impact assessment requirements set by the authorities having jurisdiction.	The Applicant will engage with the Nottinghamshire Fire and Rescue Service, independent technical advisors, OEMs and EPC Contractor to create a comprehensive Hazard Mitigation Analysis (HMA) to be conducted following the latest editions of NFPA 855 or IEC 62933-5-2/1. The HMA shall consider the safety of the BESS throughout its entire lifecycle, addressing all identified hazards and meeting environmental impact requirements. The analysis shall be specific to the project and product.	Partially Compliant (Full compliance upon selection of equipment supplier.)
2.6	<u>Product safety - Containment Measures: Fire detection and alarm</u> To enhance fire safety, the following measures should be considered: <ul style="list-style-type: none"> <li>Install an automatic fire detection system with audible and visible alarms across the site.</li> <li>Network in-unit fire panels for centralised monitoring. If absent, use external detection based on manufacturer or site design.</li> </ul>	This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.  The Applicant will ensure that their chosen BESS OEM equipment features an automatic fire detection system in compliance with the latest editions of IEC 62933-5-2, EN 54, NFPA 855, UL 9540, and EC 60079. The system shall incorporate robust detection capabilities to provide early warnings of potential hazards, with audible and visible	Partially Compliant (Full compliance upon selection of equipment supplier.)

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	<ul style="list-style-type: none"> <li>• Integrate fire detection with the Battery Management System (BMS) or other manufacturer-provided interfaces for real-time risk monitoring.</li> <li>• Place annunciator panels at site entrances for quick emergency access.</li> <li>• Re-commission the facility only after confirming all risks are mitigated and safety conditions restored.</li> <li>• Regularly review detection systems, as they are rarely activated.</li> <li>• Incorporate gas detection (e.g., H<sub>2</sub> sensors) to detect hazards before ignition.</li> </ul> <p>Advanced options include pressure sensors in cells to identify swelling before thermal runaway. Where feasible, use gas, smoke, or infrared (IR) heat detection to provide early warnings before fire develops. short circuit) before smoke even occurs (as heat precedes smoke in a thermal event).</p>	<p>alarms, networked for centralised monitoring and integrated with the BMS for real-time risk monitoring.</p> <p>Furthermore, the BESS facility specification shall require the prominent display of clear and legible safety information at site entrances. The O&amp;M requirements will also include provision for regular reviews of the detection system.</p>	
2.7	<p><u>Product safety - Containment Measures: F-Stop mechanism and other shut-down mechanisms</u></p> <p>To enhance the effectiveness of F-Stop mechanisms, the following should be considered:</p> <ul style="list-style-type: none"> <li>• Design F-Stop systems to disconnect non-critical components during fire or explosion scenarios while preserving the operational functionality of the BMS and firefighting or explosion prevention systems. However, in current designs, the cooling system shuts down when F-Stop is triggered, so its continued operation may not always be feasible.</li> <li>• Facilitate effective communication between F-Stop mechanisms and the BMS without direct integration, as F-Stop is not currently controlled by the BMS. Instead, the BMS may disconnect certain racks in response to alarms.</li> <li>• Conduct rigorous testing to validate F-Stop performance across multiple fault conditions, including thermal events and electrical failures.</li> <li>• Address F-Stop reliability through functional safety assessments (e.g., FMEA, HARA). Compliance with UL 9540 (Class B or SIL2) or IEC 61508 SIL 2, where applicable, should be considered sufficient to determine the need for redundancy. If required, incorporate redundancy to eliminate single points of failure and enhance system reliability during emergencies.</li> </ul>	<p>The BESS technical specification will require the implementation of a reliable F-Stop mechanism, designed to disconnect non-critical components during fire or explosion scenarios while maintaining the operational functionality of the BMS and firefighting or explosion prevention systems.</p> <p>The Applicant will ensure that their chosen BESS features an F-Stop mechanism designed to facilitate effective communication with the BMS. The F-Stop mechanism shall be tested to validate its performance across multiple fault conditions. The specification shall also require functional safety and risk assessments to address F-Stop reliability and shall consider compliance with UL 9540 (Class B or SIL2) or IEC 61508 SIL 2 aiming at determining the need for redundancy to eliminate single points of failure.</p>	Partially Compliant (Full compliance upon selection of equipment supplier.)
2.8	<p><u>Product safety - Containment Measures: Explosion control</u></p> <p>To ensure effective explosion hazard mitigation, all internationally recognised fire safety approaches should be permitted, including explosion prevention systems, explosion protection systems, and engineered explosion control systems. The regulatory framework should remain technology-neutral, allowing both passive and active</p>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The Applicant will procure equipment compliant with NFPA 855, certified to UL 9540, and tested in accordance with UL 9540A. Furthermore, the BESS technical specification shall mandate compliance with at least one of NFPA 68 or NFPA 69, with system</p>	Partially Compliant (Full compliance upon selection of equipment supplier.)

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	<p>safety architectures, provided they comply with or exceed established safety standards.</p> <p>To improve explosion prevention and control, the following principles should be applied:</p> <ul style="list-style-type: none"> <li>• Implement a combination of explosion prevention and protection systems, ensuring they are tailored to the specific BESS designs and architectures available on the market.</li> <li>• Use NFPA 68 and NFPA 69 as frameworks to design effective venting and prevention solutions.</li> <li>• Prioritise real-world testing and risk assessments to validate system performance under expected operating conditions.</li> <li>• Provide clear documentation and training for operators and first responders on system functionality and emergency procedures.</li> </ul> <p>Note: Regulatory requirements should allow for flexibility in meeting safety objectives, recognising that different technologies and approaches may offer equivalent or even superior levels of protection. An evidence and performance-based approach, rather than prescriptive hardware mandates, would enable solutions to be tailored to different BESS designs and architectures while upholding the highest safety standards.</p>	<p>design informed by the results of UL 9540A testing and other real-world testing.</p> <p>Incorporating both active venting with detection and forced ventilation, in addition to deflagration venting, is preferred by The Applicant and will be given priority in the BESS selection process, to provide enhanced explosion control measures.</p>	
<p>2.9 2.9.1</p>	<p><u>Product safety - Mitigation Measures: Fire safety strategy - Battery fires</u></p> <p>It is imperative to allow for flexible fire safety strategies adapted to different BESS designs and architectures. While installation environment requirements may be subject to national or local regulations, fire safety strategies should allow for adaptability to accommodate various system designs. Controlled burning is a viable approach, as confirmed throughout the world, and evidence from large-scale fire tests must support this decision.</p> <p>Whereas water can extinguish fires and prevent/stop thermal propagation, it cannot stop a thermal runaway once initiated within a battery cell. However, direct water injection can be a viable fire suppression strategy where feasible. This approach may be necessary when a "let-it-burn" strategy is no longer sufficient to prevent fire spread. It is good practice for BESS manufacturers to provide evidence of the effectiveness and reliability of the suppression method by providing a third-party report.</p> <p>Nevertheless, the presence of water on-site should be determined by local jurisdiction. Below are advantages and disadvantages to be considered:</p> <p><u>Factor: Fire Suppression</u></p> <p>Advantages: Can reduce peak heat load when supplied through dry piping into the BESS enclosure (if designed by OEM).</p>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS facility firefighting strategy includes cooling nearby BESS enclosures using the on-site water supply. The water supply system shall meet or exceed the requirements of NFPA 855, and provide a minimum of 1,900 litres per minute (LPM) for at least 2 hours. The strategy shall also consider the results of UL 9540A testing, and require that the BESS remain in place until the thermal event has fully ended, as determined by the BESS OEM emergency response team and local fire authorities.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier and provision of studies.)</p>

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	<p>Disadvantages: Limited suppression effectiveness—may prolong the fire event without fully extinguishing it.</p> <p><u>Factor: Cooling Adjacent Units</u></p> <p>Advantages: Helps prevent cascading fire propagation to nearby BESS units or infrastructure.</p> <p>Disadvantages: Excessive use may lead to water runoff carrying toxic byproducts – this also applies to fire suppression.</p> <p><u>Factor: Controlled Burning Strategies</u></p> <p>Advantages: Fire brigades can use water to manage a controlled Fire burn, preventing spread to vegetation or critical assets.</p> <p>Disadvantages: Requires careful planning to avoid unintended thermal effects.</p> <p><u>Factor: Toxic Emission Mitigation</u></p> <p>Advantages: Can dilute hazardous emissions, reducing environmental and health impacts.</p> <p>Disadvantages: Can spread contaminants if runoff is not properly contained.</p> <p><u>Factor: Electrical Safety</u></p> <p>Advantages: No noted advantages</p> <p>Disadvantages: High conductivity increases risk of electrical shock or short circuits.</p> <p><u>Factor: Thermal Runaway Risk</u></p> <p>Advantages: No noted advantages</p> <p>Disadvantages: May intensify thermal runaway under certain conditions.</p>		
2.9.2	<p><u>Product safety - Mitigation Measures: Fire safety strategy – Non-Battery fires</u></p> <p>Where the risk of fire in non-battery related components is unacceptable, i.e., if there is a risk of fire/heat reaching the battery modules, the fire origin could be detected by a suitable fire/heat detection and fixed extinguishment system placed inside or outside as the BESS design allows for it.</p> <p>The battery must be appropriately separated from other flammable components to avoid the spread of fire, as specified in Section 2.4 of this document.</p>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS facility design shall comply with regulations and NFPA 855. A minimum separation distance of 3m shall be maintained between BESS enclosures. UL 9540A compliance testing shall be conducted up to the installation level, and the test report from the BESS OEM shall be submitted for approval by the NFRS and insurer prior to construction. The BESS enclosures shall meet UL 9540 standards. Pending acceptance of the UL 9540A test report, a minimum spacing of 3.0m between BESS enclosures shall be maintained on all sides.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier.)</p>
2.10	<p><u>Product safety - Mitigation Measures: Large scale fire testing</u></p> <p>To ensure safety and compliance, BESS manufacturers must provide evidence of adherence to NFPA 855:2026 Large-Scale Fire</p>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier.)</p>

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	Testing (or equivalent). In case of other methods chosen, their evidence has to be precisely described and verified. The test report should confirm that no fire propagation occurs between BESS units or in advanced solutions no fire propagation occurs between sub-units (e.g., packs) of a BESS to prevent container fire. This evidence helps site owners, customers, and authorities understand BESS fire behaviour.	The Applicant will procure BESS equipment with UL 9540A test reports, to demonstrate no fire propagation between modules, units, or systems. An independent assessor will review the report, guiding the final site design. The chosen BESS OEM's equipment will prevent fire propagation, and the fire suppression system will prevent cell-to-cell propagation. The firefighting strategy will include cooling nearby enclosures using on-site water supply, with two 231m <sup>3</sup> water tanks providing 1,900 LPM for at least 2 hours, meeting NFRS, NFPA 855, and ARC requirements.	
3.1	<p><u>Site safety - Mitigation Measures: Location requirements</u></p> Site assessments should be conducted at project inception and revisited periodically. These assessments could address: <ul style="list-style-type: none"> <li>• Fire and smoke risks for nearby communities.</li> <li>• Drainage systems for water runoff, including municipal water integration for firefighting.</li> <li>• Scaled regulations tailored to system size.</li> <li>• Clear emergency escape routes and on-site firefighting strategies.</li> <li>• Environmental risk for the site has to be assessed and mitigated.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS will be designed and installed in compliance with NFPA 855, IEC 62933-5-2, and tested in accordance with UL 9540A, with a focus on mitigating fire propagation risks. A robust emergency planning strategy will be established, informed by the NFRS and considering local conditions, to ensure clear emergency escape routes, on-site firefighting strategies, and effective management of environmental risks. Regular site assessments will be conducted to revisit and refine these strategies as needed.</p>	Partially Compliant (Full compliance upon completion of ERP)
3.3	<p><u>Site safety - Mitigation Measures: Water availability at site</u></p> Coordinate water availability with site-specific risks. Focus should be put on: <ul style="list-style-type: none"> <li>• Providing on-site reserves or connecting to public supplies.</li> <li>• Consulting fire authorities to match resources with suppression needs.</li> <li>• Ensuring compliance with local water management and safety regulations.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS site will ensure adequate water availability for firefighting purposes, coordinating with local fire authorities to match resources with suppression needs. The Applicant will provide on-site water reserves, comprising two 231m<sup>3</sup> tanks, meeting the minimum requirements of NFRS, NFPA 855, and ARC. The water supply will deliver 1,900 LPM for at least 2 hours, enabling effective cooling of nearby BESS enclosures. This strategy complies with local water management and safety regulations, ensuring a robust firefighting capability.</p>	Partially Compliant (Full compliance upon completion of ERP, and selection of equipment supplier.)
3.4	<p><u>Site safety - Mitigation Measures: Hazardous liquids containment</u></p> Implement strong containment measures to properly handle wastewater. Ensure the systems include: <ul style="list-style-type: none"> <li>• Secondary containment for transformer oil leaks, in compliance with NFPA 30, NFPA 850, and IEEE C57.12.</li> <li>• Spill trays or bund walls to capture glycol leaks from liquid cooling systems.</li> <li>• Oil-water separators and filtration to prevent hazardous discharge into the environment.</li> </ul>	The site will implement hazardous liquids containment measures, including drainage and bunding capabilities. The BESS technical specifications will require adequate management and containment of wastewater and toxic spills, including the provision of an automated penstock on the outfall of the containment system, addressing transformer oil, cooling system refrigerants, and firewater drainage, in compliance with NFPA 855. <u>The penstock will have a backup power system.</u>	Partially Compliant (Full compliance upon selection of equipment supplier.)

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	<ul style="list-style-type: none"> <li>Leak detection sensors to monitor potential spills and ensure timely response.</li> <li>Proper drainage and wastewater treatment to handle contaminated runoff from fire suppression and prevent pollution of soil and water sources.</li> </ul>		
3.5	<p><u>Site safety - Mitigation Measures: Container spacing</u></p> <p>Container spacing at BESS sites should be determined through a comprehensive risk-based analysis that accounts for:</p> <ul style="list-style-type: none"> <li>Fire protection, including suppression system access.</li> <li>Emergency response measures including fire brigade response time and capabilities.</li> <li>Installation-specific factors like BESS enclosure fire rating, size, capacity, and battery chemistry.</li> <li>Spacing necessary for preventive and corrective maintenance.</li> <li>Insights from large-scale fire tests and simulation data to estimate the required clearance for preventing fire propagation under standard conditions.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS facility design shall comply with regulations and NFPA 855. A minimum separation distance of 3m shall be maintained between BESS enclosures. UL 9540A compliance testing shall be conducted up to the installation level, and the test report from the BESS OEM shall be submitted for approval by the NFRS and insurer prior to construction. The BESS enclosures shall meet UL 9540 standards. Pending acceptance of the UL 9540A test report, a minimum spacing of 3.0m between BESS enclosures shall be maintained on all sides.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier.)</p>
3.6	<p><u>Site safety - Mitigation Measures: Spacing towards Power Conversion System (PCS)</u></p> <p>Spacing in between Power Conversion Systems (PCS) should minimise risks. Key measures for this include:</p> <ul style="list-style-type: none"> <li>Maintain distances based on flammability and arcing potential.</li> <li>Include fire barriers in high-risk areas.</li> <li>Regularly update designs to align with PCS technology advancements.</li> </ul>	<p>The BESS facility design will comply with regulations and NFPA 855. A minimum separation distance, based on final supplier specifications, shall be maintained between BESS enclosures and PCS or MV Station (whenever applicable). UL 9540A compliance testing shall be conducted up to the installation level, and the test report from the BESS OEM shall be submitted for approval by the NFRS and insurer before construction.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier.)</p>
3.7	<p><u>Site safety - Mitigation Measures: Spacing towards environment (Buildings / Fence / Vegetation)</u></p> <p>Key spacing considerations include:</p> <ul style="list-style-type: none"> <li>Clear vegetative barriers to prevent fire spread.</li> <li>Buffer zones for buildings and fences to minimise heat damage.</li> <li>Engage authorities and communities to address risks in urban and rural settings.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in the other technical publications referenced in this document.</p> <p>The BESS facility design will comply with regulations and NFPA 855. The operator will engage an O&amp;M provider to maintain the site, including vegetation management, ensuring a 3m clearance from vegetation to BESS containers. The Applicant will require UL 9540A compliance as part of the tendering process, which will determine the final grouping and separation distances between battery enclosures, other equipment, and buildings. UL 9540A test reports from BESS OEMs will be submitted for NFRS sign-off prior to construction, and insurer agreement.</p>	<p>Partially Compliant (Full compliance upon selection of equipment supplier.)</p>
3.8	<p><u>Site safety - Mitigation Measures: Gas/smoke/noise emissions</u></p>	<p>The BESS will comply with requirements from NFPA 855, IEC 62933 - 5-2, IEC 63056, UL 9540, UL 9540A, and relevant local regulations and directives relating to noise emissions.</p>	<p>Partially Compliant</p>

Ref.	EASE Best Practice Recommendation	Compliance Statement	Compliance
	<p>To ensure safety and minimise impacts, emissions from BESS fires should be managed as follows:</p> <ul style="list-style-type: none"> <li>• In emergency response plans, include evacuation, first-responder safety, and strategies based on thermal runaway research.</li> <li>• Mitigate noise impacts by complying with local noise regulations. A BESS development planning application should include an Acoustic Impact Assessment, typically reviewed by the Environmental Health Officer (EHO) or an equivalent authority. The energy storage system must meet strict noise limits set by local authorities to prevent adverse effects on residential areas.</li> <li>• Align with local and regional regulations, balancing operations with community well-being.</li> </ul>		<p>(Full compliance upon completion of ERP, and selection of equipment supplier.)</p>
4.1	<p><u>Personnel safety - Mitigation Measures: Emergency Response Plan</u></p> <p>Emergency response plans must prioritise personnel safety and align with recognised standards. They should incorporate practical, evidence-based strategies to minimise risks during incidents:</p> <ul style="list-style-type: none"> <li>• When a large-scale fire testing shows that the fire is confined to a single BESS unit, firefighters should adopt a defensive approach. Allowing the fire to self-extinguish reduces risks to responders.</li> <li>• When necessary, cool adjacent units or exposed assets using fog nozzles with a wide-angle cone. This approach is advisable when large-scale fire testing has not been performed or when additional cooling is required.</li> <li>• Personnel should never manually open the doors of a smoking or burning BESS. If access is needed, use remote or robotic equipment from a safe distance to avoid creating an explosive atmosphere by introducing oxygen.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in other sections of this document.</p> <p>A comprehensive ERP will be developed in collaboration with the Nottinghamshire Fire and Rescue Service (NFRS) and independent technical advisors. The ERP will outline procedures for site personnel, operations control room staff, and first responders in the event of a thermal event, fire, or explosion. The plan will address key considerations, including hazard identification, safe access, and firefighting infrastructure, and will be reviewed and updated regularly to ensure effectiveness. The ERP will be agreed with NFRS before construction commences and will provide critical information for first responders to evaluate and respond to incidents on site.</p>	<p>Partially Compliant</p> <p>(Full compliance upon completion of ERP, and selection of equipment supplier.)</p>
4.2	<p><u>Personnel safety - Mitigation Measures: Training (personnel /firefighters)</u></p> <p>Training programmes must be based on the established emergency response strategy, which is specifically designed for people at BESS locations. Key features include:</p> <ul style="list-style-type: none"> <li>• Providing firefighters with comprehensive training to ensure effective response during emergencies.</li> <li>• Creating customised training modules for both personnel and emergency responders, aligned with regional and national standards.</li> <li>• Regularly updating training to reflect advancements in battery technology and evolving safety practices.</li> </ul>	<p>This recommendation has already been addressed through similar requirements outlined in other sections of this document.</p> <p>The Applicant will ensure compliance with training requirements through specialised training programs for site personnel and local firefighters. The O&amp;M contractor will provide training on specific equipment deployed at the site, while the BESS OEM will develop customised training for personnel who frequently attend the facility. Site personnel and local firefighters will receive regular training on emergency response priorities and actions, with updates and reviews to ensure the plan remains effective, and aligns with standards.</p>	<p>Partially Compliant</p> <p>(Full compliance upon completion of ERP, and selection of equipment supplier.)</p>

#### **A5.4.3.5 FIRE SAFETY TRAINING**

- 30 All staff will receive appropriate fire safety training. The main features of the training will be as shown in Appendix A.
- 31 Training should be provided at the intervals stated in the schedule; however, it may be appropriate to update training in circumstances such as changes to the site layout, introduction of new fire risks, changes to the emergency procedures. Such issues should be highlighted through the ongoing fire risk assessment process.
- 32 Detailed records should be kept of all fire safety training, including the dates, subjects covered and names of those receiving the training.
- 33 Local firefighters and first responders responsible for responding to emergencies at the BESS facility will receive training as per Appendix A.

#### **A5.4.3.6 FACILITIES FOR FIRE FIGHTING**

- 34 There are certain facilities on the site to assist with Fire Service operations. These are:
  - Fire vehicle access route;
  - Emergency response plan;
  - Emergency control operations control room, manned continuously to provide guidance;
  - Fire water tanks;
  - Fire alarm system to BS5839-1:2017; and
  - Fire water drainage.
- 35 NFRS will be invited to site to familiarise themselves with the site, BESS equipment and the firefighting facilities. Ongoing liaison will be maintained throughout the development and operation of the BESS facility.
- 36 Safe working distances will be discussed with the chosen BESS OEM, evaluated with NFRS and then agreed in writing as part of the fire safety risk assessment conducted by the Principal Contractor under their duties as part of the Construction Design and Maintenance Regulations 2015. This will then be adopted by the O&M contractor and periodically reviewed with NFRS as part of the fire safety risk assessment for the operational site.

#### **A5.4.3.7 EVACUATION / EMERGENCY PROCEDURES**

- 37 All staff should be trained in necessary actions in the event of fire.
- 38 The emergency evacuation procedures are in Appendix C. Evacuation procedure notices will be displayed at key locations around the BESS facility as a reminder to staff.
- 39 The BESS facility will not be permanently manned, and it is expected that personnel shall only attend site for routine maintenance, troubleshooting and site inspection reasons.
- 40 The evacuation strategy for fire is for total simultaneous evacuation. All site occupants present will evacuate from all areas of the site when the fire alarm warning is given.

- 41 There is a specific assembly point to which all occupants must report in the event of an evacuation.
- 42 Attendance records and the visitor book will be taken to the assembly point to enable a roll call to be made.
- 43 Contact details for the operations room will be shared with NFRS prior to commissioning, these will be clearly sign-posted throughout the BESS facility, and at the BESS facility gates within the Information Box.
- 44 NFRS will be issued with a copy of the ERP for the BESS facility, and this will also be made available within the BESS facility as a back-up in paper format.
- 45 Attending Fire Service crews will be met at the Site Main Entrance if personnel are present, and a rollcall will be shared. Where no personnel are present, NFRS will contact the remote-operations control room and check the visitors sign-in log and proceed with guidance from the remote operations control room.
- 46 Emergency lighting will be provided to all common escape routes and the system should comply with the recommendations given in BS 5266: Part 1.
- 47 All escape routes are to be distinctively and conspicuously marked by emergency exit signs following the recommendations of BS ISO 3864-1 and BS 5499-4.

#### **A5.4.3.8 FIRE SUPPRESSANT**

- 48 As outlined in Environmental Statement Technical Appendix A9.1, FRA, [EN010162/APP/6.4.9.1] based on recommendations in NFPA 855 Standard for the Installation of Stationary Energy Storage Systems and NFCC - Grid Scale Battery Energy Storage System planning - Guidance for FRS, a burn time of 2 hours and a requirement of 1,900 l/min of fire suppression water has been used to calculate the volume of fire suppressant water required to be stored onsite in the event of a container fire.
- 49 This equates to 228 m<sup>3</sup> of storage.
- 50 The SuDS structures serving each catchment of the BESS compound will be sized to accommodate the 1 % AEP + 40 % CC ~~or~~ and an additional 228 m<sup>3</sup> as an additional holding basin, and this will be sufficient for storing the full fire suppressant volume.
- 51 An automatic penstock will be placed on the outlet of the SuDS structure and would be shut off in the event of a fire suppression event. It would remain closed until testing of the captured water has taken place. Water will then be removed offsite by tankers to a licenced facility. A backup power system will also be in place in case of power failure.
- 52 There will also be an impermeable lined (clay or synthetic liner or or appropriate method at the time of construction to be agreed with the EA) holding basin available for spent firefighting water to be pumped to in the event of a battery fire during heavy rainfall. As such, the SuDS system will not reach capacity during such an event. Following a fire-fighting event, the lining or clay base of the detention basin could be replaced if testing identified that contaminants were present.

- 53 It is recommended that the BESS Compound has a shallow bund or cut-off permitter drain to limit the potential for run-off to leave the Development and drain to the cellular storage.

## **A5.4.4 MONITORING**

### **A5.4.4.1 EVACUATION DRILLS**

- 54 An evacuation drill will be carried out at the frequency stated in Appendix A. Routine drills will be organised and monitored by the Fire Safety Manager. Records will be kept of each evacuation drill.

### **A5.4.4.2 CHECKS, MAINTENANCE AND TESTING**

- 55 All fire safety equipment and systems will be subject to routine checks, tests and maintenance at periods recommended by manufacturers / suppliers, British Standards or general fire safety guides. The testing and maintenance schedule is included at Appendix D.

### **A5.4.4.3 RECORD KEEPING**

- 56 Fire safety records should be kept up to date and available for inspection on site. The summary of fire safety records to be kept is as follows:
- Staff fire safety training;
  - Equipment and systems testing and checks;
  - Equipment and systems routine maintenance and servicing;
  - Fire alarm activations;
  - Fire events;
  - Fire risk assessment and associated action plans;
  - Fire safety officer visits and associated correspondence;
  - Lessons learned and actions implemented following discussion with NFRS; and
  - Evacuations planned and unplanned.

## **A5.4.5 AUDIT AND REVIEW**

### **A5.4.5.1 FIRE RISK ASSESSMENT**

- 57 The fire risk assessment should be reviewed at least annually.
- 58 A review will also take place in the event of significant changes, such as;
- Increase in number of people likely to be in the site;
  - Proposed alterations in the layout of the site;
  - Increase in fire loading in the site; and
  - Proposed changes to this fire safety management plan or the arrangements specified within it.
- 59 The fire risk assessment and procedures should also be reviewed following any occurrence of fire (no matter how minor) or any reported fire-related near-miss.

#### **A5.4.5.2 RESPONSE TO CHANGES**

60 Whenever changes are made which:

- Necessitate review of fire risk assessment (as specified in A5.4.5.1 above), or
- Affect the management structure or arrangements of the premises,

the impact of those changes on this FSMP should be assessed and amendments made as necessary.

#### **A5.4.5.3 RECORDS AUDIT**

61 The fire safety records detailed in Section A5.4.3.5 and Section A5.4.4.3 above should be audited annually by personnel with designated responsibility.

#### **A5.4.5.4 FSMP FORMAL REVIEW**

62 The FSMP should be the subject of an annual review. The results of the review should be recorded by The Applicant digitally, and any necessary changes will be made and implemented. The FSMP should then be shared with all relevant parties, such as the Insurers, NFRS, O&M Contractor and any financing partners.

63 The review will be undertaken by a competent person nominated by personnel with designated responsibility.

## A5.4 APPENDIX A – TRAINING SCHEDULE

64 Training will be provided as appropriate to those with designated responsibilities.

**Table A5.4.A-1 – Training Schedule**

<b>Training</b>	<b>Content</b>	<b>Frequency</b>
<b>General Fire Safety Induction – All Staff and Local FRS</b>	Site layout familiarisation Identification of escape routes and assembly point Fire detection, suppression and warning arrangements Emergency procedures	On commencement
<b>Routine Staff Training – All Staff and Local FRS</b>	Emergency plan and procedures Roll call procedures Fire prevention (including BESS) Roles and responsibilities Key points from fire risk assessment False alarms – review and prevention measures Fire events (and near-misses) Special instruction relevant to particular role (e.g. calling fire service, assisting person as part of PEEP)	Initial and annual refresher
<b>Evacuation Practice</b>	Full evacuation drill testing all procedures Review and communication of feedback to all	6 monthly (for each shift group)
<b>Portable Fire Extinguisher Training (Designated Staff only)</b>	Practical firefighting using portable equipment of types as installed in the premises	Initial and periodic refresher
<b>Nominated Person Training / Fire Warden</b>	Role and responsibilities detail Routine fire checks Understanding fire-related systems and equipment Assisting evacuation process Checking premises / areas safely Liaison with Fire Service Reporting procedures for faults, near-misses	Initial and annual refresher

## **A5.4 APPENDIX B – STANDARD PERSONAL EMERGENCY EVACUATION PLANS (PEEPS)**

- 65 Standard PEEPS are for use when a person who requires assistance in an emergency comes to the premises as a visitor. In other circumstances it will be appropriate to have a specific PEEP for anyone requiring one
- 66 NB: Specific PEEPs are beyond the scope of these FSMP recommendations.

### **PLAN 1 – PERSON WITH SIGHT IMPAIRMENT**

#### **Requirement**

- 67 Person is partially sighted or blind making it difficult to locate and negotiate escape routes.

#### **Escape Procedure**

- 68 The person's host will take them to a safe position outside the site. (It is not anticipated that visitors with sight impairments will be allowed unaccompanied access around the site).

#### **Specialist Equipment**

- 69 None specified for this plan.

#### **Fire Warden Assistance**

- 70 None specified for this plan.

#### **Communication**

- 71 Information on escape routes, fire alarms and procedures will need to be detailed verbally at the reception area when signing in as standard printed information will not be adequate.

### **PLAN 2 – PERSON WITH HEARING IMPAIRMENT**

#### **Requirement**

- 72 Person has hearing impairment making it difficult to hear the fire alarm clearly.
- 73 OR
- 74 Person is totally deaf making it impossible to hear the fire alarm.

#### **Procedure**

- 75 The person will be alerted by their host, or by a companion / colleague who is visiting with them.
- 76 OR
- 77 The person will be alerted by seeing a fire alarm visual warning device.
- 78 It is anticipated that an independent escape can then be made following the signed escape routes.

### **Specialist Equipment**

- 79 Some visual warning devices are in place where visitors may be unaccompanied, e.g. toilets.

### **Fire Warden Assistance**

- 80 None specified for this plan.

### **Communication**

- 81 Availability of visual information in the reception area to inform visitors of escape routes and procedures

## **A5.4 APPENDIX C – EMERGENCY PROCEDURES**

- 82 THESE ARE THE EMERGENCY FIRE PROCEDURES. NOTICES DISPLAYING THIS INFORMATION ARE DISPLAYED IN THE SWITCHROOMS, AND AVAILABLE WITHIN THE INFORMATION BOX FOR FIRST RESPONDERS.

### **FIRE EMERGENCY RESPONSE PLAN**

#### **What People / Staff Should Do If They Discover a Fire**

- 83 Raise the alarm by operating the nearest fire alarm call point (and then act as follows):

#### **What People / Staff Should Do If They Hear the Fire Alarm**

- Leave the site by the nearest exit.
- Evacuate to the designated assembly point.
- Do not stop or return to collect personal belongings.
- Close any doors en-route without delaying your escape.
- Remain at the assembly place.
- Return to the site only when authorised to do so by authorised personnel or attending Fire Officer.

NB: A person who discovered the fire should immediately pass any information to the supervising manager at the assembly point.

- 84 For those with specific designated duties:

- Call the Fire & Rescue Service by dialling 999.
- Inform the operations control room.
- Tackle the fire only if trained and where appropriate.
- Those with responsibilities for assisting persons with Personal Emergency Evacuation Plans should respond as required following the actions as identified in the Plan.
- Ensure any visitors are escorted from the site to the assembly point.
- During joint occupation (Contractor still present), notify the Contractor following the agreed protocol.

#### **What Designated Staff Should Do if a False Activation has Occurred:**

- Reset the Fire Alarm.
- Advise staff that it is safe to return to the site.
- Record the event in the Logbook.

- 85 Visitors

- All Visitors are logged in and out of the site by use of the Visitors Book.
- All Visitors are made aware of the Fire Evacuation Procedures on arrival.
- The designated person will take the Visitors Book to the Assembly Point in the event of an evacuation and perform a roll call.
- The Fire & Rescue Service will be made aware of any suspected missing person(s).

### **Contacting the Fire & Rescue Service**

- The Fire & Rescue Service will be called by a designated staff member from the operational control room, or personnel on site conducting maintenance activities.
- Although the Fire Alarm will send a signal to the Automatic Monitoring Centre, a confirmatory 999 call will still be made.

### **Fire & Rescue Service Liaison Procedure**

- 86 On the arrival of the Fire & Rescue Service the following will be done:
- The designated staff member / operator control room member will make themselves known to the Officer in Charge of the attending crew on their arrival (meeting them at the designated location);
  - The designated staff member will provide all known details to the Fire & Rescue Service on arrival;
  - The designated staff member will continue to act as liaison / point of contact at the direction of the Fire Incident Commander.

### **Battery Energy Storage Specific Information**

- 87 The following information shall be made available prior to construction of the BESS facility, and included within the information box at the site entrance:
- Lithium-Ion battery chemistries, and procedure from the OEM for tackling the fire
  - Methods of isolation for each individual BESS enclosure and the full site, including actions to be taken depending upon the scenario.
  - Toxic gas mixtures
  - Environmental related considerations including where fire water should be applied, and fire runoff activities (i.e., opening of the penstock)
  - Responsibility and handling of damaged batteries

### **Specific Information for the Fire & Rescue Service**

- 88 The designated staff member or operations control room will give the Fire & Rescue Service specific information such as:
- Location of the fire / incident;
  - Location of fire panel;
  - Missing persons;
  - Flammable material stores;
  - Location of high risk areas;
  - Any unusual activities such as site works or temporary structures.
- 89 Contractor to include the procedure to follow if they have a fire emergency on their site with regards to notification of responsible persons/tenants.

## A5.4 APPENDIX D – MAINTENANCE / TESTING SCHEDULE

**Table A5.4.D-1 – Recommended Maintenance Schedule**

System	Frequency	Comment
Fire Alarm (Audio & Visual)	Monthly	User operation test
	Quarterly, Six-monthly, Annually	Check / service by specialist contractor
BESS Smoke Detectors	As agreed with BESS OEM	All sensors checked in accordance with interval specified by BESS OEM including link to SCADA / HMI
BESS Heat Detectors	As agreed with BESS OEM	All sensors checked in accordance with interval specified by BESS OEM including link to SCADA / HMI
BESS Fire Suppression and Explosion Protection	As agreed with BESS OEM	All fire suppression devices checked in accordance with interval specified by BESS OEM including link to SCADA / HMI
BESS Audible Alarm	As agreed with BESS OEM	All fire alarms checked in accordance with interval specified by BESS OEM including link to SCADA / HMI
BESS Visual Alarm	As agreed with BESS OEM	All fire alarms checked in accordance with interval specified by BESS OEM including link to SCADA / HMI
Emergency Lighting	Monthly	User operation test
	Annually	Check / service by specialist contractor
Substation Fire Suppression System	Weekly	Check by user
	Quarterly, Six-monthly, Annually, 3-yearly, 10-yearly	Check / service by specialist contractor
Water Tanks	Weekly	Check by user for obstructions
	Annually	Check / service by specialist contractor
Fire Doors	Six-monthly	Inspection by user
Fire Exits	Monthly	User check for ease of opening
Fire Extinguishers	Monthly	Inspection by user
	Annually	Check / service by specialist contractor

System	Frequency	Comment
Fire door / shutter release mechanisms	Weekly	Operation check by user
	Annually	Check / service by specialist contractor
<u>Automated SuDS Penstock</u>	<u>Weekly</u>	<u>Operation check by user</u>
<u>SuDS Structures e.g. basins</u>	<u>As per the frequency outlined in the SuDS Manual for each structures – see the Outline Drainage Strategy [EN010162/APP/6.4.93].</u>	<u>Check / service by specialist contractor</u>

\*Different frequencies may be appropriate – manufacturers or supplier’s recommendations should be followed