

Application by Lime Down Solar Park for an order granting development consent for the Lime Down Solar Project

Issue Specific Hearing 1

Date: 22 April 2026

Venue: Need Community and Arts Centre, Borough Parade, Chippenham, SN15 3WL; and Microsoft Teams

Action points arising

No	Party	Action	Deadline
1	Applicant	Resubmission of document Appendix 3-3 Illustrative Drawings [APP-184] at a higher resolution so that the dimensions shown on the substation compound and substation elevation plans are readable. In addition, applicant to include in updated [APP-184] a plan of the 400kV substation with fence (if applicable); and a plan of a 4.5m single access tracker panel with dimensions.	1A
2	Applicant	To confirm why air insulated substations are proposed instead of gas insulated substations considering the larger footprint of air insulated substations.	1A
3	Applicant	To confirm whether lightning conductors are included on substations and if so, whether these are contained within the overall height parameters assessed in the ES.	1A
4	Applicant	To clarify the percentage transmission losses associated with the length of the cable route. Include the export and import losses.	1A
5	Wiltshire Council - LLFA	To confirm and submit any Section 19 flooding investigation reports in relation to flooding within the Gauze Brook catchment area, specifically in relation to flooding events in Corston and Rodbourne.	1A
6	Applicant	To submit a list of outstanding ecological surveys for the cable route corridor.	1A
7	Applicant	To respond to Wiltshire Council's submission made at the end of Item 5 (Alternatives) on the ISH1 agenda, regarding any differences of impacts from a 132kV vs 400kV connection.	1A

8	Applicant	To respond to all other comments raised by IPs at the end of Item 5 (Alternatives) on the ISH1 agenda.	1A
---	-----------	--	----