

Date: 11 May 2026  
Your ref: EN0110001



**BY EMAIL ONLY**

Customer Services  
Hornbeam House  
Crewe Business Park  
Electra Way  
Crewe  
Cheshire  
CW1 6GJ

T 0300 060 3900

[keadbynextgeneration@planninginspectorate.gov.uk](mailto:keadbynextgeneration@planninginspectorate.gov.uk)

Dear Inspector

**NSIP Reference Name / Code: EN0110001 The Keadby Next Generation Power Station Project**

Please see Natural England's submission for Examination deadline 4.

The Applicant has now provided clarification that the section of North Humber to High Marnham surveys referred to in the assessment include the land to the north of the Keadby Wind Farm. This evidence, alongside the desk study information in section 7.2 of the HRA, addresses our previous concerns related to noise impacts to birds during construction and operation (issue refs NE1 and NE2). While Natural England does generally require noise modelling to include Lamax and LApeak we concur that the evidence provided in this instance demonstrates there will be no requirement for additional mitigation related to noise. We also note that the noise contour plots for the LAeq modelling have been included in the latest version of the HRA (April 2026) as figures 3 and 4, which addresses our other outstanding comment on this issue.

Therefore, we concur with the conclusion of no adverse effect on integrity for this impact pathway during construction or operation and have no further comments on this topic.

We will continue to work with the Applicant to resolve the outstanding impacts associated with air pollution.

Yours faithfully

L [REDACTED]  
Yorkshire and Northern Lincolnshire Area Team  
Natural England

Email: [REDACTED]@[naturalengland.org.uk](mailto:naturalengland.org.uk)