



Gwasanaeth Tân ac Achub
Canolbarth a Gorllewin Cymru
Mid and West Wales
Fire and Rescue Service

Prif Swyddog Tân | Chief Fire Officer

Craig Flannery

Y Pencadlys, Lôn Pisgwydd,
Caerfyrddin, Sir Gâr, SA31 1SP
post@tancgc.gov.uk | tancgc.gov.uk

Headquarters, Lime Grove Avenue,
Carmarthen, Carmarthenshire, SA31 1SP
mail@mawwfire.gov.uk | mawwfire.gov.uk

0370 60 60 699

Environmental Services
Infrastructure Decisions and Applications
Service
Planning Inspectorate
69 Buckingham Avenue
Slough
SL1 4PN

Gofynner am/
Please ask for:

Watch Manager

Rhif Est/Extn. No.

9831

E-bost/E-mail:

bregs@mawwfire.gov.uk

Fy Nghyf/My Ref:

KS/CW/00365078

Dyddiad/Date:

28th July /2026

Dear Sir/Madam,

**THE TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(WALES) ORDER 2012**

THE DEVELOPMENTS OF NATIONAL SIGNIFICANCE (PROCEDURE) (WALES) ORDER 2016

**DEVELOPMENT PROCEDURE (CONSULTEES) (WALES) (MISCELLANEOUS AMENDMENTS)
ORDER 2021 – FIRE AND RESCUE AUTHORITIES**

RE: Gwynt Glas Offshore Wind Farm

REFERENCE NUMBER: EN0110036

I acknowledge receipt of the notification to the Mid and West Wales Fire and Rescue Authority in relation to the above application.

The site plan(s) of the above proposal has been examined, and the Fire and Rescue Authority would wish the following comments to be brought to the attention of the planning committee/applicant. It is important that these matters are dealt with early on in any proposed development.

- The Fire Authority has no objection to the proposed development and refers the Local Planning Authority to any current standing advice by the Fire Authority about the consultation.

The developer should consider the need to provide adequate water supplies and vehicle access for firefighting purposes on the site and general guidance on this matter is given in the attached Appendix and the following links:


<https://www.water.org.uk/national-guidance-document-provision-water-firefighting>

Furthermore, the applicant should be advised to contact the appropriate Authority responsible for ensuring safety and compliance for these types of developments i.e., Health & Safety Executive / Local Authority Building Control.

Rydym yn croesawu gohebiaeth yn y Gymraeg a'r Saesneg
- byddwn yn ymateb yn gyfartal i'r ddau ac yn ateb yn eich
dewis iaith heb oedi.
Rydym yn croesawu galwadau yn y Gymraeg a'r Saesneg.

We welcome correspondence in Welsh and English -
we will respond equally to both and will reply in your
language of choice without delay.
We welcome calls in Welsh and English.

100% wedi'i ailgylchu | recycled





Gwasanaeth Tân ac Achub
Canolbarth a Gorllewin Cymru
Mid and West Wales
Fire and Rescue Service

The plan(s) has been retained for record purposes.

Yours faithfully



Watch Manager [REDACTED]
Authorised Fire Safety Inspector
On behalf of the Mid and West Wales Fire and Rescue Authority

Encs.

Rydym yn croesawu gohebiaeth yn y Gymraeg a'r Saesneg
- byddwn yn ymateb yn gyfartal i'r ddau ac yn ateb yn eich
dewis iaith heb oedi.
Rydym yn croesawu galwadau yn y Gymraeg a'r Saesneg.

We welcome correspondence in Welsh and English -
we will respond equally to both and will reply in your
language of choice without delay.
We welcome calls in Welsh and English.

100% wedi'i ailgylchu | recycled

EIN GWELEDIGAETH
I ddarparu'r Gwasanaeth gorau posibl i
gymunedau canolbarth a gorllewin Cymru.

OUR VISION
To deliver the best possible service for
the communities of mid and west Wales.

#eichgtacgc #yourmawwfrs



MID AND WEST WALES FIRE AND RESCUE SERVICE

Advice on Water Supplies

1. WATER SUPPLIES FOR FIREFIGHTING

The existing output of the statutory water supply network may need to be upgraded in certain parts of the local plan area to care for firefighting needs of new developments. It is recommended that this provision be a condition of planning consent.

Reference to the National Guidance Document on the Provision of Water for Fire Fighting 2007.

Access to Open Water Supplies

Where development of water-front sites takes place, the need for permanent and unobstructed access for firefighting appliances to the water should be made a condition of any planning consent.

Consultation must take place with the Fire and Rescue Authority during the earliest planning stages of any development to ensure access for fire pumping appliances is satisfactory.

1.1. HOUSING

Minimum main size 100 millimetres. Housing developments of units of detached or semi-detached houses of not more than two floors should have a water supply capable of delivering a minimum of eight litres per second through any hydrant on the development.

The Fire and Rescue Authority should be consulted at the outline planning stage of any proposed projects to ascertain the exact requirements.

1.2. TRANSPORTATION

Lorry/Coach Parks - Multi-Storey Car Parks-Service Stations

Minimum main size 100 millimetres. All of these amenities should have a water supply capable of delivering a minimum of 25 litres per second through any hydrant on the development or within a vehicular distance of 90 metres from the complex.

1.3. INDUSTRY

In order that an adequate supply of water is available for use by the Fire and Rescue Authority in case of fire, it is recommended that the water supply infrastructure to any commercial industrial estate is as follows:

Light Industrial/Commercial

Up to one hectare, 20 litres per second - Minimum Main Size 100 millimetres

Up to two hectares, 35 litres per second - Minimum Main Size 150 millimetres



High Risk Industrial

Up to three hectares 50 litres per second - Minimum Main Size 150 millimetres

Over three hectares, 75 litres per second - Minimum Main Size 150 millimetres

In rural areas it may not be possible to provide sufficient mains water. To overcome this, static or river supplies would be considered on site if they are capable of supplying the above flow rates for at least one hour.

The Fire and Rescue Authority should be consulted at the outline planning stage of any proposed projects to ascertain the exact requirements, as high-risk premises may require a greater flow.

1.4. SHOPPING, OFFICES, RECREATION AND TOURISM

Commercial developments of this type should have a water supply capable of delivering a minimum of 20 to 75 litres per second to the development site. The Fire and Rescue Authority should be consulted at the outline planning stage of any proposed projects to ascertain the exact requirements.

1.5. EDUCATION, HEALTH AND COMMUNITY FACILITIES

Village Halls

Should have a water supply capable of delivering a minimum of 15 litres per second through any hydrant on the development or within a vehicular distance of 100 metres from the complex.

Primary Schools and Single Storey Health Centres

Should have a water supply capable of delivering a minimum of 20 litres per second through any hydrant on the development or within a vehicular distance of 70 metres from the complex.

Secondary Schools, Colleges, Large Health and Community Facilities

Should have a water supply capable of delivering a minimum of 35 litres per second through any hydrant on the development or within a vehicular distance of 70 metres from the complex.



1.6. DISTANCES BETWEEN FIRE HYDRANTS

The distance between fire hydrants should not exceed the following:

Residential areas	-	200 metres
Industrial Estates	-	150 metres
Town Centre Areas	-	90 metres
Commercial (Offices & Shops)	-	100 metres
Residential Hostels	-	Adjacent to access
Hotels	-	Adjacent to access
Institutional (Hospitals & Old Persons Home)	-	Adjacent to access
Old Persons Home	-	Adjacent to access
Educational (Schools & Colleges)	-	Adjacent to access

1.7. CONCLUSION

Developers should hold joint discussions with the relevant Water Authority or the Environmental Agency and the Fire and Rescue Authority to ensure that adequate water supplies are available in case of fire.

The Fire and Rescue Authority reserve the right to ask for static water supplies for firefighting on site, as a condition of planning consent, if the supply infrastructure is inadequate for any given risk.