


Environmental Statement Noise and Vibration

Hinkley Point C Connection Project

*Regulation 5(2)(a) of the Infrastructure Planning
(Applications: Prescribed Forms and Procedure)
Regulations 2009*





Hinkley Point C Connection Project

ENVIRONMENTAL STATEMENT – MAY 2014

VOLUME 5.14.1, CHAPTER 14 – NOISE AND VIBRATION

Document Control			
Document Properties			
Organisation	National Grid		
Author	David Gray, Bureau Veritas		
Approved By	Bobby Clayton, TEP		
Title	Environmental Statement Chapter 14 – Noise and Vibration		
Document Reference	Volume 5.14.1		
Date	Version	Status	Description/Changes
09/05/14	A	Live	Final version for DCO submission

Table of Contents

14	Noise and Vibration.....	7
14.1	Introduction	7
Part 1 – Construction and Decommissioning Noise and Vibration		13
14.2	Method	13
14.3	Baseline Environment.....	25
14.4	Prediction and Assessment of Significance of the Potential Construction Noise Effects	26
14.5	Inter-relationship of Potential Effects	34
14.6	Mitigation.....	35
14.7	Residual Effects	36
14.8	Cumulative Effects	39
14.9	Conclusions.....	39
Part 2 – Operational Noise and Vibration		41
14.10	Method	41
14.11	Baseline Environment.....	56
14.12	Prediction and Assessment of Significance of the Potential Operational Noise Effects	57
14.13	Inter-relationship of Potential Effects	64
14.14	Mitigation.....	64
14.15	Residual Effects	65
14.16	Cumulative Effects	66
14.17	Conclusions.....	67
Part 3 – Summary of Noise and Vibration Effects.....		69
14.18	Conclusions.....	69

INSETS (VOLUME 5.14.1)

Inset 14.1: Proposed Sandford Substation Night Time Noise Propagation Model

Inset 14.2: Example CadnaA 400kV Overhead Line Noise Assessment Model

APPENDICES (VOLUME 5.14.2)

Appendix 14A: Construction Noise Assessment Tables

Appendix 14B: Construction Traffic Noise Assessment

Appendix 14C: Noise and Vibration Scoping Out Note

Appendix 14D: Sandford Substation CadnaA Noise Modelling

Appendix 14E: Summary of Night-time Background Noise Measurements on Route of Proposed 400kV Overhead Line and Substations

Appendix 14F: Generic Data Curves to Assess Spans of 400kV Overhead Line Noise

Appendix 14G: 400kV Overhead Line Noise Modelling

14 NOISE AND VIBRATION

14.1 Introduction

14.1.1 This chapter of the Environmental Statement (ES) describes the assessment of potential noise and vibration effects of the construction (including removal of existing overhead lines), operation and decommissioning of the various components of the Proposed Development. Potential effects and mitigation measures that would be implemented to reduce or avoid effects, if needed, are then summarised.

14.1.2 A description of the Proposed Development is provided in **Volume 5.3.1** and illustrated in **Volume 5.3.3, Figures 3.1 - 3.6**. This chapter, **Volume 5.14**, is supported by a number of appendices provided after the main chapter and insets provided within the chapter. This chapter should be read with the corresponding insets and appendices available for reference as they assist the understanding of the descriptions and assessments presented in the text.

Chapter Layout

14.1.3 Following this introduction section, which includes records of and responses to relevant consultee representations, this chapter has been separated into three parts. Part 1 deals with construction and decommissioning effects. Part 2 deals with operational effects. Part 3 summarises the findings of this chapter for construction, decommissioning and operational effects. This separation should aid the reader and minimise confusion between the various methodologies, standards and assessments described in this chapter. There may be repetition between Part 1, Part 2 and Part 3, where appropriate; this is included to aid the reader.

Project Engagement

EIA Scoping

14.1.4 As part of the scoping phase of the Environmental Impact Assessment (EIA), National Grid Electricity Transmission plc (National Grid) prepared the EIA Scoping Report 2013 setting out the proposed approach to EIA in respect of the Proposed Development, including the identification of assessment methods for each of the EIA topics to be assessed.

14.1.5 In response to that Scoping Report, the Planning Inspectorate produced a Scoping Opinion. The Scoping Opinion is provided at **Volume 5.5.2, Appendix 5A**. A summary of all Scoping Opinion representations received (relevant to EIA) and National Grid's responses are set out at **Volume 5.5.2, Appendix 5B**. A summary of the main Scoping Opinion representations received in relation to noise and vibration are presented in the table below.

Table 14.1 Summary of the Main Noise and Vibration Scoping Representations Received

Representation	Response
<p>The SoS recommends that the methodology and choice of noise receptors should also be discussed and agreed with the relevant Environmental Health Department of the Councils and the relevant parish councils where the new substations would be sited. In particular, consideration should be given to any potential noise disturbance likely to occur at night and other unsocial hours such as weekends and public holidays.</p>	<p>Volume 5.14.1, describes consultation with EHOs and other relevant stakeholders. Representations have been taken into account in the determination of baseline conditions, assessment and proposals for mitigation. Assessment of operational noise has been undertaken against night time background conditions. A meeting took place with the EHO representing the LPA where the background monitoring methodology was discussed.</p>
<p>Information should be provided on the types of vehicles and plant to be used during the construction phase and an assessment of noise and vibration undertaken. The noise and vibration assessments should take account of construction traffic movements along access routes.</p>	<p>A quantitative traffic noise assessment and a qualitative traffic vibration assessment for sensitive receptors have been undertaken and is provided in Volume 5.14.1. Types of vehicles and plant to be used during the construction phase are described in Volumes 5.3.1, 5.12.1 and 5.14.1. Volume 5.14.1 includes an assessment of noise and vibration during the construction phase and refers to the Transport Assessment (Volume 5.22) and the Draft Construction Traffic Management Plan (CTMP) (Volume 5.26.5) for traffic movements during construction.</p>
<p>The SoS notes the intention to mitigate impacts during construction through working time restrictions and the provision of an appropriate Construction Management Plan. The ES should identify the measures that the plan will contain and assess their effectiveness.</p>	<p>Works would be undertaken in accordance with the Draft Construction Environmental Management Plan (CEMP) (Volume 5.26);</p>
<p>In relation to cumulative effects from other potential developments, the final assessment should include the combined, indirect effects of road transport. The assessment should also identify where construction or operational traffic from different developments will simultaneously affect certain road links.</p>	<p>Cumulative effects from traffic serving simultaneous development are addressed within the TA (Volume 5.22) and Volume 5.17.</p>

Representation	Response
Insufficient evidence has been presented in the Scoping Report to allow the scoping out of operational vibration. Evidence should be provided in the ES to justify the decision to scope out these effects.	Transformers and other wound power equipment vibrate at twice power frequency i.e. 100Hz and associated harmonic frequencies e.g. 200Hz, 300Hz. However the effects are negligible and are countered by the use of industry standard mitigation techniques such as the use of vibration isolation pads to prevent transmission of ground borne vibration. Ground borne vibration has never been raised as a significant issue or resulted in any complaints at any of our other operational sites.
Insufficient evidence has been presented in the Scoping Report to allow the scoping out of operational noise from Aust and Seabank substations. Evidence should be provided in the ES to justify the decision to scope out these effects during operation. If this cannot be done then the effects should not be scoped out at this stage.	Further information regarding the scoping out of noise sources is provided in Volume 5.14.2, Appendix 14C .

Statutory Stage 4 Consultation

14.1.6 Statutory Stage 4 Consultation took place over a period of eight weeks between 3 September and 29 October 2013 in accordance with the Planning Act 2008. Statutory and non-statutory consultees and members of the public were included in the consultation. Various methods of consultation and engagement were used in accordance with the Statement of Community Consultation (SoCC) including letters, website, public exhibitions, publicity and advertising, inspection of documentation at selected locations and parish and town council briefings.

14.1.7 National Grid prepared a Preliminary Environmental Information Report (PEIR) which was publicised at this consultation stage. National Grid sought feedback on the environmental information presented in that report. Feedback received during Statutory Stage 4 Consultation was considered by National Grid and incorporated where relevant in the design of the Proposed Development and its assessment and presentation in this ES.

14.1.8 A summary of the Statutory Stage 4 Consultation representations received (relevant to EIA) and National Grid's responses are summarised at **Volume 6.1** (Consultation Report). A summary of the main Statutory Stage 4 Consultation representations received in relation to noise and vibration is presented in the table below.

Table 14.2 Summary of the Main Noise and Vibration Statutory Stage 4 Consultation Representations Received

Representation	Response
Further clarification is required regarding noise generated by the T pylon during wet weather, which is touched upon in the Pylon Options Report.	The impact of noise from the overhead lines is discussed in Volume 5.14.1 and takes account of the noise generation from each specific pylon design
The assessment criteria described for construction noise in the methodology does not seem to align with the approach that is then described in the assessment text.	Volume 5.14.1 provides an assessment of the geographic range of construction noise effects. This has been defined more clearly in the assessment text.
The impact assessment is systematic in applying the selected assessment criteria to evaluate construction and operational effects. There is a minor anomaly concerning the assessment of construction traffic vibration. Although this should be clarified for later assessment stages, it does not affect the result of the PEIR. The locations of noise effects are identified and the magnitudes quantified.	Vibration due to construction traffic cannot be directly assessed. Further, as noted in the PEIR, traffic vibration is typically caused by uneven road surfaces which can be easily rectified.

Draft ES and Supporting Documents

14.1.9 The Draft ES and a large number of the ES supporting documents were provided to a number of statutory and non-statutory bodies over a period of two weeks between 3 and 17 February 2014. This process of engagement (over and above that required by the statutory consultation process) was undertaken to provide an opportunity for these bodies to influence the assessment documents prior to their finalisation to accompany the Development Consent Order (DCO) application.

14.1.10 A summary of the Draft ES representations received (relevant to EIA) and National Grid's responses are summarised at **Volume 5.5.2, Appendix 5C**. A summary of the main Draft ES representations received in relation to noise and vibration are presented in the table below.

Table 14.3 Summary of the Main Noise and Vibration Draft ES Representations Received

Representation	Response
Difficult to distinguish between construction and operational sections of the chapter.	The chapter has been split into parts dealing with construction and operational effects separately. This should significantly aid the reader.

Representation	Response
14.2.24 Describes the 5dB Change method from BS5228. The BS considers significance where the “ total noise (pre-construction ambient plus construction noise) exceeds the pre-construction ambient noise by 5 dB or more ” and not the construction noise only as stated in the text. If this difference is intentional, further explanation is required in justification.	<p>It is expected that noise levels at the vast majority of locations would be significantly below 65dBA. As such, the sum of pre-construction ambient plus construction noise is not expected to be significantly affected by the pre-construction noise. Where the pre-construction ambient noise approaches or exceeds 65dBA, a higher noise limit may be applicable. The 65dB criterion is therefore considered to provide a worst case assessment.</p> <p>This has been made clearer in the text.</p>
Section 4.3 also states that the core working hours will be from 07.00 to 19.00 Mondays to Saturdays and 07.00 and 17.00 on Sundays, but there should be localised additional restrictions near to residential properties. Bristol CC normal restrictions should be used to mitigate construction noise in this location and limit working hours to 08 00 Hours and 18 00 Hours on Mondays to Fridays, 08 00 and 13 00 Hours on Saturdays and at no time on Sundays and Bank Holidays. Joint Councils agreement will be required in respect of working hours, activities within start up and shut down and any departures from these defined activities.	<p>The local authorities and surrounding communities will be informed of known activities that will be undertaken outside of the core working hours. Where advised, consent will be sought under Section 61 of the Control of Pollution Act 1974. A Section 61 is a formal agreement between the contractor and the Local Authority. This agreement is applied for before work commences and allows the contractor and Local Authority to agree, for example noise levels and hours of work.</p>
In area G the route passes near to residential properties at Portview Road, Clayton Street, Queen Street and King Street (LD109-LD113 page 18 of 5.3 draft figure 3.1) but there appears to be no reference in the other documentation as to predicted noise levels from the overhead power cables or noise from the construction phase of the development at the nearby residential the properties.	<p>Table 14.14 (now in Volume 5.14.2, Appendix 14A, Table 3) contains details of the effects of construction in this area. Generic data curves were produced (Volume 5.14.2, Appendix 14F) and were used to identify spans of the overhead line where more detailed modelling of effect was required, due to either proximity of residential properties or low background noise levels. At this stage, some spans with residential receptors within 200m of the overhead line were scoped out of further assessment. These spans are listed in Volume 5.14.2, Appendix 14G.</p>
No provision has been included for noise insulation and temporary rehousing. This should be included as a provision in the CEMP and adopt threshold criteria as outlined within the draft ES text in 14.2.25.	<p>Noise levels and durations required for noise insulation and temporary rehousing are not expected to be reached.</p>

Other Engagement

14.1.11 The engagement with the local planning authorities to discuss noise and vibration has been concise and effective. A meeting was held between the Joint Councils' and National Grid's respective noise and vibration and planning representatives on 13 November 2013. No significant concerns were raised regarding construction and operational noise by the Joint Councils' representatives. A revised assessment methodology for operational noise was discussed and agreed as acceptable. The background noise surveys completed to date were agreed as acceptable and it was agreed that no further surveys were required.

Part 1 – Construction and Decommissioning Noise and Vibration

14.2 Method

Approach

14.2.1 A desk-based assessment has been applied to identify and evaluate the potential noise and vibration effects on receptors arising from the construction of the Proposed Development.

14.2.2 The following information has been used in the assessment:

- Ordnance Survey mapping;
- topographical data;
- previous experience of similar developments elsewhere; and
- on-site noise monitoring data.

14.2.3 In order to produce a robust and conservative assessment, noise levels used for the construction assessment are based on quieter, night time data. These data indicate that daytime noise levels would be low along the majority of the route.

14.2.4 The construction noise assessment uses the construction method statements and noise levels from manufacturers' data or British Standards to determine the noise levels that can be expected at the nearest receptors. The effects of these noise levels have been assessed against the guidelines identified in this chapter and appropriate mitigation measures recommended.

Assessment Guidance

14.2.5 The following documents have been used to assess the noise effects from the construction of the Proposed Development.

National Policy Statements

14.2.6 National Policy Statements (NPS) provide the primary basis on which the Secretary of State is required to make a decision on Nationally Significant Infrastructure projects (NSIPs). The specific assessment requirements for construction noise, as detailed in Overarching NPS for Energy (EN-1), are set out below.

Table 14.4 Summary of NPS EN-1 Requirements Relevant to Construction and Decommissioning Noise and Vibration

Para	Requirement	Section of ES	Compliance Assessment
5.11.4	The applicant should include a description of the noise generating aspects of the development proposal leading to noise impacts, including the identification of any distinctive tonal, impulsive or low frequency characteristics of the noise	Section 14.4 of this Volume	Descriptions of the noise generating aspects of the Proposed Development leading to noise impacts, including the identification of any distinctive tonal, impulsive or low frequency characteristics of the noise are provided in the chapter for both construction and operation noise sources.
5.11.4	The applicant should include identification of noise sensitive premises and noise sensitive areas that may be affected;	Section 14.4 of this Volume	Noise sensitive premises and noise sensitive areas that may be affected have been identified for both construction and operation noise effects.
5.11.4	The applicant should include the characteristics of the existing noise environment	Section 14.3 of this Volume	The chapter and Appendices include a description of the existing noise environment.
5.11.4	The applicant should include a prediction of how the noise environment will change with the proposed development:	See below.	
	> in the shorter term such as during the construction period	Section 14.4 of this Volume, Volume 5.14.2, Appendix 14A, Appendix 14D, Appendix 14G	The chapter and Appendices include a prediction of how the noise environment will change due to construction effects.
	> at particular times of the day, evening and night as appropriate	Section 14.4 of this Volume, Volume 5.14.2, Appendix 14A, Appendix 14D, Appendix 14G	Construction and operational noise effects have been assessed for the periods over which they are expected to have the most significant effect.
5.11.4	The applicant should include an assessment of the effect of predicted changes in the noise environment on any noise sensitive premises and noise sensitive areas	Section 14.4 of this Volume	The chapter includes an assessment of how the noise environment will change due to both construction and operational effects.
5.11.4	The applicant should include measures to be employed in mitigating noise	Section 14.6 of this Volume	The chapter includes measures to be employed in mitigating noise.

Para	Requirement	Section of ES	Compliance Assessment
5.11.4	The nature and extent of the noise assessment should be proportionate to the likely noise impact.	Volume 5.14	The noise assessment presented at Volume 5.14 is considered to be proportionate to the likely noise impact.
5.11.5	The noise impact of ancillary activities associated with the development, such as increased road and rail traffic movements, or other forms of transportation, should also be considered	Section 14.4 and 14.5 of this Volume	The chapter considers the noise impact of ancillary activities associated with the Proposed Development, such as increased road and rail traffic movements, or other forms of transportation.
5.11.6	For the prediction, assessment and management of construction noise, reference should be made to any relevant British Standards and other guidance which also give examples of mitigation strategies.	Section 14.2 of this Volume	Construction noise is predicted and assessed and mitigation is detailed with reference to BS5228:2009.
5.11.7	The applicant should consult EA and Natural England (NE), or the Countryside Council for Wales (CCW), as necessary and in particular with regard to assessment of noise on protected species or other wildlife.	Volume 5.8.1 , section 8.5	All effects on ecological receptors are addressed in Volume 5.8.1 , section 8.5, with technical input from the acoustics and vibration consultants.
5.11.7	The results of any noise surveys and predictions may inform the ecological assessment. The seasonality of potentially affected species in nearby sites may also need to be taken into account.	Volume 5.8.1 , section 8.5	All effects on ecological receptors are addressed in Volume 5.8.1 , section 8.5, with technical input from the acoustics and vibration consultants.

Para	Requirement	Section of ES	Compliance Assessment
5.11.9	<p>The IPC should not grant development consent unless it is satisfied that the proposals will:</p> <ul style="list-style-type: none"> - avoid significant adverse impacts on health and quality of life from noise; mitigate and minimise other adverse impacts on health and quality of life from noise; and where possible, contribute to improvements to health and quality of life through the effective management and control of noise. 	Section 14.4 of this Volume	The chapter demonstrates that significant adverse impacts on health and quality of life from noise will be avoided, mitigated and minimised through the effective management and control of noise.
5.11.12	<p>Mitigation measures may include one or more of the following: engineering: reduction of noise at point of generation and containment of noise generated; lay-out: adequate distance between source and noise-sensitive receptors; incorporating good design to minimise noise transmission through screening by natural barriers, or other buildings; and administrative: restricting activities allowed on the site; specifying acceptable noise limits; and taking into account seasonality of wildlife in nearby designated sites.</p>	Volume 5.8.1 , section 8.7; BMS at Volume 5.26.3 ; section 14.6 of this Volume; Draft CTMP at Volume 5.26.5	The chapter demonstrates that operational noise is controlled and mitigated as far as practicable at source by design and layout and construction noise is controlled by effective administrative and engineering noise control measures.

National Planning Policy Framework

14.2.7 The National Planning Policy Framework (NPPF) (published March 2012) (Ref. 14.2) has replaced the relevant Planning Policy Guidance (PPG 24: Planning and Noise) as the means by which noise is considered within the town and country planning regime. The NPPF does not contain assessment criteria; instead it provides a series of policies, giving local authorities the flexibility necessary to meet

the needs of local communities. The NPPF states that planning policies and decision should aim to:

“avoid noise from giving rise to significant adverse impacts on health and quality of life as a result of new development;

mitigate and reduce to a minimum other adverse impacts on health and quality of life arising from noise from new development, including through the use of conditions;

recognise that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them because of changes in nearby land uses since they were established; and

identify and protect areas of tranquillity which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.”

14.2.8 The NPPF Planning Practice Guidance for noise (March 2014), was published recently to provide a degree of technical grounding to the policies described in the NPPF. The Planning Practice Guidance mirrors much of the policies and guidance introduced in the Noise Policy Statement for England (NPSE, 2010), with the emphasis on avoiding significant adverse effects, and promoting sustainable growth with overall improvement in health and quality of life for the country. These principles form the basis upon which the relevant National Policy Statements (see **Table 14.4**) were written and on which this assessment is founded.

Local Policy

14.2.9 Local planning policies state that developments should seek to avoid or else appropriately mitigate unavoidable harm to environmental amenity. Local planning policy does not set policy for testing the acceptability of nationally significant infrastructure projects and does not add materially to the protection afforded at a national level in respect of noise and vibration.

14.2.10 The majority of local planning policies seek to control the impact of noise. The remaining policies (policy D10 from the Sedgemoor District Council Core Strategy and South Gloucestershire Local Plan saved policy T12), relate to transport, and more particularly ensuring adequate provision for transport is made in development, whilst minimising adverse impacts.

14.2.11 Local planning policies are summarised at **Volume 5.4.2, Appendix 4A.**

British Standards and Guidance Documents

14.2.12 Various British Standard methods for noise assessments have been used in this assessment as follows:

BS5228-1:2009 - Calculation for Noise from Open and Construction Sites - Part 1: Noise

14.2.13 Construction site noise is assessed differently from noise from permanent installations, as it is recognised that the former is an inevitable by-product of required works and its effects are limited in duration.

14.2.14 Advice is contained within BS5228-1 (Ref. 14.3). This document contains a database of the noise emission levels from individual items of equipment and certain activities to allow the prediction of noise from construction (and demolition) works to the nearest noise-sensitive receptors. The prediction method provides guidance on the effects of different types of ground and barrier attenuation and on how to assess the impact of fixed and mobile plant. Whilst not mandatory, Annex E of BS5228 provides informative advice to aid the development of noise assessment criteria based on previous published guidance and methodologies adopted successfully for other planning applications.

14.2.15 In assessing the requirement for noise limits, or operating period controls relating to construction works, Government Agencies and Local Authorities generally give consideration to the following aspects of the planned works, all of which have a bearing on the 'significance' of the effect:

- duration of planned activities (weeks, months, years);
- whether activities are planned for the night time period;
- proximity of development to residential areas; and
- predicted source-term noise levels and noise effects at residential areas.

14.2.16 The assessment predicts noise emissions from various construction activities, which are then compared against baseline ambient noise levels at the location of nearby residential receptors. Noise levels generated by construction activities are significant if the construction noise level exceeds the pre-construction ambient noise by 5dB or more, subject to lower cut-off values as highlighted in **Table 14.5** below, for a duration of one month or more, unless works of a shorter duration are likely to result in significant impact.

Table 14.5 Time Periods, Averaging Times and Noise Levels Applicable Lower Threshold Values of Construction Noise

Day	Relevant Time Period	Averaging Time, T	Lower Cut-Off Value, dB ($L_{Aeq, T}$)
Monday to Friday	07:00 – 19:00	12h	65
	19:00 – 23:00	4h	55
	23:00 – 07:00	8h	45
Saturday	07:00 – 13:00	5h	65
	13:00 – 23:00	10h	55
	23:00 – 07:00	8h	45
Sunday	07:00 – 23:00	16h	55

Day	Relevant Time Period	Averaging Time, T	Lower Cut-Off Value, dB ($L_{Aeq, T}$)
	23:00 – 07:00	8h	45

Note 1) Equivalent continuous A-weighted noise level predicted or measured at a point 1m in front of the most exposed windows or doors leading directly to a habitable room (living room or bedroom) in an eligible dwelling.

14.2.17 Annex E of the standard also provides criteria for the assessment of significance. Exceeding a threshold level triggers a responsibility on the developer to provide noise insulation or a scheme to facilitate temporary rehousing. The standard suggests that noise insulation should be provided if the trigger levels shown in **Table 14.6** are predicted to be exceeded for a period of ten or more days of working in any fifteen consecutive days, or for a total of days exceeding 40 in any six month period.

Table 14.6 Time Periods, Averaging Times and Noise Levels Applicable to Assessing Eligibility for Noise Insulation (Construction Noise)

Day	Relevant Time Period	Averaging Time, T	Noise Trigger Level, dB ($L_{Aeq, T}$)
Monday to Friday	07:00 – 08:00	1h	70
	08:00 – 18:00	10h	75
	18:00 – 19:00	1h	70
	19:00 – 22:00	3h	65
	22:00 – 07:00	1h	55
Saturday	07:00 – 08:00	1h	70
	08:00 – 13:00	5h	75
	13:00 – 14:00	1h	70
	14:00 – 22:00	3h	65
	22:00 – 07:00	1h	55
Sunday & Public Holidays	07:00 – 21:00	1h	65
	21:00 – 07:00	1h	55

Note 1) Equivalent continuous A-weighted noise level predicted or measured at a point 1m in front of the most exposed windows or doors leading directly to a habitable room (living room or bedroom) in an eligible dwelling.

BS5228-2:2009 - Noise and Vibration Control on Construction and Open Sites - Part 2: Vibration

14.2.18 BS5228-2 (Ref. 14.4) describes methods of mitigation that can be employed for ground-borne vibration from construction activities and provides historical library data of vibration levels measured during various activities on various ground types.

14.2.19 **Table 14.7** (Table B.1 from BS5228-2) describes the likely response to various peak particle velocity (PPV) vibration levels.

Table 14.7 Typical Human Responses to Different PPV Levels

Vibration Level	Effect
0.14mms^{-1}	Vibration might just be perceptible in the most sensitive situations for most vibration frequencies associated with construction. At lower frequencies, people are less sensitive to vibration.
0.3mms^{-1}	Vibration might just be perceptible in residential environments.
1.0mms^{-1}	It is likely that vibration of this level in residential environments will cause complaint, but can be tolerated if prior warning and explanation has been given to residents
10mms^{-1}	Vibration is likely to be intolerable for any more than a very brief exposure to this level.

14.2.20 BS5228-2 states transient vibration guide values in the 4Hz – 15Hz and 15Hz and above frequency bands that lead to cosmetic damage. BS5228-2 also discusses the assessment of the vulnerability of ground-related structures and services concluding that a maximum PPV for intermittent or transient vibration of 30mms^{-1} and a maximum PPV for continuous vibration of 15mms^{-1} . BS5228 also discusses the vulnerability of building contents and activities within buildings to vibration, concluding that they too should be assessed on an individual basis.

Calculation of Road Traffic Noise & Design Manual for Roads and Bridges

14.2.21 The ‘Calculation of Road Traffic Noise’ (CRTN) (Ref. 14.5) produced by the Department of Transport and Welsh Office provides a method for the prediction of noise from road traffic. The Highways Agency Design Manual for Roads and Bridges, Volume 11, Section 3, Part 7 HD 213/11 Noise and Vibration (DMRB) (Ref. 14.6), provides guidance on the assessment of noise and vibration effects from road traffic. The criteria from DMRB for short-term effects (i.e. during construction), shown in **Table 14.8**, can be used in the assessment of changes to traffic noise as a result of proposed construction traffic, including heavy vehicles. No significant long term traffic effects (i.e. post development) are expected and are therefore scoped out of further assessment.

Table 14.8 Classification of Magnitude of Noise Effects from Changes to Traffic Noise in the Short-term

Noise Change, $L_{A10, 18 \text{ hour}}$ (dB)	Magnitude of Effect
0.0	No change
0.1 - 0.9	Negligible
1.0 - 2.9	Minor
3.0 - 4.9	Moderate
5.0 or more	Major

14.2.22 An initial review of the data should be undertaken as per the noise assessment to assess whether the traffic effect would be considered negligible (i.e. a change of less than 1dB).

14.2.23 The magnitude of effects described above is used to assess the effect of construction traffic on existing routes. Construction traffic on temporary haul and access routes are assessed as construction noise, as described in **Tables 14.6 and 14.7**.

14.2.24 Within DMRB, change to airborne vibration from traffic is assessed by examining the increases in dB (as air overpressure) and correlating this to a graph relating this change empirically to 'percentage of people bothered' by vibration.

14.2.25 DMRB states that significant ground-borne vibration is unlikely unless sensitive receptors are close to the construction traffic route. The threshold value for scoping ground-borne vibration into more detailed investigation is a Peak Particle Velocity (PPV) of 0.3 mms^{-1} or increases to the PPV if existing vibration levels exceed this level. DMRB does not have a description of how to assess ground-borne vibration.

Background to Construction Noise

14.2.26 Construction noise is assessed differently to noise from permanent installations as it is recognised that construction noise is an inevitable by-product of required works and that construction activities are of temporary operation. Construction noise is considered for activities involved in the Proposed Development, including:

- the decommissioning of the existing 132kV overhead lines;
- the construction of the 400kV overhead line and underground cables;
- construction traffic;
- construction of temporary construction compounds;
- construction of cable sealing end (CSE) compounds;
- construction of substations; and
- the end of life decommissioning of the Proposed Development.

Construction Noise and Vibration Study Areas

14.2.27 The study area for construction noise effects considers all sensitive receptors within 200m of the proposed overhead lines, overhead line decommissioning,

underground cable routes (except cable transition jointing) and substations. The effect of construction noise is expected to be below the lowest threshold criteria for all time periods at this distance. Cable transition jointing would likely require night time working and as such the study area for this activity is 350m, beyond which construction noise is expected to be below the lowest night time threshold where mitigation is applied. Underground cable construction is assessed from the boundary of the Order Limits

- 14.2.28 Due to the complex relationship between the source of vibration, forcing frequency, the distance and geological characteristics between source and receiver and the construction of the receiving structure, it is difficult to predict the degree of vibration which may occur and it is therefore not appropriate to define a study area. However, based on experience, corroborated by data such as that contained in BS5228-2, vibration is not expected to be perceptible beyond 100m. Significant effects would only be expected at much shorter distances (<10m) and is only likely to occur where pylon and substation foundations are being piled. There are no residential dwellings within 10m of proposed pylon and substation construction works.
- 14.2.29 No specific study area is defined for construction traffic noise but is assessed on a road by road basis as determined by the traffic assessment discussed in **Volume 5.12.1** (Traffic and Transport).

Construction Noise Assessment Methodology

- 14.2.30 The assessment of construction noise has been undertaken in accordance with the method presented in BS5228, and is based on the Proposed Development (see **Volume 5.3.1**). **Volume 5.14.2, Appendix 14A, Table 1** is populated by the various construction sites, activities within those sites and the expected (typical) plant to be employed, together with noise emission values taken from BS5228-1.

Decommissioning Noise and Vibration Assessment Methodology

- 14.2.31 As part of the Proposed Development, existing sections of some 132kV overhead lines would be removed. The noise from the decommissioning of these lines is considered within the construction noise and vibration assessment (section 14.4).
- 14.2.32 Decommissioning of the Proposed Development would be undertaken once its useful life is complete. It is expected that the effect of noise and vibration for the decommissioning process would be similar to the construction phase, assuming the decommissioning of the entire connection route, CSE compounds and substations. No separate assessment has therefore been carried out.

Methodology for Assessing the Significance of Construction Noise Effects

Sensitivity

14.2.33 The sensitivities of receptors to construction noise and vibration are shown in **Table 14.9**.

Table 14.9 Sensitivity of Receptor - Construction

Sensitivity of Receptor	Construction Noise	Construction Vibration
High	Education, healthcare facility	Listed buildings & non-earthwork Scheduled Ancient Monuments
Medium	Residential area	Unreinforced or light framed structures
Low	Area used primarily for leisure activities, including Public Rights of Way (PRoW), sports facilities and sites of historic or cultural importance.	Residential or light commercial buildings
Negligible	All other areas such as those used primarily for industrial or agricultural purposes	Reinforced or framed structures Industrial, heavy commercial buildings and earthworks (Scheduled Ancient Monuments)

14.2.34 The sensitivities specified above are the same as those used for the recently consented Hinkley Point C Nuclear Power Station proposal. Further definition of the receptor sensitivities, based on guidance provided by the World Health Organisation (WHO) Guidelines for Community Noise (Ref. 14.7), is provided below:

High Sensitivity

Noise

14.2.35 Receptors have been categorised as high sensitivity where noise may be detrimental to vulnerable subgroups. Such subgroups include pupils in educational facilities and patients in healthcare facilities.

Vibration

14.2.36 Receptors have been categorised as high sensitivity where the receptors are listed buildings or Scheduled Ancient Monuments.

Medium Sensitivity

Noise

14.2.37 Receptors have been categorised as medium sensitivity where noise may cause disturbance and a level of protection is required but a level of tolerance is expected.

Vibration

14.2.38 Receptors have been categorised as medium sensitivity where the structural integrity of the structure is limited but the receptor is not a listed building or Scheduled Ancient Monument.

Low Sensitivity

Noise

14.2.39 Receptors have been categorised as low sensitivity where noise may cause short duration effects in a recreational setting although particular high noise levels may cause a moderate effect.

Vibration

14.2.40 Receptors have been categorised as low sensitivity where the structural integrity of the structure is expected to be high. The level of vibration required to cause damage is very high and such levels are not expected to be reached during the Proposed Development.

Negligible Sensitivity

Noise

14.2.41 Receptors have been categorised as negligible sensitivity where noise is not expected to be detrimental.

Vibration

14.2.42 Receptors have been categorised as negligible sensitivity where vibration is not expected to be detrimental.

Magnitude

14.2.43 The significance of noise and vibration effects from construction was assessed using the criteria defined in **Table 14.10**.

Table 14.10 Magnitude of Construction Effects

Magnitude of Effect	Construction Noise	Construction Vibration
High	Construction noise levels predicted to exceed BS5228 trigger levels to a degree and for a duration triggering noise insulation requirements or temporary re-housing. A 5dB or more change in $L_{A10, 18\text{ hour}}$ traffic noise.	Vibration exceeding threshold values at frequencies likely to be encountered.
Medium	Construction noise levels predicted to exceed BS5228-1 threshold values for a period of one month or more, but not for a level and duration to trigger noise insulation or temporary re-housing requirements. A 3dB - 4.9dB change in $L_{A10, 18\text{ hour}}$ traffic noise.	Vibration effects measurable but below threshold for likely frequencies encountered.

Magnitude of Effect	Construction Noise	Construction Vibration
Low	Noise levels may cause some minor temporary disturbance, but noise levels do not exceed BS5228-1 threshold values for a period of one month or more or for a level and duration to trigger noise insulation or temporary re-housing requirements. A 1dB - 2.9dB change in $L_{A10, 18\text{ hour}}$ traffic noise.	Vibration effects measurable but below threshold of minimum cosmetic damage at all frequencies.
Negligible	Construction noise levels below BS5228-1 threshold levels at a receptor façade. A 0.1dB - 0.9dB change in $L_{A10, 18\text{ hour}}$ traffic noise.	Vibration effects minimal and below threshold of effect.

Significance

14.2.44 A combination of receptor sensitivity and magnitude of effect before and after mitigation was used to determine the overall significance of the effect, as shown in **Table 14.11**.

Table 14.11 Significance of Effects Matrix

Significance of Effect	Sensitivity of Receptor				
	Magnitude	High	Medium	Low	Negligible
High	Major	Major	Moderate	Minor	
Medium	Major	Moderate	Minor	Negligible	
Low	Moderate	Minor	Negligible	Negligible	
Negligible	Minor	Negligible	Negligible	Negligible	

14.3 Baseline Environment

Baseline Characteristics

14.3.1 The Proposed Development would be located within a mixture of rural, urban and industrial areas, which has a correspondingly varied noise environment.

14.3.2 The ambient noise levels in the vicinity of the Proposed Development were predominantly governed by their distance from the M5 Motorway and other main highways.

14.3.3 In order to produce a robust and conservative assessment, noise levels are based on quieter, night time data. These data indicate that daytime noise levels would be

low along the majority of the route. This is concordant with subjective impressions of the noise climate. This assumption leads to a robust, worst case assessment.

14.3.4 The baseline environment would not be expected to change prior to the commencement of the Proposed Development.

14.4 Prediction and Assessment of Significance of the Potential Construction Noise Effects

400kV and 132kV Overhead Line and Underground Cable Route Construction Effects

14.4.1 The distances shown in **Volume 5.14.2, Appendix 14A, Table 2** are the separation distances from the construction activity at which BS5228 would be applicable (i.e. the distance within which threshold levels would be exceeded during the daytime). Transition jointing may involve night time working and has been assessed separately.

14.4.2 Along the proposed route of the 400kV and 132kV overhead lines, threshold values would be exceeded at receptors within 131m of proposed lattice pylons and 108m of proposed T-pylons (where piling is required for foundations). For underground cable works, threshold values would be exceeded at receptors within 82m. For horizontal directional drilling (HDD) works threshold values would be exceeded at receptors within 75m. For the construction of temporary access roads threshold values would be exceeded at receptors within 66m. Threshold values would be exceeded within 112m of pylon decommissioning works. **Volume 5.14.2, Appendix 14A, Table 3** provides a summary of the receptors which fall within these threshold distances for the main construction activities.

14.4.3 Threshold values are unlikely to be exceeded for significant periods (the duration of the works would be less than one month) at each receptor and as such the magnitude of effects is expected to be low. As such, no specific receptors with a major or moderate significance of effect were identified. The exceedance of threshold values would not necessarily lead to a moderate or high magnitude effect unless they occur for significant periods of time as noise is an expected and unavoidable aspect of construction activities. Mitigation measures will be implemented (see section 14.6) to reduce the absolute noise levels likely to be experienced during construction and number of properties where threshold values would be exceeded.

Substation Construction Effects

14.4.4 Construction noise from works at the proposed Sandford Substation and works to the existing Seabank, Portishead, Avonmouth and Churchill Substations is considered in **Table 14.12**.

Table 14.12 Construction Noise Assessment at Substations

Substation	Location	Distance from Substation (m)	Facade Construction Noise Level (dB $L_{Aeq,T}$)	Magnitude of Effect
Sandford Substation	Droveway Farm	200	62dB	Negligible
	The Oaks	230	61dB	Negligible
	Mead Farm	550	53dB	Negligible
Seabank Substation	West House Farm	1200	46dB	Negligible
Portishead Substation	Wren Gardens	40	75dB	Low
Avonmouth Substation	Laurence Weston	800	49dB	Negligible
	Avonmouth Road and surrounding dwellings	600	52dB	Negligible
Churchill Substation	Dwelling on Stock Lane to South East of Site	75	70dB	Low
	Dwelling on Stock Lane to West of Site	400	55dB	Negligible
	Dwellings on to East of Site	240	60dB	Negligible

14.4.5 The time period 'T' corresponds to the averaging time periods specified in Tables 14.5 and 14.6, assuming the activity is occurring for the full period duration for the percentage of time specified in **Volume 5.14.2, Appendix 14A, Table 1**.

14.4.6 Noise from construction activity at Sandford, Seabank and Avonmouth Substations would not exceed BS5228-1 threshold values at nearby receptors and would lead to a negligible magnitude effect. All receptors are of medium sensitivity and the significance of effect is therefore **negligible**.

14.4.7 Construction activity at Portishead and Churchill Substations would occasionally exceed threshold values leading to low magnitude effects. All receptors are of medium sensitivity and the significance of effect is therefore **minor adverse**.

14.4.8 Mitigation and best practice measures will be used to reduce the magnitude of effect (see section 14.6 of this chapter).

Construction Compounds Construction Effects

14.4.9 Threshold values would be exceeded within 79m of construction compound construction works. **Volume 5.14.2, Appendix 14A, Table 4** provides a summary

of the receptors which fall within these threshold distances for the main construction activities.

14.4.10 Noise from the proposed construction activity at construction compounds would exceed threshold values at dwellings close to the Bridgwater Tee (Bath Road), Barton Road, Towerhead Road, Churchill, Nailsea, Church Lane, Cleveson Road and Whitehouse Lane construction compounds, leading to a low magnitude of effect. All receptors are of medium sensitivity and the significance of effect is therefore **minor adverse**.

14.4.11 There are no receptors within the threshold distances at the A38 Bristol Road (UGC), A38 Bristol Road (OHL), South Mendips (Hams Lane), Sandford Substation, AT Route OHL, Engine Lane, Caswell Hill, Sheepway, BW UGC Route West, BW UGC Route East, St Andrews Road, Kings Weston Lane, G Route UGC (East of M49) and Seabank (Severn Road) compounds and therefore the magnitude of effect would be negligible. All receptors are of medium sensitivity and the significance of effect is therefore **negligible**.

14.4.12 Mitigation and best practice measures will be used to reduce the magnitude effect (see section 14.6 of this chapter).

CSE Compounds Construction Effects

14.4.13 Construction noise from works at CSE compounds is considered in Table 14.13.

Table 14.13 Assessment of Noise due to the Construction of CSE Compounds

CSE Compound	Receptor Location	Distance from CSE Compound (m)	Façade Construction Noise Level (dB $L_{Aeq,T}$)	Magnitude of Effect
Bridgwater Tee	Manor Farm	400	55	Negligible
South of Mendip Hills	Riverside Farm	600	52	Negligible

14.4.14 Noise from construction activity at CSE compounds would not exceed threshold values and would therefore be of negligible magnitude for all receptors. All receptors are of medium sensitivity and the significance of effect is therefore **negligible**.

Transition Jointing Pits Construction Effects

14.4.15 Transition Jointing may include works during night time periods. This would occur if works overrun during daytime periods. Works would be required to be continuous to prevent contamination of the site. The noisiest source associated with transition jointing is the angle grinder although this would not typically be used outside of daytime periods. The angle grinding and welding during transition jointing would take place in an enclosed container to prevent contamination. The container is

expected to achieve an insertion loss of approximately 20dB(A). The major source of noise egress is therefore generator noise. The precise location of works within the Order Limits is unknown and would be determined upon appointment of a contractor. Construction noise from Transition Jointing works is considered in **Table 14.14**.

Table 14.14 Construction Noise Assessment at Transition Jointing Pits

Activity	Sound Power Level , dB(A)	Distance (m) At Which Predicted Facade Noise Level Is Below BS5228-1 Threshold Level (Including 20dBA insertion loss):				
		45dB $L_{Aeq,T}$	55dB $L_{Aeq,T}$	65dB $L_{Aeq,T}$	70dB $L_{Aeq,T}$	75dB $L_{Aeq,T}$
Transition jointing	113	860	275	86	49	28

14.4.16 Unmitigated noise from the transition jointing activity would exceed threshold values at distances of up to 860m during night time periods, up to 275m during evening periods and up to 86m during daytime periods. Works in any single location would not be expected to be of a significant duration (less than one month) and as such the magnitude of effect would be low. No specific locations for transition jointing are defined prior to submission of the DCO application but worst case receptors are expected to be of medium sensitivity and the significance of effect is therefore **minor adverse** during daytime periods. However, due to the potential for night time operations, professional judgement dictates that there is the potential for the significance of effect to be **moderate adverse** during night time periods. This is a worst case assessment assuming that the noisiest activities, such as angle grinding, are undertaken at night, which is not expected.

14.4.17 Mitigation and best practice measures will be used to reduce effects (see section 14.6 of this chapter).

Construction Traffic Noise and Vibration Effects

Construction Traffic on Existing Roads

14.4.18 The construction traffic assessment presented in **Volume 5.14.2, Appendix 14B**, **Table 1** provides an assessment of the increase in traffic noise on existing roads based on the CRTN calculation method. Due to the scale of the Proposed Development, construction traffic would be present in different areas during different periods throughout the construction programme. As such, the assessment is based on the total traffic levels with construction traffic data against baseline traffic data for the applicable peak year for each section of road. Baseline data, and therefore the assessment, took account of any predicted increase in traffic due to other local developments.

14.4.19 The predicted increase in traffic noise due to construction traffic is 0dB to 1dB on most affected routes leading to negligible magnitude effects. The A403 St Andrews Road and the Wick to Stalford Road have predicted increases of +2.9dB and +1.8dB respectively, leading to effects of low magnitude.

14.4.20 The increase in traffic noise due to construction traffic would lead to negligible or low magnitude of effects along all existing roads. Receptors are of negligible, low

and medium sensitivity and the significance of effect is therefore **minor adverse** or **negligible**.

Construction Traffic on Temporary Construction Haul and Access Roads

14.4.21 Construction traffic flows on temporary construction haul and access roads are expected to be relatively low. Noise levels for construction traffic on these routes are expected to be lower than the levels for the construction of these routes, which is assessed above and tends towards low and negligible magnitude effects and a significance of effect which is minor adverse or negligible. Construction traffic on temporary haul and access routes is expected to tend towards low and negligible magnitude effects. Receptors are of negligible, low and medium sensitivity and the significance of effect is therefore **minor adverse** or **negligible**.

Construction Traffic Vibration Effects

14.4.22 Vibration from construction traffic would be most likely to be caused by poor road surface on the haul roads which, if determined to have been caused by construction traffic associated with the Proposed Development, could be easily rectified by *ad hoc* road surface repair. On the public highway, vibration is proportional to noise generated and effects would be similar to those generated in **Volume 5.14.2, Appendix 14B, Table 1**. This would tend towards effects of negligible magnitude. Receptors are of negligible, low and medium sensitivity and the significance of effect is therefore **negligible**.

Construction Activity Vibration Effects

14.4.23 Ground-borne and airborne vibration effects have been considered in relation to construction activities. Due to the complex relationship between the source of vibration, forcing frequency, the distance and geological characteristics between source and receiver and the construction of the receiving structure, it is difficult to predict the degree of vibration that may occur.

14.4.24 The level of vibration required to cause structural damage is very high and therefore highly unlikely to be reached during the construction of this Proposed Development.

14.4.25 Airborne vibration would typically be effectively controlled via the mitigation measures to reduce the effect of airborne noise.

14.4.26 Most construction activities are not significant sources of ground-borne vibration. Activities such as earth-working, crane activities and concreting would produce relatively low levels of ground borne vibration. Piling activities could produce perceptible levels of vibration. As such, the magnitude of effect of ground-borne vibration would be negligible to low. Receptors are of negligible, low and medium sensitivity and the significance of effect is therefore **minor adverse** or **negligible**.

Summary of Significance of Construction Noise Effects (No Mitigation)

14.4.27 **Table 14.15** summarises the significance of effects of construction noise before mitigation.

Table 14.15 Significance of Effects of Construction Noise (No Mitigation)

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
400kV overhead line T-pylon construction	All receptors beyond 108m	All	Negligible	Negligible
	Residential receptors within 108m	Medium	Low	Minor adverse
400kV and 132kV overhead line Lattice pylon construction	All receptors beyond 131m	All	Negligible	Negligible
	Residential receptors within 131m	Medium	Low	Minor adverse
Underground cable construction (excluding transition jointing)	All receptors beyond 82m	All	Negligible	Negligible
	Residential receptors within 82m	Medium	Low	Minor adverse
HDD	All receptors beyond 75m	All	Negligible	Negligible
	Residential receptors within 75m	Medium	Low	Minor adverse
132kV overhead line decommissioning	All receptors beyond 112m	All	Negligible	Negligible
	Residential receptors within 112m	Medium	Low	Minor adverse
Sandford Substation	Residential to south	Medium	Negligible	Negligible
Seabank Substation	Residential to east	Medium	Negligible	Negligible
Portishead Substation	Residential to west (Wren Gardens)	Medium	Low	Minor adverse
Churchill Substation	Dwelling on Stock Lane to south east	Medium	Low	Minor adverse
	Other nearby residential	Medium	Negligible	Negligible

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Construction Compounds: Bridgwater Tee (Bath Road) Barton Road Towerhead Road Churchill Nailsea Church Lane Cleveson Road Whitehouse Lane	Residential receptors within 79m	Medium	Low	Minor adverse
Construction compounds: A38 Bristol Road (UGC) A38 Bristol Road (OHL) South Mendips (Hams Lane) Sandford Substation AT Route OHL Engine Lane Caswell Hill Sheepway BW UGC Route West BW UGC Route East St Andrews Road Kings Weston Lane G Route UGC (East of M49) Seabank (Severn Road)	Residential receptors beyond 79m	Medium	Negligible	Negligible
CSE compounds	Other nearby residential	Medium	Negligible	Negligible
Transition jointing (daytime)	Residential receptors within 86m	Medium	Low	Minor adverse

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Transition jointing (worst case night time)	Residential receptors within 860m	Medium	Low to Medium	Minor adverse to moderate adverse
Construction traffic noise on existing roads	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse
Construction traffic noise on temporary routes	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse
Construction traffic vibration	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse
Construction vibration	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse

Route Options

14.4.28 The magnitude of effect of construction noise and vibration is negligible to low and therefore the significance of effect is **negligible to minor adverse** for either preferred route Option A or alternative route Option B.

Decommissioning Effects

14.4.29 The magnitude of noise from decommissioning activities is similar to those for construction with the exception of transition jointing which would not be required. Therefore the levels determined for the preparation of the sites can be used in determining the magnitude of decommissioning effects, leading to negligible to low magnitude effects. The highest sensitivity receptors are medium sensitivity and the significance of effect is therefore **minor adverse** or **negligible**.

Limits of Deviation and Order Limits

14.4.30 The Limits of Deviation (LoD) would provide a necessary and proportionate degree of flexibility as to the final alignment of the works. The LoD identify a maximum distance or measurement of variation within which these works must be constructed. The overhead line LoD are shown at **Volume 5.3.3, Figures 3.1 and 3.2**; the underground cable LoD are shown at **Volume 5.3.3, Figure 3.3**.

14.4.31 The Order Limits, identified in the Proposed Development Plans (see **Volume 5.3.3, Figure 3.1 and 3.2**) as a red outline, are fixed and detail the anticipated maximum extent of land in which the Proposed Development may take place (if approved and subject to DCO Requirements and any other associated commitments).

14.4.32 Further detail as to the level of flexibility that would be afforded by the LoD and the Order Limits and the assessment approach is provided in **Volume 5.5.1, section 5.6**. The implication of the LoD and Order Limits is that some components of the Proposed Development (both temporary and permanent) may be closer or further away from existing receptors than assessed above.

Potential Variation of Significance of Construction Effects

14.4.33 Variation within the LoD, both lateral and longitudinal, was taken into account by the assessment. No change in significance of construction effects is expected due to variation within the LoD or variation within the Order Limits. Due to the relatively short duration (less than one month) of particular noise-generating construction activities affecting individual receptors, the significance of overhead line construction and decommissioning effects would remain **minor adverse** or **negligible**. Underground cable construction is assessed from the boundary of the Order Limits; variation within the Order Limits would not lead to a change in significance for underground cable construction noise and would remain **minor adverse** or **negligible** during daytime periods and remain up to **moderate adverse** for potential worst case night time activities.

14.4.34 Proposed substations (new and modifications/extensions to existing), CSE compounds and construction compounds have been assessed in their positions as shown on the Proposed Development Plans (see **Volume 5.3.3, Figure 3.1 and 3.2**) and as described in **Volume 5.5.1, section 5.6**. As such, these components are afforded no flexibility with regards the Order Limits and the LoD and the significance of effects remains as previously assessed.

Construction Programme Sensitivity Analysis

14.4.35 There may be changes to the construction programme that require a later commencement and/or completion of the Proposed Development (see **Volume 5.5.1, section 5.6**). Variation in the construction program is not likely to affect the duration or level of construction noise exposure at any particular receptor. In some instances variation in the construction programme may result in periods of respite; for example, if underground cable construction works are conducted outside of the winter period. The significance of effects would not differ to that previously assessed.

Climate Change Effects

14.4.36 The effects of construction noise and vibration would not be affected by climate change.

14.5 Inter-relationship of Potential Effects

14.5.1 Noise and vibration is considered in **Volume 5.8.1** (Biodiversity and Nature Conservation) in relation to the effect on fauna. Modelled data for the construction phase includes the predicted sound pressure levels at each badger sett (measurements taken from the entrance closest to the development footprint) and sound pressure levels at various receptors generated by HDD. No data is available to quantify vibration effects on fauna during construction. Whilst in general terms this is not expected to be significant for human receptors; no specific judgement can accurately be made for ecological receptors. Construction noise is unlikely to have a significant effect on species.

14.5.2 Noise and vibration is considered in **Volume 5.15.1** (Socio-economics and Land Use). An amenity effects assessment (see **Volume 5.15.2, Appendix 15J**) has

been undertaken which considers effects arising as a result of the inter-relationship of other environmental effects which together could affect the amenity value of receptors during construction, operation and decommissioning. The assessment has considered likely effects on the amenity various receptors including:

- visitor attractions, PRoW, recreational routes, tourism accommodation and recreational areas; and
- local communities and community facilities (including health, education and community gathering).

14.5.3 Construction and decommissioning noise and vibration are not expected to lead to significant effect on socio-economics and land use.

14.6 Mitigation

General Guidance and Best Practice for Construction Noise Mitigation

14.6.1 The mitigation of construction noise is not always possible. Works will be undertaken in accordance with the Noise and Statutory Nuisance Act 1992 and in accordance with BS5228-1. The following measures will be implemented to reduce effects from noise and vibration from the construction activities of the Proposed Development:

- construction traffic routes would be used in accordance with the Draft CTMP (**Volume 5.26.5**) would be implemented;
- reverse alarms will incorporate at least one of the following features: directional sounders, broadband signals, self-adjusting sounders, and/or flashing warning lights;
- internal haul roads will be well maintained;
- construction work will be undertaken in accordance with Schedule 3, Requirement 7 of the DCO;
- where advised, consent will be sought under Section 61 of the Control of Pollution Act 1974;
- loading and unloading activities will be located as far as reasonably possible from residential properties or screened;
- mains electricity will be used rather than diesel generators where connection to mains electricity is possible;
- exhaust silencing and plant muffling equipment will be fitted and maintained in good working order;
- low-noise generators and quieter plant and equipment will be used and will conform to European standards;
- the bunding (soil stockpiles) and fencing proposed at the construction compounds will also help to attenuate noise;
- vehicles will not wait or queue on the public highway with engines idling;
- engines would be turned off when vehicles are stationary to avoid idling;
- plant and equipment will be shut down when not in use;
- plant and equipment will be started-up sequentially rather than simultaneously;
- the jointing of cables will be undertaken in a covered working area; and
- drop heights of materials will be minimised.

Monitoring

14.6.2 Monitoring will be undertaken in accordance with the Draft CEMP (**Volume 5.26.1**).

14.6.3 Records will be kept of noise and vibration incidents and complaints in accordance with the Draft CEMP (**Volume 5.26.1**). Where non-conformance with the CEMP is found, the incident will be reported and investigated using the Pollution Incident Control Plan as described in the Draft CEMP (**Volume 5.26.1**). Appropriate remedial measures will be implemented.

14.7 Residual Effects

14.7.1 **Table 14.16** summarises the residual significance of effects of construction and decommissioning noise. As described in section 14.6, mitigation of construction noise is not always possible. As such, the residual effects described below assume no additional mitigation is applied.

Table 14.16 Significance of Residual Effects of Construction and Decommissioning Noise

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
400kV overhead line T-pylon construction	All receptors beyond 108m	All	Negligible	Negligible
	Residential receptors within 108m	Medium	Low	Minor adverse
400kV and 132kV overhead line lattice pylon construction	All receptors beyond 131m	All	Negligible	Negligible
	Residential receptors within 131m	Medium	Low	Minor adverse
Underground cable construction (excluding transition jointing)	All receptors beyond 82m	All	Negligible	Negligible
	Residential receptors within 82m	Medium	Low	Minor adverse
HDD	All receptors beyond 75m	All	Negligible	Negligible
	Residential receptors within 75m	Medium	Low	Minor adverse
132kV overhead line	All receptors beyond 112m	All	Negligible	Negligible

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
decommissioning	Residential receptors within 112m	Medium	Low	Minor adverse
Sandford Substation	Residential to south	Medium	Negligible	Negligible
Seabank Substation	Residential to east	Medium	Negligible	Negligible
Portishead Substation	Residential to west (Wren Gardens)	Medium	Low	Minor adverse
Churchill Substation	Dwelling on Stock Lane to south east	Medium	Low	Minor adverse
	Other nearby residential	Medium	Negligible	Negligible
Construction compounds: Bridgwater Tee (Bath Road) Barton Road Towerhead Road Churchill Nailsea Church Lane Cleveson Road Whitehouse Lane	Residential receptors within 79m	Medium	Low	Minor adverse

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Construction compounds: A38 Bristol Road (UGC) A38 Bristol Road (OHL) South Mendips (Hams Lane) Sandford Substation AT Route OHL Engine Lane Caswell Hill Sheepway BW UGC Route West BW UGC Route East St Andrews Road Kings Weston Lane G Route UGC (East of M49) Seabank (Severn Road)	Residential receptors beyond 79m	Medium	Negligible	Negligible
CSE compounds	Other nearby residential	Medium	Negligible	Negligible
Transition jointing (daytime)	Residential receptors within 86m	Medium	Low	Minor adverse
Transition jointing (worst case night time)	Residential receptors within 860m	Medium	Low to Medium	Minor adverse to moderate adverse
Construction traffic noise on existing roads	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse
Construction traffic noise on temporary routes	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse

Construction Activity	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Construction traffic vibration	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse
Construction vibration	Industrial and residential	Low to Medium	Negligible to Low	Negligible to minor adverse

14.8 Cumulative Effects

14.8.1 The cumulative assessment is provided at **Volume 5.17** and includes potential cumulative effects of the Proposed Development together with other major development proposals.

14.8.2 Cumulative construction effects have been considered for all other major developments with regards to noise and vibration. No significant cumulative effects are expected.

14.8.3 No further mitigation measures would be required above those identified in this chapter (section 14.6). The residual cumulative effects would be the same as those identified at section 14.7 above.

14.9 Conclusions

Construction Effects

14.9.1 The assessment of the significance of effects due to construction noise and vibration has concluded that:

- the significance of noise from construction activities (excluding transition jointing) is assessed as being **negligible to minor adverse**;
- due to night time working, the significance of noise from transition jointing may be **moderate adverse**;
- the significance of construction traffic noise and vibration is assessed as being **minor adverse to negligible**; and
- construction vibration is assessed as being **minor adverse to negligible**.

Decommissioning Effects

14.9.2 The significance of decommissioning noise is assessed as being **minor adverse to negligible**.

Part 2 – Operational Noise and Vibration

14.10 Method

Approach

14.10.1 A combination of desk-based and site-based techniques have been employed in the assessment; the objective being to identify and evaluate the potential noise and vibration effects on receptors arising from effects of the operation of the Proposed Development.

14.10.2 The following information has been used in the assessment:

- Ordnance Survey mapping;
- topographical data;
- previous experience of similar developments elsewhere; and
- on-site noise monitoring data.

Assessment Guidance

14.10.3 The following documents have been used to assess the noise effects from the operation of Sandford Substation and 400kV overhead lines.

National Policy Statements

14.10.4 NPSs provide the primary basis on which the Secretary of State is required to make a decision on NSIPs. The specific assessment requirements for noise, as detailed in NPS EN-1 and NPS for Electricity Networks Infrastructure (EN-5) are set out below.

Table 14.17 Summary of NPS EN-1 and EN-5 Requirements Relevant to Operational Noise and Vibration

Para	Requirement	Section of ES	Compliance Assessment
EN-1			
5.11.4	The applicant should include a description of the noise generating aspects of the development proposal leading to noise impacts, including the identification of any distinctive tonal, impulsive or low frequency characteristics of the noise	Section 14.4 of this Volume	Descriptions of the noise generating aspects of the Proposed Development leading to noise impacts, including the identification of any distinctive tonal, impulsive or low frequency characteristics of the noise are provided in the chapter for both construction and operation noise sources.
5.11.4	The applicant should include identification of noise sensitive premises and noise sensitive areas that may be affected;	Section 14.4 of this Volume	Noise sensitive premises and noise sensitive areas that may be affected have been identified for both construction and operation noise effects.

Para	Requirement	Section of ES	Compliance Assessment
5.11.4	The applicant should include the characteristics of the existing noise environment	Section 14.3 of this Volume	The chapter and Appendices include a description of the existing noise environment.
5.11.4	The applicant should include a prediction of how the noise environment will change with the proposed development:	Section 14.4 of this Volume, Volume 5.14.2, Appendix 14A, Appendix 14D, Appendix 14G	The chapter and Appendices include a prediction of how the noise environment will change due to both construction and operational effects
5.11.4	> in the longer term during the operating life of the infrastructure		The chapter and Appendices include a prediction of how the noise environment will change due to operational effects.
5.11.4	> at particular times of the day, evening and night as appropriate		Construction and operational noise effects have been assessed for the periods over which they are expected to have the most significant effect.
5.11.4	The applicant should include an assessment of the effect of predicted changes in the noise environment on any noise sensitive premises and noise sensitive areas	Section 14.4 of this Volume	The chapter includes an assessment of how the noise environment will change due to both construction and operational effects.
5.11.4	The applicant should include measures to be employed in mitigating noise	Section 14.6 of this Volume	The chapter includes measures to be employed to mitigate noise.
5.11.4	The nature and extent of the noise assessment should be proportionate to the likely noise impact.	Volume 5.14.1	The noise assessment presented at Volume 5.14.1 is considered to be proportionate to the likely noise impact.
5.11.5	The noise impact of ancillary activities associated with the development, such as increased road and rail traffic movements, or other forms of transportation, should also be considered	Section 14.4 and 14.5 of this Volume	The chapter considers the noise impact of ancillary activities associated with the Proposed Development, such as increased road and rail traffic movements, or other forms of transportation.

Para	Requirement	Section of ES	Compliance Assessment
5.11.6	Operational noise, with respect to human receptors, should be assessed using the principles of the relevant British Standards and other guidance.	Section 14.2 of this Volume	Operational noise is assessed with reference to Bs4142:1997, BS833:1999 and TR (T)94.
5.11.7	The applicant should consult EA and Natural England (NE), or the Countryside Council for Wales (CCW), as necessary and in particular with regard to assessment of noise on protected species or other wildlife.	Volume 5.8.1 , section 8.6	All effects on ecological receptors are addressed in Volume 5.8.1 , section 8.5, with technical input from the acoustics and vibration consultants.
5.11.7	The results of any noise surveys and predictions may inform the ecological assessment. The seasonality of potentially affected species in nearby sites may also need to be taken into account.	Volume 5.8.1 , section 8.6	All effects on ecological receptors are addressed in Volume 5.8.1 , section 8.5, with technical input from the acoustics and vibration consultants.
5.11.9	The IPC should not grant development consent unless it is satisfied that the proposals will meet the following aims:	Section 14.4 of this Volume	The chapter demonstrates that significant adverse impacts on health and quality of life from noise will be avoided, mitigated and minimised through the effective management and control of noise.
5.11.9	- avoid significant adverse impacts on health and quality of life from noise; mitigate and minimise other adverse impacts on health and quality of life from noise; and where possible, contribute to improvements to health and quality of life through the effective management and control of noise.		

Para	Requirement	Section of ES	Compliance Assessment
5.11.12	<p>Mitigation measures may include one or more of the following: engineering: reduction of noise at point of generation and containment of noise generated; lay-out: adequate distance between source and noise-sensitive receptors; incorporating good design to minimise noise transmission through screening by natural barriers, or other buildings; and administrative: restricting activities allowed on the site; specifying acceptable noise limits; and taking into account seasonality of wildlife in nearby designated sites.</p>	<p>Volume 5.8.1, section 8.7; BMS at Volume 5.26.3; section 14.6 of this Volume; Draft CTMP at Volume 5.26.5.</p>	<p>The chapter demonstrates that operational noise is controlled and mitigated as far as practicable at source by design and layout and construction noise is controlled by effective administrative and engineering noise control measures.</p>
EN-5			
2.9.8 & 2.9.9	<p>While standard methods of assessment and interpretation using the principles of the relevant British Standards¹⁸ are satisfactory for dry weather conditions, they are not appropriate for assessing noise during rain, which is when overhead line noise mostly occurs, and when the background noise itself will vary according to the intensity of the rain. Therefore an alternative noise assessment method to deal with rain-induced noise is needed, such as the one developed by National Grid as described in report TR(T)94, 1993</p>	Section 14.2 of this Volume	<p>An assessment methodology based on the principles of BS41442:1997 and TR(T)93 has been used to assess noise from 400kV overhead lines during wet conditions.</p>
2.9.12	<p>Applicants should have considered the following measures:</p>	See below	

Para	Requirement	Section of ES	Compliance Assessment
	> The positioning of lines (see Section 2.8 (landscape/visual impact)) to help mitigate noise;	Volume 5.2.1	The alignment has been selected to minimise the effects of noise as far as practicable.
	> Ensuring that the appropriately sized conductor arrangement is used to minimise potential noise;	Embedded mitigation and further mitigation measures are provided at section 14.6 of this Volume	Twin Redwood, the proposed conductor for the majority of the Proposed Development is the quietest twin conductor system that National Grid currently operates.
	> Quality assurance through manufacturing and transportation to avoid damage to overhead line conductors which can increase potential noise effects; and		Quality assurance through manufacturing and transportation will be undertaken to avoid damage to overhead line conductors which can increase potential noise effects.
	> Ensuring that conductors are kept clean and free of surface contaminants during stringing/installation.		Care will be taken during installation to ensure that conductors will be kept clean and free of surface contaminants during stringing. This will minimise the risk of excessive dry noise on energisation of the proposed 400kV overhead line.
2.9.13	The ES should include information on planned maintenance arrangements.	Volume 5.3.1 , section 3.7	The ES includes information on planned maintenance arrangements.

EN-5

14.10.5 In respect of potential noise effects, the NPS for Electricity Networks Infrastructure, EN-5 (EN-5), (Ref. 14.8) recognises that:

“All high voltage transmission lines have the potential to generate noise under certain conditions.”

EN-5. Paragraph 2.9.2

In addition,

“Audible noise effects can also arise from substation equipment such as transformers, quadrature boosters and mechanically switched capacitors...Noise may also arise from discharges on overhead line fittings such as spacers, insulators and clamps”.

EN-5. Paragraph 2.9.7

National Planning Policy Framework

14.10.6 The National Planning Policy Framework (NPPF) (published March 2012) (Ref. 14.2) has replaced the relevant Planning Policy Guidance (PPG 24: Planning and Noise) as the means by which noise is considered within the town and country planning regime. The NPPF does not contain assessment criteria; instead it provides a series of policies, giving local authorities the flexibility necessary to meet the needs of local communities. The NPPF states that planning policies and decision should aim to:

“avoid noise from giving rise to significant adverse impacts on health and quality of life as a result of new development;

mitigate and reduce to a minimum other adverse impacts on health and quality of life arising from noise from new development, including through the use of conditions;

recognise that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them because of changes in nearby land uses since they were established; and

identify and protect areas of tranquillity which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.”

14.10.7 The NPPF Planning Practice Guidance for noise (March 2014), was published recently to provide a degree of technical grounding to the policies described in the NPPF. The Planning Practice Guidance mirrors much of the policies and guidance introduced in the NPSE, with the emphasis on avoiding significant adverse effects, and promoting sustainable growth with overall improvement in health and quality of life for the country. These principles form the basis upon which the relevant National Policy Statements (see **Table 14.17**) were written and on which this assessment is founded.

Local Policy

14.10.8 Local planning policies state that developments should seek to avoid or else appropriately mitigate unavoidable harm to environmental amenity. Local planning policy does not set policy for testing the acceptability of nationally significant infrastructure projects and does not add materially to the protection afforded at a national level in respect of noise and vibration.

14.10.9 The majority of local planning policies seek to control the impact of noise. The remaining policies (policy D10 from the Sedgemoor District Council Core Strategy and South Gloucestershire Local Plan saved policy T12), relate to transport, and more particularly ensuring adequate provision for transport is made in development, whilst minimising adverse impacts.

14.10.10 Local planning policies are summarised at **Volume 5.4.2, Appendix 4A**.

British Standards and Guidance Documents

14.10.11 Various British Standard methods for noise assessments have been used in this assessment as follows:

BS7445: 2003 - Description and Measurement of Environmental Noise - Guide to Quantities and Procedures

14.10.12 BS7445 (Ref. 14.9) provides the framework within which environmental noise should be quantified. Part 1 provides a guide to quantities and procedures and Part 2, a guide to the acquisition of data pertinent to land use. Part 3 provides a guide to the application of noise limits. The standard also refers to BS EN 61672, which prescribes the equipment necessary for such measurements.

BS4142: 1997 - Method for Rating Industrial Noise Affecting Mixed Residential and Industrial Areas

14.10.13 BS4142 (Ref. 14.10) provides a method for assessing industrial noise against ambient background noise levels. A 'rating penalty' of 5dB is added to the industrial noise if it contains characteristics that are likely to increase the potential for it to cause annoyance. Such characteristics could include impulses e.g. bangs/crashes or tonal components e.g. hums and whistles.

14.10.14 Comparison of the difference between the industrial noise level including any rating penalty (the rating level) and the background noise level indicates the likelihood of complaint. The greater the difference, the greater the likelihood of complaints arising.

- a difference of around +10dB or more indicates that complaints are likely;
- a difference of around +5dB is of marginal significance; and
- if the rating level is more than 10dB below the measured background then this is a positive indication that complaints are unlikely.

14.10.15 BS4142 is general in character and does not cover all situations. Section 1 (Scope) of BS4142 states: "*The method is not suitable for assessing the noise measured inside buildings or when the background and rating levels are both very low*". A note to Section 1 states: "*For the purposes of this standard, background noise levels below about 30dB and rating levels below about 35dB are considered to be very low*".

TR(T)94, 1993

14.10.16 TR(T)94, 1993 (Ref. 14.11) is an internal National Grid report, referenced in EN-5, describing a method to assess the potential effects of dry and rain-induced noise from new overhead lines. TR(T)94 does not set specific noise assessment criteria; instead it refers to BS4142 and the subjective response of communities and individuals to changes in noise levels.

Background to Operational Substation Noise

14.10.17 There are three basic sources of audible noise from substations. Each of these has its own characteristic frequency spectrum and pattern of occurrence due to the nature of the noise-generating mechanisms involved:

14.10.18 Transformer and shunt reactor noise is practically constant, with a low frequency hum occurring at exact harmonics of the supply frequency; 100Hz and 200Hz components are usually dominant. Transformers generally run continuously except for occasional maintenance and fault outages. The shunt reactors proposed for the Proposed Development would also be in service for the majority of the time. Transformer and shunt reactor coolers typically emit a broadband noise; however, their operation depends on temperature and loading.

14.10.19 Switchgear noise is generated, in the main, by the operation of circuit breakers, for which the noise emissions are 'impulsive' in character (i.e. of short duration). Switchgear operations would be very infrequent. Modern switchgear of the Sulphur Hexafluoride (SF_6) type operates with a dull 'thud'.

14.10.20 Substation auxiliary plant comprises standby diesel generators and air compressors to provide emergency back-up power to cooling plant. When present and operating, these may contribute to the broadband noise climate. They do not run continuously, and in any case, are housed in a building or outdoor acoustic enclosure. Noise from such assets, if installed at the substation, is seldom discernible beyond the substation perimeter fence.

Background to 400kV Overhead Line Noise

14.10.21 The proposed 400kV sections of overhead line would be of a twin bundle conductor system, which would be in continuous operation except for maintenance and fault outages. 400kV transmission lines of twin conductor bundle construction can produce audible noise under certain conditions. Conductor system noise occurs when the conductor surface electrical stress exceeds the inception level for corona discharge activity, a level of around 17-20kV/cm. Most transmission line conductors are designed to operate below this threshold, and so usually operate quietly in dry weather conditions. The typical electrical stress on twin Redwood conductor systems (on standard pylons or the T-pylon), as proposed for the major part of the Proposed Development, is well below 15kV/cm in ideal operating conditions and twin Redwood is the quietest twin conductor system that National Grid currently operates. However, small areas of surface contamination on conductors, spoiling the otherwise smooth conductor surface, would cause a local enhancement of electrical stress which may be sufficiently high to initiate localised discharge activity. At each discharge site a limited electrical breakdown of the air occurs. A portion of the energy associated with the corona process is released as acoustic energy which radiates into the air as sound pressure waves.

14.10.22 The highest noise levels generated by a 400kV line generally occur during and soon after periods of rainfall. Water droplets may accumulate on the surface of the conductor and initiate multiple corona discharges. The number of droplets, and the resultant noise level, would depend primarily on the rate of rainfall. Fog may also give rise to increased noise levels, although these levels will be less than those during rain. Noise generated under these circumstances is referred to as 'wet noise'. However, some of the effect of this increased noise is masked by increased ambient noise due to rainfall (either directly due to raindrops falling on hard surfaces or nearby foliage, or indirectly due to increased vehicle tyre/road interaction noise on local wet roads).

14.10.23 Similarly, after a prolonged spell of dry weather, without heavy rain to wash the conductors, contamination may accumulate sufficiently to result in increased noise. Under these circumstances, the noise is referred to as 'dry noise'. During the next occurrence of heavy rain, these discharge sources are washed away and the line would resume its normal quieter operation.

14.10.24 The level of operational noise from overhead lines falls quickly with distance from the overhead line.

14.10.25 Anecdotal evidence received by National Grid over the years suggests that levels of audible noise from overhead lines can be higher in the first few months of operation as the conductors undergo a "weathering in" process. This chapter assesses the noise impacts after this weathering in process has taken place.

Study Areas

14.10.26 The study area for substation operational noise at Sandford considers all sensitive receptors within 800m of the proposed substation site so that all of the nearest sensitive receptors were assessed.

14.10.27 The substations at Seabank, Churchill, Portishead and Avonmouth are scoped out the assessment as they contain no new material sources of noise. Further information is given in **Volume 5.14.2, Appendix 14C**.

14.10.28 The study area for overhead line operational noise extends to 200m from the proposed centre line. Based on at least 50 years of experience operating the UK transmission network at 400kV, there is no significant audible noise effect beyond this distance, even in the most sensitive of locations, for the type of conductor system that would be used in the Proposed Development.

Operational Phase Assessment Methodologies

Operational Substation Noise

Seabank Substation

14.10.29 The Proposed Development at the existing Seabank Substation includes the addition of switchgear and auxiliary plant, and the removal of an existing transformer. Since substation noise is dominated by transformer noise at this location, the Proposed Development would have an overall noise benefit and therefore operational noise associated with Seabank Substation is scoped out of further assessment. Further information is given in **Volume 5.14.2, Appendix 14C**.

Churchill, Portishead and Avonmouth Substations

14.10.30 The Proposed Developments at the existing Churchill, Portishead and Avonmouth Substations would contain no new material sources of noise and as such operational noise is scoped out of further assessment. Further information is given in **Volume 5.14.2, Appendix 14C**.

Sandford Substation

14.10.31 The proposed new development at Sandford Substation would comprise transformers, shunt reactors, switchgear and auxiliary plant. The predominant

noise source at this site would be the transformers and shunt reactors and their associated coolers, and these are all included in the assessment of the site.

Substation Maintenance

14.10.32 The substations will be unmanned under normal operating conditions. Routine maintenance would require occasional site visits by staff, and would not lead to a noticeable increase in traffic movements. Routine maintenance activities do not create sources of noise that would be audible beyond the substation fence. On this basis, audible noise from substation maintenance has been scoped out of further assessment.

Operational Substation Noise Assessment Methodology

14.10.33 A desk-based assessment of sensitive receptors close to the proposed Sandford Substation site has been undertaken, by the use of aerial photography available from Google Maps and Intergraph Geomedia mapping software.

14.10.34 Modelling of operational noise at Sandford Substation has been undertaken using CadnaA noise modelling software, which incorporates prediction methodology within ISO 9613: 1993 'Acoustics - Attenuation of sound during propagation outdoors, Part 2: 'General method of calculation'. The ISO 9613-2 method predicts a long-term equivalent continuous A-weighted sound pressure level (L_{Aeq}) under meteorological conditions favourable to propagation at distances from a variety of sources of known emission. Details, including input parameters, of the noise prediction modelling study for the proposed Sandford Substation are provided in **Volume 5.14.2, Appendix 14D**.

14.10.35 The model assumes downwind propagation, irrespective of prevailing wind direction, within +/- 45 degrees of direction connecting dominant source and receiver, wind speeds between 1m/s and 5m/s at heights between 3m and 11m above the ground.

14.10.36 The CadnaA model includes transformers and shunt reactors, and where appropriate, their coolers. The modelled sound emission levels (at receivers) include a +5dB penalty to account for the tonal element of this type of equipment, in accordance with the recommendations of BS4142. Due to the infrequent nature of operation the CadnaA model does not include switchgear or auxiliary plant noise.

14.10.37 The model has been used to assess the free field (excluding façade reflections) L_{Aeq} levels at positions representative of the external facades of residential receptors. No façade correction was applied in these calculations as the background noise measurements were free field.

14.10.38 Background noise survey results have been used to determine residential receptors likely to be most affected by noise from the Sandford Substation (whether as a result of proximity or existing background noise level). Attended five minute noise surveys were undertaken during the night-time, to represent the quietest exposure period to provide a conservative assessment (see **Volume 5.14.2, Appendix 14E**).

14.10.39 Measurements were taken in accordance with relevant measurement standards and equipment was calibrated in accordance with the manufacturers' instructions.

14.10.40 Where 'very low' (below 30dB L_{A90}) background noise levels were measured, a Proposed Development specific assessment (based on the methodology of BS4142) which compares a rating level (including a +5dB penalty where applicable) to a minimum background level of 30dB L_{A90} was followed. Background noise levels were measured during worst case, quiet night time periods. This ensured a conservative assessment outcome at these locations. Where relevant, alternative criteria, such as those based on WHO guidelines (Ref. 14.7), and British Standard BS8233:1999 Sound insulation and noise reduction for buildings - Code of practice (BS8233) (Ref. 14.12), were considered.

400kV Overhead Line Operational Noise

400kV Overhead Line Noise Assessment Methodology

14.10.41 A desk-based assessment of sensitive receptors within at least 200m of the proposed overhead line route has been undertaken, taking into account the LoD, by the use of aerial photography available from Google Maps and Intergraph Geomedia mapping software.

14.10.42 Background noise surveys, comprising attended five and 15 minute measurements at locations representing residential receptors located along the proposed route have been undertaken during the night, to represent the quietest exposure period (see **Volume 5.14.2, Appendix 14E**). These results were used to inform the analysis of likely effects from the overhead line.

14.10.43 Calculations of dry corona noise for the proposed overhead line conductors were based on data from existing overhead lines, with appropriate correction factors for pylon design and conductor wire configurations, as per the method in TR(T)94.

14.10.44 A Proposed Development specific methodology based on the principles of BS4142 was used to assess overhead line noise occurring in dry weather conditions. A difference in the sound pressure at a receptor compared to background noise levels of +10dB or more means complaints would be likely, whereas a difference of around +5dB means the likelihood would be marginal. For assessment levels below +5dB, the lower the value, the lower the likelihood of complaints, and a -10dB assessment level is a positive indication that complaints would be unlikely.

14.10.45 The methodology for assessing noise generated by overhead line conductors in wet weather conditions differs (due to the increase in background noise due to rainfall). The detailed methodology of TR(T)94 produces a weighted average increase in total sound pressure levels over a range of likely background noise levels due to rainfall, with the typical rainfall rates given the highest weighting. The greatest difference between noise levels with and without overhead line noise occur at rainfall rates of 1mm/hr, since at this level the methodology adds an additional tonal penalty of 5dB is added to line noise to account for hum inception. Using the predicted sound emission rate in wet conditions (based on the TR(T)94 method assessing conductor type and configuration, and assuming a 1mm/hr intensity rainfall), and a typical background noise level during rain, adoption of the BS4142 methodology can be considered appropriate, and is likely to produce a conservative assessment.

14.10.46 Generic data curves were produced (**Volume 5.14.2, Appendix 14F**) and were used to identify spans of the overhead line where more detailed modelling of effect was required, due to either proximity of residential properties or low background

noise levels. At this stage, some spans with residential receptors within 200m of the overhead line, taking into account the LoD, were scoped out of further assessment. These spans are listed in **Volume 5.14.2, Appendix 14G**.

14.10.47 The predicted conductor sound power levels (wet and dry) from TR(T)94 calculations for each overhead line design was then manually adjusted using measured octave curves for the observed 'crackle' (dry) or 'hum' (wet). These octave sound power data were then used as input data to detailed noise propagation models, using CadnaA noise modelling software. The prediction methodology within ISO 9613-2: 1993 was used to predict long-term equivalent continuous A-weighted sound pressure levels (L_{Aeq}) at the identified dwellings to each 'scoped-in' overhead line span (spans with residential receptors within 200m where more detailed modelling was considered appropriate). Details, including input parameters, of the noise prediction modelling study for the assessed (scoped-in) spans are provided in **Volume 5.14.2, Appendix 14G**.

14.10.48 The models assume downwind propagation, within +/- 45 degrees of direction connecting dominant source and receiver, and wind speeds between 1m/s and 5m/s at heights between 3m and 11m above the ground.

14.10.49 In order to assess the potential effects of noise during wet conditions, the measured background levels were corrected using the 'Miller Curves' (Ref. 14.13) presented in TR(T) 94 which take account of the terrain/ground around the receptor being assessed, to produce a likely background noise level due to the effect of rainfall. These calculations assumed a typical Miller Curve "Type 2", which estimated the sound levels due to rainfall as 41dB at a rainfall rate of 1mm/hr, and was considered to be a conservative estimate of the likely background noise due to rainfall over the whole Proposed Development area.

14.10.50 The model has been used to assess the free field L_{Aeq} sound levels at positions representative of the external facades of residential receptors. No façade correction was applied in these calculations.

132kV Overhead Line Operational Noise

14.10.51 Electrical stresses on 132kV overhead line conductors are generally much lower than those on 400kV overhead lines in normal operation, and as such, are below the thresholds for audible noise inception. These types of overhead lines are practically quiet in operation. Therefore, operational audible noise from any of the proposed 132kV sections of overhead line is scoped out of any further assessment.

Operational Noise from Underground Cables and CSE Compounds

14.10.52 Underground cables and CSE compounds are practically quiet in operation. Operation noise from this equipment is therefore scoped out of further detailed analysis.

Overhead Line Maintenance

14.10.53 Routine maintenance for overhead lines includes visual and infrared inspection by helicopter one or two times per year. If further work is required, components of overhead line pylons and conductors will be accessed by Mobile Elevated Working

Platforms. Maintenance activities are considered to have less effect (typically of lower magnitude and shorter duration) than construction activities and are therefore scoped out of further assessment.

Operational Vibration, Substations and Overhead Lines

14.10.54 The operation of substations and overhead lines will not generate significant levels of vibration and therefore operational vibration effects have been scoped out from further assessment.

Methodology for Assessing the Significance of Operational Noise Effects

Sensitivity

14.10.55 Residential properties are assessed as being noise sensitive, although developments such as hospitals and schools also contain receptors that are potentially noise sensitive. It is therefore appropriate to determine sensitivity on a case by case basis at a local level. The WHO guidelines do offer some comment on degrees of sensitivity, identifying 'vulnerable subgroups' such as those suffering from particular medical conditions. Taking this into account, the sensitivity scale shown in **Table 14.18** has been developed.

Table 14.18 Sensitivity of Receptor – Operational Noise

Sensitivity of Receptor	Receptor Description
High	Patients in hospitals/hospices etc. – defined as a "vulnerable subgroup" with very high or continuous rates of occupancy
Medium	Residential receptors
Low	Area used primarily for leisure activities, including PRoW, sports facilities and sites of historic or cultural importance
Negligible	All other areas such as those used primarily for industrial or agricultural purposes

14.10.56 The sensitivities specified above are identical to those used for the recent Hinkley Point C Nuclear Power Station proposal. Further definition of the receptor sensitivities, based on guidance provided by the WHO Guidelines for Community Noise (Ref. 14.7), is provided below for operational noise:

High Sensitivity

14.10.57 Receptors have been categorised as high sensitivity where noise may be detrimental to vulnerable subgroups. Such subgroups include pupils in educational facilities and patients in healthcare facilities.

Medium Sensitivity

14.10.58 Receptors have been categorised as medium sensitivity where noise may cause disturbance and a level of protection is required but a level of tolerance is expected.

Low Sensitivity

14.10.59 Receptors have been categorised as low sensitivity where noise may cause short duration effects in a recreational setting although particular high noise levels may cause a moderate effect.

Negligible Sensitivity

14.10.60 Receptors have been categorised as negligible sensitivity where noise is not expected to be detrimental.

14.10.61 No receptors within the ‘vulnerable subgroups’ categories in the Sandford Substation or the 400kV overhead line study areas have been identified, taking into account the LoD. Analysis in this report is therefore based upon receptors classified as having medium or low sensitivity.

Magnitude

14.10.62 The magnitude of effect is based upon noise predictions that were undertaken. However, since the noise predictions are based on reasonable worst case assumptions, it would be inappropriate to conclude a high magnitude of effect simply because a certain threshold (e.g. the assessment level) is exceeded. The amount by which a threshold is exceeded, along with the duration of effect should also be taken into account. The apportionment of a magnitude rating has therefore taken this situation into account by applying professional judgement.

14.10.63 A Proposed Development noise assessment of the rating level compared to background noise level was adopted for overhead line dry and wet noise, as well as noise generated by the proposed Sandford Substation. This is consistent with the principles of BS4142, and is conservative when used in situations where the background noise levels are ‘very low’ (as defined by BS4142). For background noise levels below 30dB, and therefore out of scope of BS4142, a minimum background level of 30dB was assumed. The implication of this is that rating levels lower than 30dB are therefore categorised as having no greater than a low magnitude of effect. In absolute terms, a noise level of 30dB is significantly below the recommended values for external and subsequent internal amenity (taking into account attenuation through an open window) stated by British Standard BS8233:1999 and the WHO Guidelines for Community Noise during both daytime and night time periods. Furthermore, background noise surveys were conducted during quiet night time periods and as such represented a worst case assessment. The magnitude of effect during daytime periods is therefore expected to be lower.

14.10.64 The assessment criteria for the magnitude of effect of operational noise are shown in **Table 14.19**.

Table 14.19 Magnitude of Operational Effects

Magnitude of Effect	Operational Noise - Substation or Overhead Line - Dry and Wet Noise
High	Predicted rating levels are 5dB or more above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)

Magnitude of Effect	Operational Noise - Substation or Overhead Line - Dry and Wet Noise
Medium	Predicted rating levels are between 5dB and 0dB above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Low	Predicted rating levels are between 0dB and 5dB below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Negligible	Predicted rating noise levels are between 5dB and 10dB below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
No effect	Predicted rating noise levels are 10dB or more below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)

14.10.65 The above criteria are based on the assessed levels during the quietest night-time hours, when people are likely to be sleeping. In addition, the levels assessed are free-field calculations (assuming no sound reflections other than from the ground) of external levels, and take no account of building attenuation effects to predict levels inside residential dwellings. As such, the above criteria are considered to be conservative.

Significance

14.10.66 A combination of receptor sensitivity and magnitude of effect before and after mitigation was used to determine the overall significance of the effect, as shown in **Table 14.20**.

Table 14.20 Significance of Effects

Significance of Effect	Sensitivity of Receptor				
	Magnitude	High	Medium	Low	Negligible
High	Major	Major	Moderate	Minor	
Medium	Major	Moderate	Minor	Negligible	
Low	Moderate	Minor	Negligible	Negligible	
Negligible	Minor	Negligible	Negligible	Negligible	
No effect	Negligible	Negligible	Negligible	Negligible	

14.10.67 The above significance criteria are based on the assessment at locations representing the external façade of properties, and as such there will be a correspondingly lower assessment when attenuation of buildings is taken into account.

14.11 Baseline Environment

Noise Survey Results

- 14.11.1 Attended five-minute spot measurements were taken in the vicinity of Sandford Substation during the early hours of 16 February 2013, and along the proposed overhead line route in the early hours of 27 May, 19 June and 21 August 2013. Further attended 15-minute spot measurements were taken along the proposed overhead line route in the early hours of 16 October 2013.
- 14.11.2 Night-time background levels, $L_{A90,5\text{min}}$ were between 27.9 and 31.4dB in the vicinity of Sandford Substation, and varied along the overhead line route between 28.1dB and 46.8dB. The measurements along the overhead line route in particular were affected by their proximity to the M5 Motorway and industrial areas around Avonmouth.
- 14.11.3 The measurements were all taken in the early hours of the morning, when weather conditions were fine, with little wind, and are considered representative of the likely quietest background conditions. Details of all measurements including locations and dates/times are provided in **Volume 5.14.2, Appendix 14E**.

Baseline Characteristics

- 14.11.4 The Proposed Development would be located within a mixture of rural, urban and industrial areas, which would have a correspondingly varied noise environment. While much of the development is in a rural environment, measured noise levels close to sensitive receptors were considered typical of those likely to be influenced by nearby existing noise sources such as motorways and existing industrial facilities.
- 14.11.5 The ambient noise levels in the vicinity of the Proposed Development were predominantly governed by their distance from the M5 Motorway and other main highways.
- 14.11.6 The baseline environment would not be expected to change prior to the commencement of the Proposed Development.


14.12 Prediction and Assessment of Significance of the Potential Operational Noise Effects

Sources of Operational Noise

Sandford Substation Operational Effects

14.12.1 Modelling of the operational noise effects from the proposed Sandford Substation was undertaken using CadnaA software (see **Volume 5.14.2, Appendix 14D**). **Inset 14.1** below shows the, night time CadnaA noise model.

Inset 14.1: Proposed Sandford Substation Night Time Noise Propagation Model



14.12.2 Transformers and shunt reactors would be in service 24 hours a day, except during maintenance periods. The overnight period has been modelled as substation noise would be likely to have the most effect when background noise levels in the surrounding area are at their lowest, and also when people are sleeping. Overnight, transformer loading would be reduced, so it is unlikely that transformer coolers would be operating at this time. Shunt reactors however would be at full load at all times, so continuous operation of their coolers has been assumed. A +5dB penalty was applied for the tonality of the noise sources. The transformers and shunt reactors will be specified (likely to be with acoustic enclosures) as part of

their inherent design to meet a specified rating level at the nearest residential receptors to the substation.

14.12.3 The analysis of substation noise is provided in **Table 14.21**.

Table 14.21 Sandford Substation Operational Noise

Receptor Name	Background Noise Level, dB L_{A90}	Rating Level, dB	Assessment Level, dB	Magnitude of Effect
Droveway Farm	30	27	-3	Low
The Oaks	30	25	-5	Negligible
Mead Farm	30	20	-10	No effect
Birchwood House	30	20	-10	No effect
Dorvic	30	20	-10	No effect
Meadow Croft	30	19	-11	No effect

14.12.4 The above assessment levels represent the free field L_{Aeq} levels at positions representative of the external facades of properties. Internal levels at properties would be lower.

14.12.5 Results indicate that the magnitude of operational noise is of low, negligible or no effect at all receptors. The highest sensitivity receptors are medium sensitivity and the significance of effect is therefore **minor adverse** or **negligible**.


400kV Overhead Line Operational Effects

Medium and High Sensitivity Receptors

14.12.6 There are no high sensitivity receptors, such as schools or healthcare facilities, within the study area of operational 400kV overhead line noise. The assessment therefore considers medium sensitivity residential receptors.

14.12.7 The results of the analysis are shown in **Tables 14E.4 in Volume 5.14.2, Appendix 14G**. **Inset 14.2** below shows an example of the CadnaA noise model of overhead line noise.

Inset 14.2: Example CadnaA 400kV Overhead Line Noise Assessment Model



14.12.8 The receptors where there is there may be a major or moderate significance of effect (i.e. operational noise with a magnitude effect of medium or high for receptors of medium sensitivity) were identified and are set out in **Table 14.22**.

Table 14.22 Assessment of Predicted Dry and Wet Noise from Overhead Lines Based on CadnaA Noise Propagation Model

Receptor Ref.	Receptor Name	Section	Predicted Assessment Level, dB (Including 5dB Acoustic Character Correction)		Magnitude of Effect	
			Dry	Wet	Dry	Wet
33	Flat above Garage (Tarnock)	B	-6.8	+2.5	Negligible	Medium
34	Tarnock Cottage	B	-8.8	+0.4	Negligible	Medium
39	Moorland Park	D	-9.1	+1.2	Negligible	Medium
69	Star Inn	D	+0.6	+4.9	Medium	Medium

14.12.9 The above numbers are assessed at locations representative of the external facades of properties.

14.12.10 Results indicate that the magnitude of 400kV overhead line operational noise is low or negligible or would have no effect at the majority of receptors. All receptors are of medium sensitivity and the significance of effect is therefore **minor adverse**, or **negligible** for both dry and wet conditions.

14.12.11 During dry conditions the magnitude of 400kV overhead line operational noise is medium at the Star Inn which is classed as a medium sensitivity receptor; the significance of effect is therefore **moderate adverse**.

14.12.12 During wet conditions the magnitude of 400kV overhead line operational noise is medium at the flat above garage (Tarnock), Tarnock Cottage, Moorland Park and the Star Inn. All receptors are of medium sensitivity and the significance of effect is therefore **moderate adverse**.

14.12.13 The above assessment is based on magnitudes of effect during night time periods when background noise levels are expected to be around their lowest level. The significance is expected to be **minor adverse** to **negligible** during daytime periods.

14.12.14 Rainfall data provided by the Met Office indicates that in this area, wet weather conditions would be likely to occur around 7% of the year (2012 data).

14.12.15 It should be noted that the dry noise level at The Star Inn is calculated as an L_{Aeq} of 30.6dB. WHO Night Noise Guidelines (Ref. 14.14) give average $L_{night,outside}$ of 30dB as the level at which there is no observable effect. Levels of 30-40dB are observed to only give modest effects, $L_{night,outside}$ of 40dB is quoted as the Lowest Observable Adverse Effect Level. Against these criteria, professional judgement dictates that the significance of operational 400kV overhead line noise is **minor adverse** to **negligible**.

Low and Negligible Sensitivity Receptors

14.12.16 The route of the proposed 400kV overhead line is in the vicinity or crosses a number of areas used primarily for leisure activities, such as PRoW and nature reserves, as well as industrial and agricultural land. The magnitude of effect may be medium or high during particularly quiet or wet periods in areas close to or under the 400kV overhead lines and the effect will dissipate quickly with increased distance. Furthermore, during daytime periods when the above receptors are likely to be used, background noise levels are expected to be higher. Professional judgement therefore dictates that the effects are expected to be **minor adverse** or **negligible**.

Route Options

14.12.17 The magnitude of effect of operational 400kV overhead lines noise is negligible to low and therefore the significance of effect is **negligible** or **minor adverse** for either preferred route Option A or alternative route Option B.

Indicative Access for Future Maintenance

14.12.1 During the operational phase, National Grid would require infrequent access to ensure the Proposed Development could be appropriately maintained. The access would typically be made by foot, 4x4 or tractor and trailer and would not typically require any new temporary accesses; however access to tension pylons may require temporary stone roads or aluminium trackway to be laid. Upon completion of any maintenance works, surfaces would be restored to their condition at the commencement of the works. The indicative accesses for future maintenance are shown at **Volume 5.3.3, Figure 3.5 – 3.6**.

14.12.2 The effects of noise due to the temporary construction and use of future maintenance access routes is expected to be no worse than the effect of construction of temporary access routes as discussed in section 14.4. The highest sensitivity receptors are medium sensitivity and the significance of effect is therefore expected to be **minor adverse** or **negligible**. However, due to the limited frequency of occurrence and the likely duration of noise exposure (typically less than 1 week), primarily associated with trackway construction (if required), the actual effects are unlikely to be significant at any receptors.

Significance of Effects of Operational Noise

14.12.3 **Table 14.23** summarises the significance of effects of operational noise.

Table 14.23 Significance of Effects of Operational Noise (No Mitigation)

Operational Source	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Sandford Substation	Droveway Farm	Medium	Low	Minor adverse
	The Oaks	Medium	Negligible	Negligible
	Mead Farm	Medium	No effect	Negligible
	Birchwood House			
400kv Overhead Line – Dry Conditions	Dorvic			
	Meadow Croft			
	Star Inn	Medium	Medium	Moderate adverse
400kv Overhead Line – Wet Conditions	All other receptors	Medium	Low or Negligible	Minor adverse or negligible
	Flat above Garage (Tarnock)	Medium	Medium	Moderate adverse
	Tarnock Cottage			
	Moorland Park			
	Star Inn			
	All other receptors	Medium	Low or negligible	Minor Adverse or negligible

Limits of Deviation and Order Limits

14.12.4 The LoD would provide a necessary and proportionate degree of flexibility as to the final alignment of the works. The LoD identify a maximum distance or measurement of variation within which these works must be constructed. The overhead line LoD are shown at **Volume 5.3.3, Figure 3.1 and 3.2**; the underground cable LoD are shown at **Volume 5.3.3, Figure 3.3**.

14.12.5 The Order Limits, identified in the Proposed Development Plans (see **Volume 5.3.3, Figure 3.1 and 3.2**) as a red outline, are fixed and detail the anticipated maximum extent of land in which the Proposed Development may take place (if approved and subject to DCO Requirements and any other associated commitments).

14.12.6 Further detail as to the level of flexibility that would be afforded by the LoD and the Order Limits and the assessment approach is provided in **Volume 5.5.1, section 5.6**. The implication of the LoD and Order Limits is that some components of the Proposed Development (both temporary and permanent) may be closer or further away from existing receptors than assessed above.

14.12.7 In practice, the implication of the LoD is that pylon structures and hence the centre line of the overhead line can move a maximum of 10m laterally, i.e. the noise sources can move a maximum of 10m closer to receptors, although there are 'pinch points' (see **Volume 5.5.1, section 5.6 and Volume 5.5.3, Figure 5.2**) along the route where this distance is less.

Potential Variation of Significance of Operational Effects

14.12.8 **Table 14.24** shows the receptors where a change in lateral overhead line route within the LoD would result in an increase of significance from overhead line noise.

Table 14.24 Summary of Potential Increase in Significance of Effect within Limits of Deviation

Ref.	Receptor	Condition (Dry/Wet)	Increase in significance from:	Increase in significance to:	Movement Required to Trigger Change
10	Cripps Farm Caravans	Wet	Minor adverse	Moderate adverse	6m towards receptor
19	Court Villa	Wet	Negligible	Minor adverse	2m towards receptor
25	Withy Cottage	Dry	Negligible	Minor adverse	7m towards receptor
		Wet	Minor adverse	Moderate adverse	4m towards receptor
31	The Willows	Wet	Negligible	Minor adverse	7m towards receptor
35	South View	Wet	Negligible	Minor adverse	4m towards receptor
46	Homeground	Wet	Negligible	Minor adverse	7m towards receptor
58	1 Clevedon Road	Dry	Negligible	Minor adverse	7m towards receptor
61	Honeysuckle Cottage	Wet	Minor adverse	Moderate adverse	1m towards receptor

Climate Change Effects

14.12.9 Data from the Met Office (Ref. 14.15) shows a stable/slightly decreasing trend in rainfall rates over the last 100 years. Based on this trend in rainfall, wet noise generation by the overhead lines is not expected to be worse than assessed over the lifespan of the Proposed Development.

14.13 Inter-relationship of Potential Effects

14.13.1 Noise and vibration is considered in **Volume 5.8.1** (Biodiversity and Nature Conservation) in relation to the effect on fauna. Operational noise is unlikely to have a significant effect on sensitive species.

14.13.2 Noise and vibration is considered in **Volume 5.15.1** (Socio-economics and Land Use). An amenity effects assessment (see **Volume 5.15.2, Appendix 15J**) has been undertaken which considers effects arising as a result of the inter-relationship of other environmental effects which together could affect the amenity value of receptors during construction, operation and decommissioning. The assessment has considered likely effects on the amenity various receptors including:

- visitor attractions, PRoW, recreational routes, tourism accommodation and recreational areas; and
- local communities and community facilities (including health, education and community gathering).

14.13.3 Operational noise and vibration are not expected to lead to a significant effect on socio-economics and land use.

14.14 Mitigation

Sandford Substation Operational Noise Mitigation

14.14.1 The substation design will include specifications for the sound power of the transformers and shunt reactors and their associated coolers such that the calculated rating level at nearby residential receptors does not exceed defined limits.

14.14.2 Operational noise from Sandford substation will be secured via a Requirement to ensure noise does not exceed a specified and agreed level.

400kV Overhead Line Operational Noise Mitigation

14.14.3 Noise from overhead lines cannot be practically mitigated. Quality assurance through manufacturing and transportation will be undertaken to avoid damage to overhead line conductors which can increase potential noise effects. Care will be taken during installation to ensure that conductors will be kept clean and free of surface contaminants during stringing. This will minimise the risk of excessive dry noise on energisation of the proposed 400kV overhead line.

14.15 Residual Effects

Residual Effects of Operational Noise

14.15.1 Residual effects for operational noise are not assessed, since all practical mitigation has already been applied during the design and specification of the overhead line and substation.

Significance of Residual Effects of Operational Noise

14.15.2 **Table 14.25** summarises the significance of effects of operational noise. No mitigation is applied to 400kV overhead line noise, as described above, and no additional mitigation is applied to Sandford Substation.

Table 14.25 Significance of Effects of Residual Operational Noise

Operational Source	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
Sandford Substation	Droveway Farm	Medium	Low	Minor adverse
	The Oaks	Medium	Negligible	Negligible
	Mead Farm	Medium	No effect	Negligible
	Birchwood House			
	Dorvic			
400kv Overhead Line – Dry Conditions	Meadow Croft			
	Star Inn	Medium	Medium	Moderate adverse
	All other receptors	Medium	Low or negligible	Minor adverse or negligible

Operational Source	Receptors	Sensitivity of Receptor	Magnitude of Effect	Significance of Effect
400kv Overhead Line – Wet Conditions	Flat above Garage (Tarnock) Tarnock Cottage Moorland Park Star Inn	Medium	Medium	Moderate adverse
	All other receptors	Medium	Low or negligible	Minor adverse or negligible

14.16 Cumulative Effects

- 14.16.1 The cumulative assessment is provided at **Volume 5.17** and includes potential cumulative effects of the Proposed Development together with other major development proposals.
- 14.16.2 Cumulative construction and operational effects have been considered for all other major developments with regards to noise and vibration. No significant cumulative effects are expected.
- 14.16.3 No further mitigation measures would be required above those identified in this chapter (section 14.14). The residual cumulative effects would be the same as those identified at section 14.15 above.

14.17 Conclusions

Operational Effects

14.17.1 The assessment of the significance of effects due to operation noise has concluded that:

- the significance of operational noise from Sandford Substation is assessed as being **minor adverse or negligible**;
- the significance of operational dry noise from 400kV overhead lines is assessed as being **minor adverse or negligible** at all receptors except The Star Inn, where the significance of dry overhead line noise is assessed as being **moderate adverse**;
- the significance of operational wet noise from 400kV overhead line noise is assessed as being **minor adverse or negligible** at all receptors except at The Star Inn, Flat above garage (Tarnock), Tarnock cottage and Moorland Park where the significance of wet 400kV overhead line noise is assessed as being **moderate adverse**.

Part 3 – Summary of Noise and Vibration Effects

14.18 Conclusions

14.18.1 The likely residual noise and vibration effects of the Proposed Development are summarised below:

Construction Effects

14.18.2 The assessment of the significance of effects due to construction noise and vibration has concluded that:

- the significance of noise from construction activities (excluding transition jointing) is assessed as being **negligible to minor adverse**;
- due to night time working, the significance of noise from transition jointing may be **moderate adverse**;
- the significance of construction traffic noise and vibration is assessed as being **minor adverse to negligible**; and
- construction vibration is assessed as being **minor adverse to negligible**.

Operational Effects

14.18.3 The assessment of the significance of effects due to operation noise has concluded that:

- the significance of operational noise from Sandford Substation is assessed as being **minor adverse or negligible**;
- the significance of operational dry noise from 400kV overhead lines is assessed as being **minor adverse or negligible** at all receptors except The Star Inn, where the significance of dry overhead line noise is assessed as being **moderate adverse**;
- the significance of operational wet noise from 400kV overhead line noise is assessed as being **minor adverse or negligible** at all receptors except at The Star Inn, Flat above garage (Tarnock), Tarnock cottage and Moorland Park where the significance of wet 400kV overhead line noise is assessed as being **moderate adverse**.

Decommissioning Effects

14.18.4 The significance of decommissioning noise is assessed as being **minor adverse to negligible**.

- 14.1 Department of Energy & Climate Change. Overarching National Policy Statement for Energy (EN-1). London: The Stationery Office, 2011.
- 14.2 Department for Communities and Local Government. National Planning Policy Framework. London, 2012.
- 14.3 British Standards Institution. BS5228-1:2009. Code of practice for noise and vibration control on construction and open sites - Noise, London, 2008.
- 14.4 British Standards Institution. BS5228-2:2009. Code of practice for noise and vibration control on construction and open sites - Vibration, London, 2008.
- 14.5 Department of Transport. Calculation of Road Traffic Noise. London, 1988
- 14.6 Department of Transport. Design Manual for Roads and Bridges, Volume 11, Section 3, Part 7, Noise and Vibration. London, 1988.
- 14.7 World Health Organisation. Guidelines for Community Noise. Geneva, 1995.
- 14.8 Department of Energy & Climate Change. National Policy Statement for Electrical Networks (EN-5). London: The Stationery Office, 2011.
- 14.9 British Standards Institution. BS7445-1:2003. Description and measurement of environmental noise – Guide to quantities and procedures, London, 2003.
- 14.10 British Standards Institution. BS4142:1997. Method for rating industrial noise affecting mixed residential and industrial areas, London, 1997.
- 14.11 National Grid. Technical Report TR(T)94 – A Method for Assessing the Community Response to Overhead Line Noise
- 14.12 British Standards Institution. BS8233:1999. Sound insulation and noise reduction for buildings. Code of practice, London, 1999.
- 14.13 Miller L N. 1978, 'Sound Levels of Rain and Wind in the Trees', Noise Control Engineering Vol 11, No 3
- 14.14 World Health Organisation. Night Noise Guidelines for Europe. Copenhagen, 2009.
- 14.15 Jenkins, G.J., Perry, M.C., and Prior, M.J. 2008. The Climate of the United Kingdom and Recent Trends. Met Office Hadley Centre, Exeter, UK

Appendix 14A – Construction Noise Assessment Tables

Activity	Plant	No.	BS5228 ref. or Alternative Source	On Time	A-weighted Sound Pressure Level (dB(A)) at 10m or Alternative
General Works					
Site Preparation	Tracked Excavator	2	C2.3	90%	78
	Dozer	3	C2.1	90%	75
Topsoil Strip	Tracked Excavator	2	C2.3	90%	78
	Dozer	3	C2.1	90%	75
Access Road	Wheeled backhoe loader	1	C2.8	90%	68
	Dumper	2	C4.7	90%	78
	Vibratory roller	1	C2.40	90%	73
Underground Cable Construction (400 and 132kV)					
Trenching	Tracked excavator	1	C2.5	90%	76
	Tracked mobile crane	1	C3.29	90%	70
	Piling	1	C3.9	90%	63
	Power pack	1	C3.10	90%	68
Lower and Lay	Side boom	3	C3.28	90%	67
	Water pump	1	C4.88	90%	68
	Wheeled backhoe loader	1	C2.8	90%	68
Backfill Trench	Wheeled backhoe loader	1	C2.8	90%	68
	Tracked excavator	1	C2.5	90%	76
	Dumper	2	C4.7	90%	78
	Vibratory roller	2	C2.40	90%	73
Reinstatement	Wheeled backhoe loader	1	C2.8	90%	68
	Dumper	1	C4.7	90%	78
Transition Joint	Generator	3	C3.32	90%	73

Activity	Plant	No.	BS5228 ref. or Alternative Source	On Time	A-weighted Sound Pressure Level (dB(A)) at 10m or Alternative
Pit	Welder	3	C3.31	90%	73
	Grinder	2	C4.93	90%	80
	Generator	2	C4.94	90%	75
	Sideboom	1	C3.28	90%	67
Cable Pulling	Conveyor Drive Unit	1	C10.20	90%	77
	Field Conveyor	2	C10.23	90%	53
Horizontal Directional Drilling	Power Auger (Crawler Mounted Rig)	1	C3.21	100%	79
	Power Pack	1	C3.10	100%	68
	Generator	2	C4.84	100%	74
	Tracked excavator (22t)	1	C2.3	50%	78
	Water pump	2	C4.88	100%	68
Overhead Line Construction (400 and 132kV)					
Lattice Pylon Construction (Piling Single)	Excavator (For Ground prep)	1	C2.14	10%	79
	Steel Tube Piling Rig	1	C3.8	70%	88
	Concrete Pump	1	C3.25	20%	78
Lattice Pylon Construction (Piled with cap)	Excavator (Ground Prep and cap prep)	1	C2.14	70%	79
	Steel Tube Piling Rig	1	C3.8	70%	88
	Concrete Pump (pile and cap)	1	C3.25	70%	78
Lattice Pylon Construction (No piling)	Excavator (on time dependant on size)	1	C2.14	70%	79
	Telehandler	1	C4.55	70%	70
	Concrete Pump	1	C3.25	70%	78
Lattice Pylon	Tele Handler	1	C4.55	50%	70

Activity	Plant	No.	BS5228 ref. or Alternative Source	On Time	A-weighted Sound Pressure Level (dB(A)) at 10m or Alternative
Assembly					
Lattice Pylon Installation	Crane Lifting Pylon	1	C4.38	10%	78
T-pylon Installation	Tracked Excavator	1	C2.14	10%	79
	Piling Rig (MonoPile)	1	C3.2	70%	87
	MEWP	1	C4.57	40%	67
	Concrete Pump	1	C3.25	10%	78
Lattice and T-pylon Tensioning	Winder	1	Suppliers data	60%	77
	Rear Winder	1	Suppliers data	60%	77
Overhead Line Decommissioning					
Site Preparation	Tracked Excavator	1	C2.14	90	79
Breaking up Concrete	Excavator Mounted Pulverizer	2	C1.3	90	80
Dumping Brick Rubble	Tracked Excavator	1	C1.10	20	85
Breaking Up/Cutting Steel	Tracked Excavator	1	C1.16	50	82
Sandford Substation					
Site preparation	Tracked Excavator	2	C2.3	90%	78
	Dozer	3	C2.1	90%	75
Substation Assembly	Tele Handler	2	C4.55	50%	70
	Generator	2	C4.84	100%	74
	Vibrating Piling Rig	1	C3.8	10%	88
Seabank, Portishead, Avonmouth and Churchill Substations and Cable Sealing End (CSE) Compounds					
Site preparation	Tracked Excavator	2	C2.3	90%	78
	Dozer	3	C2.1	90%	75
Substation/CSE	Tele Handler	2	C4.55	50%	70

Activity	Plant	No.	BS5228 ref. or Alternative Source	On Time	A-weighted Sound Pressure Level (dB(A)) at 10m or Alternative
Assembly	Generator	2	C4.84	100%	74
Construction Compounds					
Site Preparation	Tracked Excavator	2	C2.3	90%	78
	Dozer	3	C2.1	90%	75
Road Construction	Dumper	3	C4.3	90%	76
	Road Roller	1	C5.19	90%	80
Compound Buildings	Tele Handler	2	C4.55	50%	70
	Generator	2	C4.84	100%	74

Table 2 Distances from Works at Which BS5228 Annex E Trigger Levels Would Be Exceeded

Activity	Sound Power Level, dB(A)	Distance (m) At Which Predicted Noise Level Is Below Threshold Or Trigger Level:		
		65dB(A)	70dB(A)	75dB(A)
General Works				
Site clearance	111	79	45	25
Topsoil strip	111	79	45	25
Construction of temporary site access road	109	66	37	21
Underground Cable Construction (132 and 400kV)				
Trenching	105	41	23	13
Lower and lay	102	28	16	9
Backfill trench	111	82	46	26

Activity	Sound Power Level, dB(A)	Distance (m) At Which Predicted Noise Level Is Below Threshold Or Trigger Level:		
		65dB(A)	70dB(A)	75dB(A)
Reinstatement	106	44	25	14
Cable pulling	105	38	21	12
Horizontal directional drilling	111	75	42	24
Lattice Pylon Construction				
Piling required	115	131	74	41
Piling not required	108	58	33	18
Pylon assembly	95	13	7	4
Pylon installation	96	14	8	4
T-pylon Construction				
Monopiling, and assembly	114	108	63	35
Overhead Line Tensioning				
Tensioning	106	44	25	14
Decommissioning 132kV and 400kV Overhead Lines				
Decommissioning overhead lines	114	112	63	35

Table 3 Summary of Receptors Falling Within Maximum Threshold Distances for Main Construction Activities

Activity	Minimum Threshold Distance, m	Receptors Falling Within Maximum Threshold Distances
Existing 132kV Overhead Line Decommissioning	112	The Lodge, Dunware Slape Cross (approx. 5 properties) Manor Farm, Bradney The Yards

Activity	Minimum Threshold Distance, m	Receptors Falling Within Maximum Threshold Distances
		Homestead Farm Court Farm Moor Row Southwick House Elm Tree Farm Mark Causeway (approx. properties) Dwelling on Northwick Road Vole House Pear Tree House Knoll View Farm Pilrow Farm Tarnock (approx. 4 properties) Westliegh Farm Nye Farm Moorland Park Heathgate Middle Elm Primrose Cottage Orchard Side Homeground Rushlands Nailsea Western Fringe (>50 properties) Stone Edge (approx. 5 properties) Spindlewood Cockoos Mead Hunters Croft Clapton-in-Gordano (approx. 5 properties) Portbury Eastern Fringe (>20 properties)

Activity	Minimum Threshold Distance, m	Receptors Falling Within Maximum Threshold Distances
		Avonmouth (>20 properties)
400kV and 132kV Overhead Line Construction and End of Life Decommissioning	131	Dwelling on Northwick Road Tarnock (approx. 4 properties) Moorland Park Star Inn Honeysuckle Cottage Spindle Wood The Meadow 18 Elm Tree Park + Others Portview Road, Avonmouth (approx 10 properties) Rockery Farm Hinkley (approx. 3 properties)
Underground Cable Construction	82	Webbington Farm Towerhead (approx. 4 properties) Mead Lane Nailsea Western Fridges (>50 properties) Sandford Batch (approx. 10 properties) Middle Farm Waterfront Farm Crab Hole Farm Chestnut Farm

Table 4 Summary of Receptors Falling Within Maximum Threshold Distances for Construction of Construction Compounds

Compound	Minimum Threshold Distance, m	Receptors Falling Within Maximum Threshold Distances
Bridgwater Tee (Bath Road)	79	Dwellings on Bath Road to east
A38 Bristol Road (UGC)	79	None
A38 Bristol Road (OHL)	79	None
South Mendips (Hams Lane)	79	None
Barton Road	79	Dwellings on Barton Road to the east
Castle Hill	79	None
Towerhead Road	79	Dwellings on Towerhead Road to the south and west
Sandford Sub Compound	79	None
AT Route OHL Compound	79	None
Churchill	79	Dwellings on Stock Lane to the south
Engine Lane	79	None
Nailsea	79	Dwellings on Causeway View to the east
Church Lane	79	Dwellings on Washing Pound Lane and Church Lane to the south
Clevedon Road	79	Dwellings on Clevedon Road to the south, east and west
Whitehouse Lane	79	Dwellings on Cuckoo Lane to the south and Whitehouse Lane to the east
Caswell Hill	79	None

Compound	Minimum Threshold Distance, m	Receptors Falling Within Maximum Threshold Distances
Sheepway	79	None
BW UGC Route West	79	None
BW UGC Route East	79	None
St Andrews Road	79	None
Kings Weston Lane	79	None
G Route UGC (East of M49)	79	None
Seabank (Severn Road)	79	None

Appendix 14B – Construction Traffic Noise Assessment

Table 1 Construction Traffic Assessment

ATC Number	Road Name	Peak Year	Increase in Road Traffic Noise during peak year, dB	Magnitude of Effect
1	A39 Puritan Road	2018	0.1	Negligible
2	A39 Bath Road	2018	0.1	Negligible
3	B3141 Woolavington Hill	2018	0.2	Negligible
4	B3141 Causeway	2018	0.3	Negligible
5	B3139 (West of Watchfield)	2018	0.2	Negligible
6	A38 Bristol Road (North of Highbridge)	2018	0.0	No Change
7	Harp Road	2018	0.0	No change
8	Southwick Road	2018	0.0	No change
9	A38 Bristol Road, Tarnock	2018	0.2	Negligible
10	A38 Bristol Road (North of Sidcott)	2018	0.3	Negligible
11	A368 Dinghurst Road, Churchill	2018	0.4	Negligible
12	A38 Bristol Road, Langford	2018	0.2	Negligible
13	A3133 Stock Lane	2018	0.0	No change
14	A370, Hewish	2018	0.1	Negligible
14(2)	A370, Hewish	2018	0.2	Negligible
15	A370 Station Road, Congresbury	2018	0.1	Negligible
16	Lampley Road	2019	0.2	Negligible
17	Kenmoor road	2019	0.5	Negligible
18	B3133 Kenn Road	2019	0.1	Negligible
19	Kenn Street, Kenn	2019	1.6	Low
20	Nailsea Wall	2019	0.0	No change
21	B3133 (South of Clevedon)	2019	0.1	Negligible
22	Court Lane	2019	0.0	No change

ATC Number	Road Name	Peak Year	Increase in Road Traffic Noise during peak year, dB	Magnitude of Effect
23	Clevedon Road (East of Celvedon)	2019	0.1	Negligible
24	Clevedon Road (North of Tickenham)	2019	0.1	Negligible
25	B3128 Clevedon Road (North of Nailsea)	2019	0.1	Negligible
26	Whitehouse Lane	2019	0.1	Negligible
27	Caswell Hill	2019	0.9	Negligible
28	Sheepway	2019	0.5	Negligible
29	A369 The Portbury Hundred	2019	0.0	No Change
30	Victoria Road	2017	0.1	Negligible
31	Avonmouth Way	2017	0.3	Negligible
32	A403 St Andrews Road *	2017	2.9	Low
33	Kings Weston Lane	2017	0.1	Negligible
34	A403 Smoke Lane	2017	0.1	Negligible
35	Poplar Way West	2017	0.1	Negligible
36	Poplar Way East	2017	0.4	Negligible
37	A403 Severn Road	2017	0.1	Negligible
38	Severn Road (East of Chittingen Road)	2017	0.3	Negligible
39	Wick Moor Road	2016	0.6	Negligible
40	Wick to Stalford Road	2016	1.8	Low
41	Rodway, Cannington	2016	0.5	Negligible
42	A39 Quantock Road	2016	0.2	Negligible
43	A38 Bristol Road (North of Bridgwater)	2016	0.2	Negligible

* Limited data available for this location. Assumed velocity of 45km/h and assumes 0%HGV baseline. As such, actual increase in noise level is expected to be lower.

Appendix 14C – Noise and Vibration Scoping Out Note

Scoping Out Information Note


1 Introduction

1.1 This appendix provides information to support the scoping out of operational noise from Seabank Substation, Churchill, Avonmouth and Portishead 132kV Substations and 132kV overhead lines as part of this application.

2 Seabank Substation

2.1 This appendix provides information to support the scoping out of operational noise from Seabank Substation as part of this application. A site plan of Seabank Substation is shown in Figure 1

Figure 1 Aerial photograph showing the existing layout of Seabank Substation



2.2 The main source of operational noise at the substation is the three supergrid transformers (SGTs); this is the equipment that produces the distinctive 100Hz “hum”. The arrows in the above aerial photograph show the location of the three SGTs.

- 2.3 The proposed work at Seabank includes the decommissioning and removal of SGT4, highlighted with the green arrow. SGT1 & SGT2, highlighted with the red arrows will remain. These transformers will not change their mode of operation, and hence their noise characteristics will not change. The nearest residential receptor to the proposed site is some 750m to the South East.
- 2.4 Background noise measurements were undertaken in the vicinity in the early hours of 19 June 2013. The $L_{A90,5\text{min}}$ was measured as 46.8dB
- 2.5 The overall effect of the project at Seabank is therefore a small beneficial noise effect at all receptors due to the permanent removal of SGT4.

3 Churchill, Avonmouth and Portishead Substations

- 3.1 The proposed developments at Churchill 132kV Substation, Avonmouth 132kV Substation and Portishead 132kV Substation involve the installation of switchgear at each of these sites. Switchgear noise is generated, in the main, by the operation of circuit breakers, for which the noise emissions are ‘impulsive’ in character (i.e. of short duration). Switchgear operations will be very infrequent. Modern switchgear of the Sulphur Hexafluoride (SF_6) type operates with a dull ‘thud’. There will be no other new significant noise sources installed at these sites, and as such operational noise at these sites is scoped out of the ES.

4 132kV Overhead Lines

- 4.1 Conductor system noise occurs when the conductor surface electric stress exceeds the inception level for corona discharge activity, a level of around 17-20kV/cm. Electrical stresses on 132kV overhead lines are generally much lower than those on 400kV overhead lines in normal operation, and as such, are below the thresholds for audible noise inception. These types of overhead lines are practically quiet in operation.

5 Cable Sealing End Compounds

- 5.1 Cable sealing end (CSE) compounds produce noise in the same manner as overhead lines. Where appropriate, noise from CSE compounds would therefore be assessed similarly.

Appendix 14D – Sandford Substation CadnaA Noise Modelling

1 Objective

1.1 The objective of the noise prediction modelling exercise was to predict substation noise levels at the nearest noise sensitive receptor locations. The following scenario was assessed:

- (Night) – 2 no. Supergrid transformers and 2 no. shunt reactors within acoustic enclosures and 2 no. shunt reactor coolers;

2 Noise prediction modelling software and calculation methodology

2.1 Noise propagation calculations were undertaken in accordance with Internal Standard ISO 9613 “Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation”, which is embedded as a software module.

2.2 Predictions of substation noise levels at the receptor locations take account of features that may affect propagation, such as ground absorption; and, screening by the natural and/or formed topography.

Modelling parameters

Modelling the topography

2.3 The topography around the site is generally flat farmland. As such, the model assumes flat ground as variations in topography are unlikely to significantly affect the propagation, especially with the hard ground assumption described in below.

Modelling buildings and other obstacles

2.4 In order to provide a worst case assessment no buildings are included in the model and as such screening from buildings is ignored.

Modelling noise sources (emission points)

2.5 Point noise sources were used in the model to represent substation equipment. Sound power levels of these sources have been supplied by National Grid. The type and number of plant assumed for each scenario is presented in Table 1 together with sound power levels.

Table 1 Sandford Substation Noise Sources

Substation Item	Number of Operating Noise Source	Sound Power Level, dBA
Supergrid transformer	2	90
Shunt reactors	2	87
Supergrid transformer cooler	0	84
Shunt reactor cooler	2	70

2.6 In accordance with BS4142:1997, a 5dB correction is to be applied if one or more of the following features occur, or are expected to be present for new or modified noise sources:

Hinkley Point C Connection Project

Appendix 14D – Sandford Substation CadnaA Noise Modelling

- The noise contains a distinguishable, discrete continuous note (whine, hiss, screech hum, etc.);
- The noise contains distinct impulses (bangs, clicks, clatters, or thumps);
- The noise is irregular enough to attract attention.

2.7 It is noted that the Supergrid transformers and shunt reactors contain a tonal component and as such a 5dB acoustic character correction is to be applied.

2.8 Proposed mitigation is a noise enclosure with a 20dB insertion loss applied to each of the Supergrid Transformers and Shunt Reactor.

Other modelling parameters

Ground absorption

2.9 All land was assigned a sound absorption factor of 0 (hard ground) for the purpose of noise propagation calculations as a worst case assumption.

Meteorological conditions

2.10 The following meteorological conditions were assumed:

- Ambient temperature: 10°C
- Relative humidity: 70%

2.11 These values represent a typical worst case scenario and provide relatively low levels of atmospheric absorption.

2.12 ISO 9613 assumes wind direction within an angle of $\pm 45^\circ$ of the direction connecting the centre of the dominant sound source and the centre of the specified receiver region, with the wind blowing from the source to receiver, and wind speed between approximately 1m/s and 5 m/s, measured at a height of 3m to 11m above ground level.

Foliage/woodland areas

2.13 Areas of existing foliage are assumed to have no acoustic effect and are therefore not accounted for within noise propagation calculations.

Reflections

2.14 The model does not include any buildings and as such reflections are not taken into account (other than hard ground) to provide an assessment of free field conditions.

Noise sensitive receptor locations (immission points)

2.15 Immission points are positions of noise reception calculation. Modelled prediction calculations determine the broadband noise levels at each immission point resulting during each assessed scenario. In each instance, the height of immission points represents first floor level. Table 2 indicates the location of nearby noise sensitive receptors.

Table 2 Noise Receptor Points

Ref.	Receptor location	Ordnance Survey co-ordinates		
		x	y	z (AGL), m
1	Droveway Farm	341822	160348	4.5

Ref.	Receptor location	Ordnance Survey co-ordinates		
		x	y	z (AGL), m
2	The Oaks	341841	160279	4.5
3	Mead Farm	341456	159930	4.5
4	Birchwood House	341992	160017	4.5
5	Dorvic	341961	159984	4.5
6	Measdow Croft	341936	159893	4.5

3 Methodology for Assessing the Significance of Operational Noise Effects

3.1 The assessment criteria for the sensitivity of noise sensitive receptors are shown in Table 3.

Table 3 Sensitivity of Receptor – Operational Noise

Sensitivity of Receptor	Receptor Description
High	Patients in hospitals/hospices etc. – defined as a “vulnerable subgroup” with very high or continuous rates of occupancy
Medium	Residential receptors
Low	Area used primarily for leisure activities, including Public Rights of Way (PRoW), sports facilities and sites of historic or cultural importance
Negligible	All other areas such as those used primarily for industrial or agricultural purposes

3.2 The assessment criteria for the magnitude of effect of operational noise effects are shown in Table 4.

Table 4 Magnitude of Effects – Operational Noise

Magnitude of Effect	Operation Noise - Substation or Overhead Line - Dry and Wet Noise
High	Predicted rating levels are 5dB or more above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Medium	Predicted rating levels are between 5 - 0dB(A) above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Low	Predicted rating levels are between 0dB(A) above and 5dB(A) below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)

Magnitude of Effect	Operation Noise - Substation or Overhead Line - Dry and Wet Noise
Negligible	Predicted rating levels are between 5dB(A) and 10dB(A) below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
No effect	Predicted rating noise levels are 10dB or more below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)

3.3 The assessment criteria for the significance of operational noise effects are shown in Table 5.

Table 5 Significance of Effect – Operational Noise

Significance of Effect	Receptor Sensitivity			
Magnitude	High	Medium	Low	Negligible
High	Major	Major	Moderate	Minor
Medium	Major	Moderate	Minor	Negligible
Low	Moderate	Minor	Negligible	Negligible
Negligible	Minor	Negligible	Negligible	Negligible


4 Model outputs

4.1 Figure 1 shows a graphical CadnaA representation of noise propagation from Sandford substation during night time periods..

Hinkley Point C Connection Project

Appendix 14D – Sandford Substation CadnaA Noise Modelling

Figure 1 CadnaA Noise Propagation Model of Sandford Substation During Night Time



4.2 Table 6 summarises the substation noise levels, predicted using CadnaA modelling in accordance with BS 9613-2, at each selected receptor location during night time periods.

Table 6 Summary of predicted Sandford Substation noise levels at identified sensitive receptor locations

Receptor Name	Background Noise Level, dB LA ₉₀	Predicted L _{Aeq,T} Sound Pressure Level, dB (Free Field) (Including 5dB Acoustic Character Correction)	Assessment Level, dB	Magnitude of Effect
Droveway Farm	30	27	-3	Low
The Oaks	30	25	-5	Negligible
Mead Farm	30	20	-10	No effect
Birchwood House	30	20	-10	No effect
Dorvic	30	20	-10	No effect

Hinkley Point C Connection Project

Appendix 14D – Sandford Substation CadnaA Noise Modelling

Receptor Name	Background Noise Level, dB L_{A90}	Predicted $L_{Aeq,T}$ Sound Pressure Level, dB (Free Field) (Including 5dB Acoustic Character Correction)	Assessment Level, dB	Magnitude of Effect
Meadow Croft	30	19	-11	No effect

4.3 Table 7 summarises the significance of effect for each receptor.

Table 7 Summary of Significance of Effect

Receptor Name	Magnitude of Effect	Receptor Sensitivity	Significance of Effect
Droveway Farm	Low	Medium	Minor adverse
The Oaks	Negligible	Medium	Negligible adverse
Mead Farm	No effect	Medium	Negligible
Birchwood House	No effect	Medium	Negligible
Dorvic	No effect	Medium	Negligible
Meadow Croft	No effect	Medium	Negligible

**Appendix 14E – Summary of Night-time Background
Noise Measurements on Route of Proposed 400kV
Overhead Line and Substations**

Environmental Engineering Note

EEN/218/NOTE2013
Issue 3

Date: 3rd Mar 2014

National Grid
Electricity Network
Investment


National Grid House
Warwick Technology Park
Gallows Hill
Warwick
CV34 6DA

Summary of night-time background noise measurements on route of proposed Hinkley Point C connection overhead line


AUTHOR
Sue Fitton

Addressee: **Aileen Smith**

Signed:
Author



Signed:
Approval for iss



1 INTRODUCTION

1.1 This report documents the night-time background noise measurements taken in the vicinity of the proposed route for the Hinkley Point C Connection overhead line and substation.

1.2 To establish the prevailing background noise conditions along the proposed route a series of five minute attended measurements were taken at many of the convenient public access points [road crossings] along the proposed route during the early hours on several different occasions as detailed below;

- The majority of the route to the south of Avonmouth was surveyed in the early hours of Monday 27 May 2013, this being a bank holiday Monday.
- The route around Avonmouth was surveyed in the early hours of 19 June 2013, this being a normal working day.
- The entire route was resurveyed in the early hours of 21 August 2013, this also being a normal working day.
- A number of locations were resurveyed in the early hours of 16 October 2013, for attended 15-minute measurements.
- The area around Sandford substation was surveyed in the early hours of 16 Feb 2013.

1.3 On all of the above occasions the weather was suitable for the purpose of the task. It was fine, calm and dry allowing the real minimum background noise levels to be measured without the influence of wind and precipitation. Throughout the measurement surveys the weather remained fine and there were no peculiar or atypical noise sources to contend with. For the great majority of the measurements, the measurement intervals were not disturbed by passing local traffic or other human activity. When there was passing local traffic, it was considered to be typical for that location, and the number of vehicles passing was noted. Surveyor comments were noted at each location and recorded in National Grid files.

1.4 This report is not a noise assessment; it is simply a record of prevailing background noise measurements which may subsequently be used in an assessment exercise. These measurements have been used to guide the audible noise impact assessment included in the project Environmental Statement.

2 EQUIPMENT AND CALIBRATION

2.1 Measurements were taken with a variety of instruments, all of which were calibrated in accordance with the relevant standards:

- Brüel & Kjaer 2270 Investigator, Serial No. 2664167
- Brüel & Kjaer 4189 microphone, Serial No. 2662754

- Brüel & Kjaer 2250 Investigator, Serial No. 2506571
- Brüel & Kjaer 4189 microphone, Serial No. 2529520
- Brüel & Kjaer 2250 Investigator, Serial No. 3000223
- Brüel & Kjaer 4189 microphone, Serial No. 2775412
- Brüel & Kjaer 2260 Investigator, Serial No. 2001634
- Brüel & Kjaer 4189 microphone, Serial No. 2282114

2.2 Sound level equipment was also successfully field calibrated immediately before and after each noise survey in accordance with manufacturer's instructions. Meteorological parameters were recorded for indication only.


3 Version control for this report

Issue Number	Date	Reason for re-issue	Issued by
1	8 Nov 2013	First issue	SJ Fitton
2	21 Jan 2014	Updated to include background measurements around substation	SJ Fitton
3	26 Feb 2014	Formatting to Hinkley C project requirements and removing reference to PEIR	SJ Fitton

4 SUMMARY OF SURVEY LOCATIONS


4.1 Background noise surveys were undertaken in the following locations at the Southern end of proposed route:

Figure 1: the proposed alignment of the southern section of the route (in red) and the areas close to residential areas along the route where background surveys have been undertaken (green pins).



4.2 Background noise surveys were undertaken in the following locations at the Northern end of proposed route:

Figure 2: the proposed alignment of the southern section of the route (in red) and the areas close to residential areas along the route where background surveys have been undertaken (green pins).



4.3 Detailed surveys were not undertaken in the middle part of the route which proposed to be constructed using underground cables, since assessment of operational noise has been scoped out in this area.

5 DETAIL OF SURVEY LOCATIONS

Figure 3: Survey detail, Hinkley line entries



Table 1: Hinkley line entry measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
16/10/2013	00:02	15	26	

Figure 4: Survey detail, Woolavington Road



Table 2: Woolavington Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	00:36	5	32.4	
21/08/2013	00:28	5	32.7	

Figure 5: Survey detail, East Huntspill:



Table 3: East Huntspill measurement details

Date	Time	Measurement time, mins	L _{A90} , dB	Notes
27/05/2013	00:49	5	28.6	Burgle Road
21/08/2013	00:56	5	31.0	Burgle Road
21/08/2013	00:44	5	29.0	Long Moor Drove
16/10/2013	00:58	15	22.0	Long Moor Drove

Figure 6: Survey detail, Southwick Road:



Table 4: Southwick Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	01:04	5	30.2	
21/08/2013	01:15	5	32.9	

Figure 7: Survey detail, Mark:



Table 5: Mark measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	01:18	5	31.5	Mark Crossroads
21/08/2013	01:26	5	33.8	Butt Lake Road
21/08/2013	01:40	5	36.6	Harp Road
21/08/2013	01:49	5	36.6	Mark Causeway
21/08/2013	02:01	5	32.4	Northwick Road
16/10/2013	01:23	15	28	Mark Causeway

Figure 8: Survey detail, Rooks Bridge:



Table 6: Rooks Bridge measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	01:34	5	35.8	Bristol Road
21/08/2013	02:43	5	36.2	Bristol Road
16/10/2013	02:02	15	36	Bristol Road
21/08/2013	02:33	5	33.5	Chapel Road

Figure 9: Survey detail, Drove Way:



Table 7: Drove Way measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
21/08/2013	03:01	5	32.3	

Figure 10: Survey detail, Moorland Park:



Table 8: Moorland Park measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	02:28	5	36.8	
21/08/2013	02:44	5	40.0	

Figure 11: Survey detail, Lampley Road:



Table 9: Lampley Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	02:53	5	40.5	
21/08/2013	02:25	5	40.7	

Figure 12: Survey detail, Kenn Road:



Table 10: Kenn Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	03:02	5	38.4	
21/08/2013	02:09	5	43.6	

Figure 13: Survey detail, Kenmoor Road:



Table 11: Kenmoor Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	03:12	5	38.1	
21/08/2013	01:51	5	36.8	

Figure 14: Survey detail, Causeway, Nailsea:



Table 12: Causeway, Nailsea measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	03:35	5	28.2	
21/08/2013	01:30	5	30.3	

Figure 15: Survey detail, Stone Edge Batch:




Table 13: Stone Edge Batch measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
21/08/2013	01:12	5	28.8	Clevedon Road
21/08/2013	03:09	5	29.0	Clevedon Road
27/05/2013	03:44	5	28.1	Batch Farm
21/08/2013	01:01	5	31.0	Batch Farm
21/08/2013	03:02	5	26.5	Batch Farm
16/10/2013	02:52	15	29	Batch Farm
21/08/2013	00:46	5	27.5	Tickenham Hill
21/08/2013	02:55	5	26.5	Tickenham Hill

Figure 16: Survey detail, junction of Cadbury Camp Lane and Whitehouse Lane:



Table 14: junction of Cadbury Camp Lane and Whitehouse Lane measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	03:56	5	33.2	
21/08/2013	02:44	5	26.6	
16/10/2013	03:16	15	36	

Figure 17: Survey detail, Caswell Hill:



Table 15: Caswell Hill measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
27/05/2013	04:05	5	46.2	
21/08/2013	02:35	5	47.5	

Figure 18: Survey detail, Portbury:



Table 16: Portbury measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
19/06/2013	01:31	5	46.6	Station Road, north of M5
21/08/2013	02:03	5	48.8	Station Road, north of M5
19/06/2013	01:20	5	31.2	Station Road, south of M5
21/08/2013	02:26	5	44.7	Station Road, south of M5
16/10/2013	03:41	15	42	Station Road, south of M5

Figure 19: Survey detail, Sheepway:



Table 17: Sheepway measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
19/06/2013	01:41	5	34.7	
21/08/2013	02:13	5	35.1	

Figure 20: Survey detail, Avonmouth:




Table 18: Avonmouth measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
19/06/2013	02:23	5	45.6	Gloucester Road/Clayton Street
21/08/2013	01:25	5	48.9	Gloucester Road/Clayton Street
19/06/2013	02:14	5	41.8	Portview Road, nr Collins Street
21/08/2013	01:34	5	45.6	Portview Road, nr Collins Street
19/06/2013	02:06	5	40.8	Portview Road/Pages Mead
21/08/2013	01:41	5	46.1	Portview Road/Pages Mead
19/06/2013	01:58	5	43.8	Portview Road/Catherine Street
21/08/2013	01:48	5	46.6	Portview Road/Catherine Street

Figure 21: Survey detail, Kings Weston Lane:




Table 19: Kings Weston Lane measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
19/06/2013	02:56	5	43.5	
21/08/2013	01:12	5	41.2	

Figure 22: Survey detail, Severn Road:




Table 20: Severn Road measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
19/06/2013	02:42	5	46.8	
21/08/2013	00:58	5	45.0	

Figure 23: Survey detail, area around proposed Sandford Substation:



Table 21: area around proposed Sandford Substation, measurement details

Date	Time	Measurement time, mins	L_{A90} , dB	Notes
16/02/2013	00:23	5	31.4	Sandmead Road
16/02/2013	00:41	5	35.4	Riverside
16/02/2013	00:55	5	27.9	Mead Lane
16/02/2013	01:06	5	29.6	Nye Road
16/02/2013	01:15	5	28.0	Droveway
16/02/2013	01:25	5	30.5	Droveway

Note: blue and green pins show approximate location of main plant items in proposed substation.

Distribution List:

PDF format electronic versions to:

Administration Included in Environmental Engineering electronic archive

PDF format electronic copies to:

Damien Culley

Sue Fitton

Richard Morris

Janine Dickinson

ENVIRONMENTAL ENGINEERING NOTE; PROGRESS SHEET

EEN/218/NOTE2013 v3

<p>TITLE Summary of background noise measurements for Hinkley Point C connection project</p>	
<p>AUTHOR(S) Sue Fitton</p>	
<p>Date sent for Technical Editing: 03 March 2014</p>	
<p>Technical Editing by: Richard Morris Signature [REDACTED]</p>	
<p>Date: 04/03/2014</p>	
<p>Approval for Issue: Damien Culley Signature [REDACTED]</p>	
<p>Date: [REDACTED]</p>	
<p>Distribution Date: 03 March 2014</p>	
<p>Date NGTnet Index updated: 03 March 2014</p>	
<p>Date Document Archived to S Drive: 03 March 2014</p>	

Appendix 14F – Generic Data Curves to Assess Spans of 400kV Overhead Line Noise

14F TECHNICAL APPENDIX: GENERIC OPERATIONAL NOISE ASSESSMENT CURVES

14.1 INTRODUCTION

14.1.1 Noise from overhead line conductors can be categorised into two types: noise in dry weather (dry noise) which is usually heard as an intermittent or continuous 'crackle' from specific points on the conductor, and noise in wet weather (wet noise), usually heard as semi-continuous or continuous 'crackle' or 'fizz', and under heavier rainfall conditions a low frequency 'hum'. Noise is produced by "corona discharge" on the surface of the conductors. The effect of the audible noise drops off with distance from the overhead line, and the effect will also depend upon the existing levels of background noise in the area. A summary of overhead line noise and the assessment of its impact and significance are described in **Chapter 14** (Audible Noise and Vibration) in the main part of the ES.

14.1.2 The principal factor affecting conductor noise is conductor surface electrical stress, which itself is a function of operating voltage and physical line configuration. The level of noise can vary depending on weather (principally rainfall) and the surface condition of the conductors (surface contamination). The prediction of noise therefore requires a number of assumptions to be made in order for an assessment of potential noise impact to be made. National Grid uses an in-house method, described in internal report TR(T)94 and referenced in EN-5, which follows the principles of BS 4142 (1997) for dry noise and describes a method for predicting and assessing wet noise. Other methods are available, but these have been developed for systems other than the UK transmission network, and are not thought to give as accurate a result for UK operating conditions.

14.1.3 The National Grid method is based on empirical electrical stress data and measured noise data from selected twin-bundle 400kV overhead lines. The data produced is essentially a time-weighted average noise level for overhead line noise; lines will usually operate quietly under certain (usually dry) conditions and may be noisier under other conditions (usually heavy rainfall).

14.1.4 The model in TR(T)94 was developed with measured data from in service twin Zebra ACSR (28.6 mm diameter) and twin Rubus AAAC (31.5mm diameter) conductor systems on a range of lattice tower types. These conductor systems are inherently noisier (due to much higher surface electrical stresses) than that proposed for Hinkley. It is therefore necessary to assume extrapolation of the assessment method to other conductor systems with lower electrical stresses is valid and because of this, prudent modelling data has been selected to ensure the assessment is conservative. This is particularly the case for the T-pylon, which presents a very different conductor system geometry to that for which the model was developed. As an entirely new design, there are currently no T-pylons in service so that noise behaviour and predictions can be verified.

14.1.5 The method does not predict how a particular individual may perceive noise from an overhead line, instead it produces assessment levels which can then be compared to significance criteria to predict the impact on populations of people living within approximately 200 metres either side. In order to ensure that the predicted impact is conservative, the BS 4142 (1997) dry noise assessment is carried out relative to measured night-time (i.e. lowest) background noise levels, while the wet noise assessment assumes a rate of rainfall sufficient to induce 'hum' on the

overhead line and also a ground terrain that produces minimal masking due to the noise of rainfall on the ground. Both dry and wet noise assessments include a +5dB penalty to account for character in the noise in accordance with the principles of BS 4142 (1997).

14.2 HINKLEY PROJECT DETAILS

14.2.1 This appendix provides a record of the generic noise assessment curves for the Hinkley Point C Connection Project overhead line scheme. It is proposed to construct a new 400kV overhead line with a conductor system comprised of twin 41mm diameter 'Redwood' all aluminium alloy conductors (AAAC), spaced 550mm apart. The conductor system geometry in this generic assessment is based on National Grid standard construction, updated with specific data for the Hinkley Project provided by the project design team. The project design ground clearance of 12.4m average span height has been applied to both proposed tower types, namely L12 lattice towers (L12/1) and T-pylon (T1). An average 12.4m ground clearance is considered a typical worst case for normal operating conditions.

14.2.2 For the wet noise assessment it is assumed that an average 850mm of rain falls over 600hrs per year for the whole project area. This is based upon recent rainfall data provided to National Grid by the Met Office for the period 2001-2010 (see section 14.5). From this data it can be assumed that wet weather conditions will be present for approximately 7% of the year.

14.3 OVERHEAD LINE NOISE PREDICTION METHOD

14.3.1 The noise prediction methodology is carried out in three steps:

14.3.2 Step 1: Calculation of conductor surface electrical stress:

- Expressed in kV/cm, conductor surface electrical stress is the principal factor which determines the likelihood that the principal source of noise, corona discharge, can occur when contamination or rain drops impinge on the surface of the conductor. The lower the electrical stress, the quieter the overhead line is likely to be. Conductor surface electrical stress is determined by the line voltage (in this case 400kV), the size (diameter) of the conductors, the number of conductors per bundle and the geometry of the tower or pylon.
- The input factors for the electrical stress calculation are: line voltage, tower/pylon geometry (including height and arrangement of cross arms), conductor radius, bundle geometry and electrical phasing arrangement.

14.3.3 Step 2: Calculation of a sound pressure level at 1.5m from the conductor bundle surface:

- The National Grid model calculates an A-weighted sound pressure level [dB(A)] at 1.5 metres from the surface of each conductor bundle, corrected with a +5dB penalty for character of the noise source. This produces twelve values: six corrected sound pressures for dry noise and six for wet noise. These values have been used as inputs to produce the CadnaA noise contour plots shown in **Appendix 14E**.

- The input factors for the calculation of the corrected sound pressure level are: conductor radius, the averaged maximum conductor surface electrical stress (Emax) for each bundle calculated in step 1, and a 'k factor' which describes the skew of the stress profile around the conductors.

14.3.4 Step 3: Calculation of dry noise and wet noise assessment levels at distances from the line.

- The National Grid model includes a basic noise propagation model which accounts for the attenuation of noise over distance and absorption in the air. This propagation model is used to produce the generic noise curves shown in figures 14D.1 and 14D.2. The noise contour plots shown in **Appendix 14E** are produced with the propagation model used in CadnaA, which is complaint with ISO 9612-2. The two propagation models produce consistent results.
- For dry noise, a free-field BS 4142 (1997) type assessment level is calculated at various distances from the line. The assessment level can be positive or negative, depending on the noise level from the line compared to the prevailing background noise level without the line. It is possible to report the result as a rating level (dB LAr,Tr) by adding the assessment level to the background noise level.
- The input values for this are the output values of step 2, a selected background noise level (dB LA90), and the distance in metres to the receiver being assessed.
- For wet noise, additional input information includes the typical annual rainfall rate (mm per year and number of hours of rainfall) and information on the ground terrain near the receiver, which provide an estimate of the increase in background noise due to the noise of rain falling on the ground. (This information can be represented as "Miller curves" (ref 14.13).) The calculated assessment value is the predicted difference in noise level in rain including the presence of the line compared to the noise level in the rain without the line and is always a positive figure.

14.3.5 The electrical stress values and corrected sound pressure values calculated in steps 1 and 2 for the two proposed overhead line configurations for the Hinkley project are summarised in Table 14D.1 below.

TABLE 14D.1: Conductor surface electrical stress and predicted source sound pressure levels

Tower type	Maximum Conductor Surface Electrical Stress [twin Redwood - 2 x 41mm diameter] (Emax) kV/cm	Dry noise rating level at 1.5m from each bundle (dBA)	Wet noise rating level at 1.5m from each bundle (dBA)
Lattice L12/1	13.8	Top: 26.3, 26.3 Middle: 28.5, 28.5 Bottom: 28.4, 28.4	Top: 41.9, 41.9 Middle: 44.1, 44.1 Bottom: 44.0, 44.0
T-pylon T1	14.6	Outer: 33.0, 33.0 Inner: 30.3, 30.3 Bottom: 34.8, 34.8	Outer: 48.6, 48.6 Inner: 45.9, 45.9 Bottom: 50.4, 50.4

14.3.6 The sound level values calculated above can then be used in a sound propagation model to calculate the relevant assessment levels at various distances from the line. By inputting a range of background noise levels (30, 35, 40 and 45 dB LA90) and a range of distances (0, 40, 70, 100, 150, and 200 metres), a matrix of results is produced which can be represented as a series of curves for each proposed overhead line construction type.

14.3.7 The dry noise and wet noise curves generated using the National Grid TR(T)94 method are shown in Figures 14D.1 and 14D.2.

14.3.8 The dry noise curves represent assessment levels consistent with BS 4142 (1997) and hence these values can be compared to the assessment method values presented in section 9 of BS 4142 (1997). BS 4142 (1997) describes a method to assess the likelihood of complaints from a population of people when a new industrial noise source is introduced. BS 4142 (1997) states that a difference of around +10dB or indicates that complaints are likely, a difference of around +5dB is of marginal significance and a difference of more than 10dB below background is a positive indication that complaints are unlikely.

14.3.9 The wet noise curves represent the predicted time weighted change (increase) in noise levels near the overhead line in wet weather. (Wet weather noise will vary with rainfall rate and hence is not a single number.) The noise change can be used to calculate an equivalent rating level for wet noise.

14.3.10 It is important to understand that overhead line noise and background noise levels can vary hence the assessment describes typical conditions, time-weighted average noise levels and typical rainfall rates.

14.4 GENERIC NOISE CURVES FOR HINKLEY PROJECT

14.4.1 The charts below are explained using the following worked example for a person standing directly under an L12 line with twin Redwood conductors in an area where the night-time background noise level without the line is 30dB LA90 (yellow curve with triangles in Figure 14D.1).

- The dry noise curve indicates a 0dB BS 4142 (1997) assessment level. This means the new noise introduced by the line is roughly equal to the pre-existing background noise level. In dry weather the person would typically experience a noise level from the line of just below the night-time background noise level.
- In wet weather the person would typically experience a noise level 4dB higher in the presence of the line compared to being in the same location without the line present. A 4dB change is regarded as being 'just perceptible'.
- Both these values include a +5dB penalty for character in the noise and hence they include a correction to account for that fact the overhead line noise can subjectively be regarded as intrusive or annoying in certain circumstances.

Figure 14D.1: Generic noise curves for twin Redwood conductors on L12 lattice towers







Figure 14D.2: Generic noise curves for twin Redwood conductors on T-pylon



Note: The T-pylon has a very different geometrical configuration to the to a lattice tower. The above results are considered to be a conservative estimate of the likely effects. Comparison with calculations from other overhead line noise application modelling packages (which were developed in non-UK transmission systems) suggests that the above charts are conservative and hence predict a conductor noise higher than will actually be produced.

14.5 WET WEATHER DATA

14.5.1 The Met Office has recently reviewed its rainfall intensity and rainfall duration data for the period 2001 to 2010 on behalf of National Grid and has produced the charts shown in figures 14D.3 and 14D.4. From these figures it can be seen the typical rainfall rate in the project area falls in the range 700 to 1000 mm over 450 to 600 hours. The selected rainfall rate for the wet noise modelling for the Hinkley Project is 850 mm rain falling over 600 hours.

Figure 14D.3: Total annual average rainfall, 2001-2010:





Figure 14D.4: Annual Average Wet Hours (above 0.2mm/hr), 2001-2010:



14.6 References

14.13 Miller L N. 1978, 'Sound Levels of Rain and Wind in the Trees', Noise Control Engineering Vol 11, No 3

Appendix 14G – 400kV Overhead Line Noise Modelling

1 Objective

1.1 The objective of the noise prediction modelling exercise was to predict overhead conductor noise levels at the nearest noise sensitive receptor locations. The following scenarios were assessed:

- Dry conductor noise (crackle); and
- Wet conductor Noise (hum).

2 Noise prediction modelling software and calculation methodology

2.1 Noise propagation calculations were undertaken in accordance with Internal Standard ISO 9613 “Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation”, which is embedded as a software module.

Modelling parameters

Modelling the topography

2.2 Topography is assumed to be flat along the proposed route as worst case (lowest) source heights are assumed. The height of the source compared to the receptor height is not likely to lead to significant screening, especially at worst case receptors closest to the conductor route.

Modelling buildings and other obstacles

2.3 In order to provide a worst case assessment no buildings are included in the model and as such screening from buildings is ignored.

Modelling noise sources (emission points)

2.4 Line noise sources were used in the model to represent conductors. Sound power levels of these sources have been supplied by National Grid. Conductor noise levels vary for different conductor types and electrical stresses. The configuration and sound power level for the conductors is presented in Table 1.

Table 1 Conductor Noise Sources

Pylon Type	Wet/Dry	Conductor Position	Conductor Height AGL, m	Conductor Distance from Centre Line, m	Conductor Sound Power Level, dBA
T Pylon	Dry	Lower	12.40	10.55	42.7
		Inner	18.81	6.90	40.9
		Outer	18.81	14.20	40.9
	Wet	Lower	12.40	10.55	58.3
		Inner	18.81	6.90	56.5
		Outer	18.81	14.20	56.5

2.5 In accordance with BS4142:1997, a 5dB correction is to be applied if one or more of the following features occur, or are expected to be present for new or modified noise sources:

- The noise contains a distinguishable, discrete continuous note (whine, hiss, screech hum, etc.);
- The noise contains distinct impulses (bangs, clicks, clatters, or thumps);
- The noise is irregular enough to attract attention.

2.6 A 5dB acoustic character correction is to be applied to the above data to take account of 'hum' and 'crackle' noise.

Other modelling parameters

Ground absorption

2.7 All land was assigned a sound absorption factor of 0 (hard ground) for the purpose of noise propagation calculations, resulting in noise levels 3dB higher than those expected for soft ground and represents a worst case scenario.

Meteorological conditions

2.8 The following meteorological conditions were assumed:

- Ambient temperature: 10°C
- Relative humidity: 70%

2.9 These values represent a typical worst case scenario and provide relatively low levels of atmospheric absorption.

2.10 ISO 9613 assumes favourable (worst case) conditions for downwind propagation.

Foliage/woodland areas

2.11 Areas of existing foliage are assumed to have no acoustic effect and are therefore not accounted for within noise propagation calculations.

Reflections

2.12 The model does not include any buildings and as such reflections are not taken into account (other than hard ground) to provide an assessment of free-field conditions.

Noise sensitive receptor locations

2.13 Immission points are positions of the noise reception calculation and are representative of the position of building façades. Modelled prediction calculations determine the broadband noise levels at each immission point resulting during each assessed scenario. In each instance, the height of immission points represents first floor level. Table 2 shows indicates the location of nearby noise sensitive receptors.

Table 2 Receptor Locations

Receptor Ref.	Receptor Name	Ordnance Survey co-ordinates		
		x	y	z (AGL), m
1	Hillside Farm	333477	141366	4.5
2	The Yards	333943	141442	4.5
3	East Farm	333689	141559	4.5
4	99 Woolavington Road	333658	141623	4.5
5	Homestead Farm	334473	143272	4.5
6	Cote Lea	335072	144215	4.5
7	Elm Cottage	335036	144238	4.5
8	Sunningdale	335051	144289	4.5
9	Cripps Farm	336054	145133	4.5
10	Cripps Farm Caravans	335950	145230	4.5
11	Merry Farm	335720	145286	4.5
12	Willow Cottage	336488	147305	4.5
13	Yardwell House	336465	147449	4.5
14	Wainbridge	336438	147625	4.5
15	Dwelling	336370	147649	4.5
16	Wainbridge Farm	336468	147660	4.5
17	The Yews	336820	147681	4.5
18	Court Farm	336720	147699	4.5
19	Court Villa	336771	147707	4.5
20	Little Dean	336782	147709	4.5
21	Ashdene	336795	147713	4.5
22	Portland Cottage	336828	147726	4.5
23	Victory House	336718	148296	4.5
24	Sunnydene	336698	148301	4.5
25	Withy Cottage	336534	148356	4.5
26	Poachers Cottage	336386	148389	4.5
27	Vole House Farm	336920	149286	4.5

Hinkley Point C Connection Project

Appendix 14G – 400kV Overhead Line Noise Modelling

Receptor Ref.	Receptor Name	Ordnance Survey co-ordinates		
		x	y	z (AGL), m
28	Pillrow	337099	150173	4.5
29	Acacia Farm	337237	152422	4.5
30	Laurel Cottage	337177	152463	4.5
31	The Willows	337251	152483	4.5
32	Little Willows	337202	152488	4.5
33	Flat above Garage	337427	152492	4.5
34	Tarnock Cottage	337444	152533	4.5
35	South View	337528	152553	4.5
36	Tarnock Farm	337469	152555	4.5
37	Willow Cottage	337568	152586	4.5
38	Ty Barah	337591	152589	4.5
39	Moorland Park	341697	164232	4.5
40	Heathgate	341821	164431	4.5
41	Middle Elm	341881	164466	4.5
42	Primrose Cottage	341187	167066	4.5
43	Orchardside	341207	167073	4.5
44	Rose Lea Cottage	341258	167092	4.5
45	Hope Farm	341477	167474	4.5
46	Homeground	341493	167492	4.5
47	Oakland Farm	341312	167680	4.5
48	Rose Bungalow	342452	168135	4.5
49	Manor Farm	342532	168454	4.5
50	Causeway House	345819	170756	4.5
51	Yeovil	346207	171677	4.5
52	Little Orchard	346148	171697	4.5
53	Furze	346221	171730	4.5
54	Lavender Cottage	346610	171731	4.5
55	Stone Edge Farm	346529	171734	4.5
56	Stone Edge Barn	346561	171744	4.5
57	Stonewell Barn	346640	171758	4.5
58	1 Clevedon Road	346495	171759	4.5
59	2 Clevedon Road	346505	171759	4.5
60	Stone Edge Cottage	346500	171759	4.5
61	Honeysuckle Cottage	346479	171770	4.5
62	Wellhouse Farm	346604	171777	4.5
63	The Gables	346558	171788	4.5
64	The Granary	346531	171795	4.5

Receptor Ref.	Receptor Name	Ordnance Survey co-ordinates		
		x	y	z (AGL), m
65	12 Clevedon Road	346272	171812	4.5
66	The Elms	346586	171815	4.5
67	11 Clevedon Road	346279	171816	4.5
68	Dwelling (Stone Edge)	346355	171843	4.5
69	Inn	346403	171861	4.5
70	Naish Cottage	348086	172739	4.5
71	Hunters Croft	348070	172858	4.5
72	Birchwood	347671	172922	4.5
73	Deep Acres	347739	172957	4.5
74	Spindlewood	347825	172963	4.5
75	Cuckoos Mead	348037	172965	4.5
76	Naish Lodge	348028	173550	4.5
77	Cole Acre	349566	175591	4.5
78	The Meadow	349578	175626	4.5
79	18 Elm Tree Park + Others	349737	175714	4.5

Note:- Receptors 77 to 79 relate only to preferred route (Option A).

3 Scoped out receptors

3.1 The receptors highlighted in Table 2 are assessed due their proximately to the overhead line and relative background noise level. The following spans contain residential receptors within 200m of the overhead line, but have been scoped out from detailed noise assessment. This is because there is a clear indication from the generic noise assessment curves (**Volume 5.14, Appendix 14F**) that the magnitude of effect at all properties is negligible or low (and hence there is not a significant effect), due to either the proximity of the properties to the line and/or the high ambient noise background.

- LD93-94
- LD103-104
- LD108-LD113
- LD119-120
- P-LD97-98

4 Methodology for Assessing the Significance of Operational Noise Effects

4.1 The assessment criteria for the sensitivity of noise sensitive receptors are shown in Table 3.

Table 3 Sensitivity of Receptor – Operational Noise

Sensitivity of Receptor	Receptor Description
High	Patients in hospitals/hospices etc. – defined as a “vulnerable subgroup” with very high or continuous rates of occupancy
Medium	Residential receptors
Low	Area used primarily for leisure activities, including Public Rights of Way (PRoW), sports facilities and sites of historic or cultural importance
Negligible	All other areas such as those used primarily for industrial or agricultural purposes

4.2 The assessment criteria for the magnitude of effect of operational noise effects are shown in Table 4.

Table 4 Magnitude of Effects – Operational Noise

Magnitude of Effect	Operation Noise - Substation or Overhead Line - Dry and Wet Noise
High	Predicted rating levels are 5dB or more above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Medium	Predicted rating levels are between 5 - 0dB(A) above the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Low	Predicted rating levels are between 0dB(A) above and 5dB(A) below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
Negligible	Predicted rating levels are between 5dB(A) and 10dB(A) below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)
No effect	Predicted rating noise levels are 10dB or more below the higher of existing background noise levels or 30dB (background noise levels for wet noise assessment include noise levels due to rainfall)

4.3 The assessment criteria for the significance of operational noise effects are shown in Table 5.


Table 5 Significance of Effect – Operational Noise

Significance of Effect	Receptor Sensitivity			
Magnitude	High	Medium	Low	Negligible
High	Major	Major	Moderate	Minor
Medium	Major	Moderate	Minor	Negligible
Low	Moderate	Minor	Negligible	Negligible
Negligible	Minor	Negligible	Negligible	Negligible


5 Model outputs

5.1 Insets 1 to 16 show graphical CadnaA representations of assessment of effect of noise from overhead line noise for conditions. Insets 17 to 32 show CadnaA graphical representations of assessment of effect from noise from overhead line noise for wet conditions. A summary of results is presented in Table 6 for dry conditions and Table 7 for wet conditions.







BUREAU
VERITAS



BUREAU
VERITAS



NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD8-10 Background Noise Level: 30dB LA90 Dry Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/4	
				Date	27.02.14	



NOTES:

Author	D Gray
Checked by	D Bradley
Scale	Defined


400kV Overhead Line Noise Modelling

Span: LD16-18
 Background Noise Level: 30dB LA90
 Dry Conditions

Project No.	8046613
Project Title	Hinkley Point C Connection Project
Drawing No.	8046613/OHLApp/5
Date	27.02.14



BUREAU
VERITAS



NOTES:

Author D Gray

Checked by D Bradley

Scale Defined

400kV Overhead Line Noise Modelling

Span: LD19-21
 Background Noise Level: 32dB LA90
 Dry Conditions

Project No. 8046613


Project Title Hinkley Point C Connection Project

Drawing No. 8046613/OHLApp/6


Date 27.02.14




BUREAU
VERITAS



BUREAU
VERITAS



BUREAU
VERITAS




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD31-32 Background Noise Level: 36dB LA90 Dry Conditions	Project No.	8046613
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project
	Scale	Defined		Drawing No.	8046613/OHLApp/9
				Date	27.02.14




BUREAU
VERITAS
1828




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD50-52 Background Noise Level: 37dB LA90 Dry Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/10	
				Date	27.02.14	



BUREAU
VERITAS




BUREAU
VERITAS




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD77-78 Background Noise Level: 30dB LA90 Dry Conditions	Project No.	8046613
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project
	Scale	Defined		Drawing No.	8046613/OHLApp/13
				Date	27.02.14



BUREAU
VERITAS



NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD80-82 Background Noise Level: 30dB LA90 Dry Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/14	
				Date	27.02.14	



NOTES:

Author D Gray

Checked by D Bradley

Scale Defined

400kV Overhead Line Noise Modelling

Span: LD86-90
Background Noise Level: 30dB LA90
Dry Conditions

Project No. 8046613


Project Title Hinkley Point C Connection Project

Drawing No. 8046613/OHLApp/15


Date 27.02.14




**BUREAU
VERITAS**




BUREAU
VERITAS




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: ZGA7-9 Background Noise Level: 42dB LA90 (32dB+41dB) Wet Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/17	
				Date	20.03.14	




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD2-3 Background Noise Level: 41dB LA90 (30dB+41dB) Wet Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/18	
				Date	20.03.14	




BUREAU
VERITAS




BUREAU
VERITAS




BUREAU
VERITAS




BUREAU
VERITAS




BUREAU
VERITAS



NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD25-26 Background Noise Level: 42dB LA90 (32dB+41dB) Wet Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/24	
				Date	20.03.14	




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD31-32 Background Noise Level: 42dB LA90 (36dB+41dB) Wet Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/25	
				Date	20.03.14	



NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD31-32 Background Noise Level: 42dB LA90 (37dB+41dB) Wet Conditions	Project No.	8046613
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project
	Scale	Defined		Drawing No.	8046613/OHLApp/26
				Date	20.03.14




BUREAU
VERITAS




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD59-63 Background Noise Level: 43dB LA90 (38dB+41dB) Wet Conditions	Project No.	8046613
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project
	Scale	Defined		Drawing No.	8046613/OHLApp/27
				Date	20.03.14




BUREAU
VERITAS



BUREAU
VERITAS




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD77-78 Background Noise Level: 41dB LA90 (30dB+41dB) Wet Conditions	Project No.	8046613	 BUREAU VERITAS
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project	
	Scale	Defined		Drawing No.	8046613/OHLApp/29	
				Date	20.03.14	




NOTES:	Author	D Gray	400kV Overhead Line Noise Modelling Span: LD80-82 Background Noise Level: 41dB LA90 (30dB+41dB) Wet Conditions	Project No.	8046613
	Checked by	D Bradley		Project Title	Hinkley Point C Connection Project
	Scale	Defined		Drawing No.	8046613/OHLApp/30
				Date	20.03.14



BUREAU
VERITAS



BUREAU
VERITAS



NOTES:

Author

D Gray

Checked by

D Bradley

Scale

Defined

400kV Overhead Line Noise Modelling

Span: LD97-100

Background Noise Level: 45dB LA90 (42dB+41dB)
Wet Conditions

Project No.

8046613

Project Title

Hinkley Point C Connection Project

Drawing No.

8046613/OHLApp/32

Date

20.03.14



BUREAU
VERITAS

5.2 Tables 6 and 7 summarise the overhead line noise levels, predicted using CadnaA modelling in accordance with BS 9613-2, at each selected receptor location for dry and wet conditions respectively. The assessment is based on measured background noise levels as described in **Volume 5.14, Appendix 14E Summary of Night-time Background Noise Measurements on Route of Proposed 400kV Overhead Line**.

Table 6 Summary of predicted noise levels from overhead lines at identified sensitive receptor locations for dry conditions

Receptor Ref.	Receptor Name	Background Noise Level, dB L_{A90}	Predicted 400kV Overhead Line Noise Level, dB L_{Aeq}	Assessment Level, dB	Effect Magnitude
1	Hillside Farm	32	21.1	-10.9	No effect
2	The Yards	32	22.2	-9.8	Negligible
3	East Farm	32	22.1	-9.9	Negligible
4	99 Woolavington Road	32	20	-12.0	No effect
5	Homestead Farm	30	22.5	-7.5	Negligible
6	Cote Lea	30	21.9	-8.1	Negligible
7	Elm Cottage	30	20.5	-9.5	Negligible
8	Sunningdale	30	19.7	-10.3	No effect
9	Cripps Farm	30	19.4	-10.6	No effect
10	Cripps Farm Caravans	30	25.3	-4.7	Low
11	Merry Farm	30	21.3	-8.7	Negligible
12	Willow Cottage	30	20.1	-9.9	Negligible
13	Yardwell House	30	20.5	-9.5	Negligible
14	Wainbridge	30	20.7	-9.3	Negligible
15	Dwelling	30	18.7	-11.3	No effect
16	Wainbridge Farm	30	22	-8.0	Negligible
17	The Yews	30	19.6	-10.4	No effect
18	Court Farm	30	23	-7.0	Negligible
19	Court Villa	30	21	-9.0	Negligible
20	Little Dean	30	20.6	-9.4	Negligible
21	Ashdene	30	20.2	-9.8	Negligible
22	Portland Cottage	30	19.3	-10.7	No effect
23	Victory House	32	23	-9.0	Negligible
24	Sunnydene	32	23.9	-8.1	Negligible
25	Withy Cottage	32	26.4	-5.6	Negligible
26	Poachers Cottage	32	19.1	-12.9	No effect
27	Vole House Farm	32	20.5	-11.5	No effect
28	Pillrow	32	22.5	-9.5	Negligible
29	Acacia Farm	36	21.2	-14.8	No effect

Hinkley Point C Connection Project

Appendix 14G – 400kV Overhead Line Noise Modelling

Receptor Ref.	Receptor Name	Background Noise Level, dB L _{A90}	Predicted 400kV Overhead Line Noise Level, dB L _{Aeq}	Assessment Level, dB	Effect Magnitude
30	Laurel Cottage	36	19	-17.0	No effect
31	The Willows	36	21.7	-14.3	No effect
32	Little Willows	36	19.8	-16.2	No effect
33	Flat above Garage	36	29.2	-6.8	Negligible
34	Tarnock Cottage	36	27.2	-8.8	Negligible
35	South View	36	21.8	-14.2	No effect
36	Tarnock Farm	36	25.1	-10.9	No effect
37	Willow Cottage	36	20.2	-15.8	No effect
38	Ty Barah	36	19.4	-16.6	No effect
39	Moorland Park	37	27.9	-9.1	Negligible
40	Heathgate	37	24.4	-12.6	No effect
41	Middle Elm	37	21.3	-15.7	No effect
42	Primrose Cottage	38	21.5	-16.5	No effect
43	Orchardside	38	21	-17.0	No effect
44	Rose Lea Cottage	38	19.8	-18.2	No effect
45	Hope Farm	38	22.4	-15.6	No effect
46	Homeground	38	22.6	-15.4	No effect
47	Oakland Farm	38	22.3	-15.7	No effect
48	Rose Bungalow	37	23.4	-13.6	No effect
49	Manor Farm	37	23	-14	No effect
50	Causeway House	30	20.3	-9.7	Negligible
51	Yeovil	30	21.4	-8.6	Negligible
52	Little Orchard	30	19.5	-10.5	No effect
53	Furze	30	21.2	-8.8	Negligible
54	Lavender Cottage	30	19.7	-10.3	No effect
55	Stone Edge Farm	30	22.4	-7.6	Negligible
56	Stone Edge Barn	30	21.3	-8.7	Negligible
57	Stonewell Barn	30	19.2	-10.8	No effect
58	1 Clevedon Road	30	24.4	-5.6	Negligible
59	2 Clevedon Road	30	23.9	-6.1	Negligible
60	Stone Edge Cottage	30	24.2	-5.8	Negligible
61	Honeysuckle Cottage	30	25.7	-4.3	Low
62	Wellhouse Farm	30	20.4	-9.6	Negligible
63	The Gables	30	22	-8.0	Negligible
64	The Granary	30	23.3	-6.7	Negligible

Receptor Ref.	Receptor Name	Background Noise Level, dB L _{A90}	Predicted 400kV Overhead Line Noise Level, dB L _{Aeq}	Assessment Level, dB	Effect Magnitude
65	12 Clevedon Road	30	21.9	-8.1	Negligible
66	The Elms	30	21.5	-8.5	Negligible
67	11 Clevedon Road	30	22.1	-7.9	Negligible
68	Dwelling	30	25.7	-4.3	Low
69	Star Inn	30	30.6	+0.6	Medium
70	Naish Cottage	30	18.3	-11.7	No effect
71	Hunters Croft	30	20.6	-9.4	Negligible
72	Birchwood	30	20.1	-9.9	Negligible
73	Deep Acres	30	21.2	-8.8	Negligible
74	Spindlewood	30	24.2	-5.8	Negligible
75	Cuckoos Mead	30	24.1	-5.9	Negligible
76	Naish Lodge	42	33.1	-8.9	Negligible
77	Cole Acre	42	26.8	-15.2	No effect
78	The Meadow	42	25	-17.0	No effect
79	18 Elm Tree Park +	42	24.5	-17.5	No effect

Note:- Receptors 77 to 79 relate only to preferred route (Option A).

Table 7 Summary of predicted noise levels from overhead lines at identified sensitive receptor locations for wet conditions

Receptor Ref.	Receptor Name	Background Noise Level, dB L _{A90}	Predicted 400kV Overhead Line Noise Level, dB L _{Aeq}	Assessment Level, dB	Effect Magnitude
1	Hillside Farm	42	36.1	-5.9	Negligible
2	The Yards	42	37.3	-4.7	Low
3	East Farm	42	37.1	-4.9	Low
4	99 Woolavington Road	42	34.9	-7.1	Negligible
5	Homestead Farm	41	37.6	-3.4	Low
6	Cote Lea	41	36.9	-4.1	Low
7	Elm Cottage	41	35.4	-5.6	Negligible
8	Sunningdale	41	34.7	-6.3	Negligible
9	Cripps Farm	41	34.3	-6.7	Negligible
10	Cripps Farm Caravans	41	40.5	-0.5	Low
11	Merry Farm	41	36.3	-4.7	Low
12	Willow Cottage	41	35	-6.0	Negligible

Hinkley Point C Connection Project

Appendix 14G – 400kV Overhead Line Noise Modelling

Receptor Ref.	Receptor Name	Background Noise Level, dB L_{A90}	Predicted 400kV Overhead Line Noise Level, dB L_{Aeq}	Assessment Level, dB	Effect Magnitude
13	Yardwell House	41	35.4	-5.6	Negligible
14	Wainbridge	41	35.6	-5.4	Negligible
15	Dwelling	41	33.6	-7.4	Negligible
16	Wainbridge Farm	41	37	-4.0	Low
17	The Yews	41	34.6	-6.4	Negligible
18	Court Farm	41	38.1	-2.9	Low
19	Court Villa	41	36	-5	Negligible
20	Little Dean	41	35.6	-5.4	Negligible
21	Ashdene	41	35.2	-5.8	Negligible
22	Portland Cottage	41	34.2	-6.8	Negligible
23	Victory House	42	38	-4.0	Low
24	Sunnydene	42	38.9	-3.1	Low
25	Withy Cottage	42	41.5	-0.5	Low
26	Poachers Cottage	42	34	-8.0	Negligible
27	Vole House Farm	42	35.4	-6.6	Negligible
28	Pillrow	42	37.5	-4.5	Low
29	Acacia Farm	42	36.2	-5.8	Negligible
30	Laurel Cottage	42	33.9	-8.1	Negligible
31	The Willows	42	36.7	-5.3	Negligible
32	Little Willows	42	34.7	-7.3	Negligible
33	Flat above Garage	42	44.5	+2.5	Medium
34	Tarnock Cottage	42	42.4	+0.4	Medium
35	South View	42	36.8	-5.2	Negligible
36	Tarnock Farm	42	40.3	-1.7	Low
37	Willow Cottage	42	35.2	-6.8	Negligible
38	Ty Barah	42	34.3	-7.7	Negligible
39	Moorland Park	42	43.2	+1.2	Medium
40	Heathgate	42	39.5	-2.5	Low
41	Middle Elm	42	36.3	-5.7	Negligible
42	Primrose Cottage	43	36.5	-6.5	Negligible
43	Orchardside	43	35.9	-7.1	Negligible
44	Rose Lea Cottage	43	34.7	-8.3	Negligible
45	Hope Farm	43	37.4	-5.6	Negligible
46	Homeground	43	37.7	-5.3	Negligible
47	Oakland Farm	43	37.3	-5.7	Negligible

Hinkley Point C Connection Project

Appendix 14G – 400kV Overhead Line Noise Modelling

Receptor Ref.	Receptor Name	Background Noise Level, dB L _{A90}	Predicted 400kV Overhead Line Noise Level, dB L _{Aeq}	Assessment Level, dB	Effect Magnitude
48	Rose Bungalow	42	38.4	-3.6	Low
49	Manor Farm	42	38	-4.0	Low
50	Causeway House	41	35.3	-5.7	Negligible
51	Yeovil	41	36.4	-4.6	Low
52	Little Orchard	41	34.4	-6.6	Negligible
53	Furze	41	36.2	-4.8	Low
54	Lavender Cottage	41	34.7	-6.3	Negligible
55	Stone Edge Farm	41	37.4	-3.6	Low
56	Stone Edge Barn	41	36.3	-4.7	Low
57	Stonewell Barn	41	34.2	-6.8	Negligible
58	1 Clevedon Road	41	39.6	-1.4	Low
59	2 Clevedon Road	41	39	-2.0	Low
60	Stone Edge Cottage	41	39.3	-1.7	Low
61	Honeysuckle Cottage	41	40.9	-0.1	Low
62	Wellhouse Farm	41	35.4	-5.6	Negligible
63	The Gables	41	37.1	-3.9	Low
64	The Granary	41	38.3	-2.7	Low
65	12 Clevedon Road	41	36.9	-4.1	Low
66	The Elms	41	36.5	-4.5	Low
67	11 Clevedon Road	41	37.2	-3.8	Low
68	Dwelling	41	40.8	-0.2	Low
69	Star Inn	41	45.9	+4.9	Medium
70	Naish Cottage	41	33.2	-7.8	Negligible
71	Hunters Croft	41	35.6	-5.4	Negligible
72	Birchwood	41	35.1	-5.9	Negligible
73	Deep Acres	41	36.2	-4.8	Low
74	Spindlewood	41	39.3	-1.7	Low
75	Cuckoos Mead	41	39.2	-1.8	Low
76	Naish Lodge	41	36.1	-4.9	Low
77	Cole Acre	45	42	-3.0	Low
78	The Meadow	45	40.1	-4.9	Low
79	18 Elm Tree Park + Others	45	39.6	-5.4	Negligible

Note:- Receptors 77 to 79 relate only to preferred route (Option A).

- 5.3 All assessed receptors are of medium sensitivity.
- 5.4 Results indicate that the magnitude of 400kV overhead line operational noise is of low, negligible or of no effect at the majority of receptors. The significance of effect is therefore **negligible adverse** or **negligible** for negligible and no magnitude effects and **minor adverse** for low magnitude effects for both dry and wet conditions.
- 5.5 During dry conditions the magnitude of 400kV overhead line operational noise is of medium effect at the Star Inn. The significance of effect is therefore **moderate adverse**.
- 5.6 During wet conditions the magnitude of 400kV overhead line operational noise is of medium effect at the Flat above garage (Tarnock), Tarnock Cottage, Moorland Park and the Star Inn. The significance of effect is therefore **moderate adverse**.

6 Limits of deviation

- 6.1 Limits of deviation (LoD) are limits within which the authorised development is permitted to deviate. The implication of these LoD is that sections of the development may be closer or further away from existing receptors than initially proposed. With regards to noise, this implies that level of noise may deviate from those that have been assessed.
- 6.2 Table 8 shows the receptors where a change in route within the LoD would result in an increase of significance of effect from overhead line noise.

Table 8 Summary of potential increase in significance of effect within the limits of deviation

Receptor Ref.	Receptor Name	Condition (Dry/Wet)	Increase in significance from:	Increase in significance to:	Movement [†] Required to Trigger Change, m
10	Cripps Farm Caravans	Wet	Minor adverse	Moderate adverse	6
19	Court Villa	Wet	Negligible Adverse	Minor adverse	2
25	Withy Cottage	Dry	Negligible Adverse	Minor adverse	7
		Wet	Minor adverse	Moderate adverse	4
31	The Willows	Wet	Negligible Adverse	Minor adverse	7
35	South View	Wet	Negligible Adverse	Minor adverse	4
46	Homeground	Wet	Negligible Adverse	Minor adverse	7
58	1 Clevedon Road	Dry	Negligible Adverse	Minor adverse	7
61	Honeysuckle Cottage	Wet	Minor adverse	Moderate adverse	1

[†]Towards receptor